

Dave Morey  
Vice President  
Farley Project

Southern Nuclear  
Operating Company  
P.O. Box 1295  
Birmingham, Alabama 35201  
Tel 205.992.5131



July 25, 1997

Docket Numbers: 50-348  
50-364

Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555


Joseph M. Farley Nuclear Plant  
Additional Response To  
NRC Inspection Report Number 50-348,364/94-28

Ladies and Gentlemen:

NRC Inspection Report Number 50-348,364/94-28 examined the Motor-Operated Valve (MOV) program implemented by Farley Nuclear Plant to determine whether the MOV program met the intent of NRC Generic Letter 89-10, "Safety-Related Motor-Operated Valve Testing and Surveillance." The January 6, 1995, inspection report transmittal letter requested (1) the schedule for resetting the torque switches of the MOVs that did not satisfy revised thrust requirements, and (2) the schedules for updating the MOV setpoint and design documents to reflect revised thrust requirements and thrust output capability. A June 14, 1995, NRC letter approved SNC's proposed schedules for items (1) and (2) above (provided in a March 3, 1995, letter to the NRC), and requested SNC to notify the NRC when the actions were complete. Actions for items (1) and (2) above have been completed.

If there are any questions, please advise.

Respectfully submitted,

  
Dave Morey

DRC:mov-done.doc

cc: Mr. L. A. Reyes, Region II Administrator  
Mr. J. I. Zimmerman, NRR Project Manager  
Mr. T. M. Ross, FNP Senior Resident Inspector

9707300117 970725  
PDR ADOCK 05000348  
G PDR



2201  
1/0