

**Northeast
Nuclear Energy**

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station
Northeast Nuclear Energy Company
P.O. Box 128
Waterford, CT 06385-0128
(860) 447-1791
Fax (860) 444-4277

The Northeast Utilities System

JUL 14 1997

Docket No. 50-336
B16630

Re: 10CFR50.71(a)


U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Millstone Nuclear Power Station, Unit No. 2
Facility Operating License No DPR-65
Monthly Operating Report

In accordance with the reporting requirements of Technical Specification Section 6.9.1.7 for Millstone Unit No. 2, enclosed, in Attachment 1, is the monthly operating report for the month of June 1997.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY



J. A. Price
Director, Millstone Unit No. 2

1/1
Terz

- cc: H. J. Miller, Region I Administrator
D. G. McDonald, Jr., NRC Senior Project Manager, Millstone Unit No. 2
D. P. Beaulieu, Senior Resident Inspector, Millstone Unit No. 2
W. D. Travers, PhD, Director, Special Projects Office

9707300155 970630
PDR ADOCK 05000336
R PDR



Docket No. 50-336

B16630

Attachment 1

Millstone Nuclear Power Station, Unit No. 2

Facility Operating License No. DPR-65
Monthly Operating Report

July 1997

DOCKET NO. 50-336
UNIT Millstone Unit 2
DATE 7/2/97
COMPLETED BY S. Doboie
TELEPHONE (860) 447-1791
EXT 4678

MONTH: JUNE 1997

DAY	AVG. DAILY POWER LEVEL (MWe-Net)	DAY	AVG. DAILY POWER LEVEL (MWe-Net)
1	0	17	0
2	0	18	0
3	0	19	0
4	0	20	0
5	0	21	0
6	0	22	0
7	0	23	0
8	0	24	0
9	0	25	0
10	0	26	0
11	0	27	0
12	0	28	0
13	0	29	0
14	0	30	0
15	0	31	-
16	0		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT NAME Millstone Unit 2
 DATE 7/02/97
 COMPLETED BY S. Doboie
 TELEPHONE (860) 447-1791
 EXT 4678

OPERATING STATUS

- | | | |
|--|-----------|----------------------------|
| 1. Docket Number | 50-336 | |
| 2. Reporting Period | June 1997 | Notes: Items 22 and 23 |
| 3. Utility Contact | S. Doboie | cumulative are weighted |
| 4. Licensed Thermal Power (MWt): | 2700 | averages. Unit operated at |
| 5. Nameplate Rating (Gross MWe): | 909 | 2560 MWTH prior to its |
| 6. Design Electrical Rating (Net MWe): | 870 | uprating to its current |
| 7. Maximum Dependable Capacity (Gross MWe): | 901.63 | 2700 MWTH power level. |
| 8. Maximum Dependable Capacity(Net MWe): | 870.63 | |
| 9. If Changes Occur in Capacity Ratings (Items Number 4 Through 8) Since Last Report,
Give Reasons: | | |
| | N/A | |
| 10. Power Level To Which Restricted, If any (Net MWe): | 0 | |
| 11. Reasons For Restrictions, If Any: NRC Category III Facility; NRC Confirmatory Order requiring
implementation of an independent corrective action verification program; NRC order requiring a third-party review
of the employee concerns program at Millstone 2; design basis verification response pursuant to 10CFR50.54(f). | | |

	This Month	Yr.-To-Date	Cumulative
12. Hours In Reporting Period	720.0	4343.0	188591.0
13. Number Of Hours Reactor Was Critical	0.0	0.0	121911.7
14. Reactor Reserve Shutdown Hours	0.0	0.0	2205.5
15. Hours Generator On-Line	0.0	0.0	116611.9
16. Unit Reserve Shutdown Hours	0.0	0.0	468.2
17. Gross Thermal Energy Generated (MWH)	0.0	0.0	300862506.4
18. Gross Electrical Energy Generated (MWH)	0.0	0.0	98709460.0
19. Net Electrical Energy Generated (MWH)	-1823.7	-12753.6	94628429.8
20. Unit Service Factor	0.0	0.0	61.8
21. Unit Availability Factor	0.0	0.0	62.1
22. Unit Capacity Factor (Using MDC Net)	0.0	0.0	58.6
23. Unit Capacity Factor (Using DER Net)	0.0	0.0	57.8
24. Unit Forced Outage Rate	100.0	100.0	21.6
25. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): Shutdown at the time of this report			
26. If Unit Shutdown At End Of Report Period, Estimated Date of Startup:	To be determined		
27. Units In Test Status (Prior to Commercial Operation):			
	Forecast	Achieved	
INITIAL CRITICALITY	N/A	N/A	
INITIAL ELECTRICITY	N/A	N/A	
COMMERCIAL OPERATION	N/A	N/A	

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-336
 UNIT NAME Millstone Unit 2
 DATE 07/02/97
 COMPLETED BY S. Dobe
 TELEPHONE (860) 447-1791
 EXT 4678

REPORT MONTH: June 1997

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	License Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
97-01	03/07/96	S/F	720	B/D	4	N/A	N/A	N/A	<p>Scheduled: Continued mid cycle surveillance testing from previous month.</p> <p>Forced: Continued from previous month. NRC Category III facility; NRC Confirmatory Order requiring independent corrective action verification; NRC order requiring third party review of Millstone Station employee concerns program; design basis verification for response to NRC pursuant to 10CRF50.54(f).</p>

¹F: Forced
 S: Scheduled

²Reason:
 A - Equipment Failure (Explain)
 B - Maintenance or Test
 C - Refueling
 D - Regulatory Restriction
 E - Operator Training & License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other (Explain)

³Method
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continued from Previous Month
 5 - Power Reduction (Duration = 0)
 6 - Other (Explain)

⁴IEEE Standard 805-1984,
 "Recommended Practices for System Identification in Nuclear Power Plants and Related Facilities"

⁵IEEE Standard 803A-1983,
 "Recommended Practices for Unique identification in Power Plants and Related Facilities - Component Function Identifiers"

REFUELING INFORMATION REQUEST

1. Name of the facility: Millstone Unit 2
2. Scheduled date for next refueling outage: First Quarter of 1999
3. Scheduled date for restart following refueling: Last Quarter of 1997 (Note - The current shutdown is not a refueling outage. This date represents the expected startup date from the current shutdown.)
4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?
Yes. There are 12 Technical Specification Change Requests which will be submitted to the NRC prior to startup. These include the following: 1) Modify the minimum instrument accuracy for Meteorological Tower instrumentation. 2) Eliminate the reference to the measurement location for the ultimate heat sink. 3) Eliminate the requirement to enter LCO 3.0.3 when the enclosure building is breached, due to making both trains of enclosure building ventilation system inoperable (unable to create a vacuum within specified time period). 4) Redefine containment integrity to permit operator action during periods when containment isolation valves may be opened under administrative controls. Also relocates the list of containment isolation valves from Technical Specifications to Technical Requirements Manual. 5) Modify the bases for specification to resolve the emergency diesel generator fuel oil storage capacity issues. 6) Revise several surveillance requirements regarding Control Room Ventilation System. 7) Certain RPS and ESAS trips did not consider the uncertainty associated with a Harsh Environment. Some RPS and ESAS setpoints were based on 24 months instead of 18 months. 8) Verbatim compliance issues. ECCS throttle valves. AFW surv. 9) Correct RCS Pressure/Temperature curves due to errors. 10) Modify Table 3.7-1 to correct errors. Reactor trip setpoints for steam generator safety valves in Table 3.7-1 are incorrectly based on 107% power instead of 106.6%. 11) Reduce maximum containment pressure from 2.1 psig to 1.0 psig to support accident analysis assumptions. 12) May be necessary to modify the safety limit curve due to changes in minimum RCS flow associated with the DNB Margin Technical Specification.
5. Scheduled date(s) for submitting licensing action and supporting information:
August 15, 1997

6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures:
Small Break LOCA analysis changes, Large Break LOCA analysis changes,
and Uncontrolled Rod Withdrawal analysis changes.

7. The number of fuel assemblies (a) in the core and (b) in the spent fuel storage pool:
In Core: (a) 0 In Spent Fuel Pool: (b) 1085

NOTE: These numbers represent the total Fuel Assemblies and Consolidated
Fuel Storage Boxes (3 total containing the fuel rods from 6 fuel
assemblies) in these two (2) Item Control Areas.

8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies:
Present storage capacity: 1306 storage locations

9. The projected date of the last refueling that can be discharged to the spent fuel pool assuming present license capacity:
2001, Spent Fuel Pool Full, Core offload capacity is reached.
2005, Core Full, Spent Fuel Pool Full.