

FEB 18 1988

Docket No. 50-219

Mr. P. B. Fiedler
Vice President and Director
Oyster Creek Nuclear Generating Station
Post Office Box 388
Forked River, New Jersey 08731

Dear Mr. Fiedler:

SUBJECT: STANDBY LIQUID CONTROL SYSTEM COMPLIANCE WITH THE ATWS
RULE - 10 CFR 50.62(c)(4) - OYSTER CREEK NUCLEAR GENERATING
STATION (TAC NO. 66126)

By letter dated September 3, 1987 and December 30, 1987, GPU Nuclear Corporation provided information concerning the requirements of 10 CFR 50.62 for Oyster Creek Nuclear Generating Station. Based on our review of this information, we have concluded that the proposed design for the Standby Liquid Control System is consistent with the requirement of 10 CFR 50.62(c)(4) and is acceptable. This is discussed in the enclosed Safety Evaluation. Other matters related to the requirements of 10 CFR 50.62 will be the subject of a future letter from the staff when the evaluation is completed.

It is requested that you submit a Technical Specification Change Request that will provide limiting conditions for operations and surveillance requirements for the Standby Liquid Control System as discussed in the staff's Safety Evaluation. You are requested to respond to this request by March 31, 1988 so that the staff can complete its review in accordance with the schedule completion date.

The reporting and/or recordkeeping requirements contained in this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P.L. 97-511.

Sincerely,
original signed by

Alexander W. Dromerick, Project Manager
Project Directorate I-4
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Enclosure: As stated

cc w/enclosure
See next page

8802240332 880214
PDR ADOCK 05000219
P PDR

DISTRIBUTION

Docket File	A. Dromerick
NRC & Local PDRs	OGC
PD#I-4 Rdg.	E. Jordan
S. Varga	J. Partlow
B. Boger	ACRS (10)
S. Norris	Grey File

LA: PDI-4
S. Norris
02/17/88

PM: PDI-4
ADromerick:bd
02/17/88

D: PDI-4
JStolz
02/18/88

Mr. P. B. Fiedler
Oyster Creek Nuclear Generating Station

Oyster Creek Nuclear
Generating Station

cc:
Ernest L. Blake, Jr.
Shaw, Pittman, Potts and Trowbridge
2300 N Street, NW
Washington, D.C. 20037

Resident Inspector
c/o U.S. NRC
Post Office Box 445
Forked River, New Jersey 08731

J.B. Liberman, Esquire
Bishop, Liberman, Cook, et al.
1155 Avenue of the Americas
New York, New York 10036

Commissioner
New Jersey Department of Energy
101 Commerce Street
Newark, New Jersey 07102

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Mr. David M. Scott, Acting Chief
Bureau of Nuclear Engineering
Department of Environmental Protection
CN 411
Trenton, New Jersey 08625

BWR Licensing Manager
GPU Nuclear Corporation
1 Upper Pond Road
Parsippany, New Jersey 07054

Deputy Attorney General
State of New Jersey
Department of Law and Public Safety
36 West State Street - CN 112
Trenton, New Jersey 08625

Mayor
Lacey Township
818 West Lacey Road
Forked River, New Jersey 08731

Licensing Manager
Oyster Creek Nuclear Generating Station
Mail Stop: Site Emergency Bldg.
P. O. Box 388
Forked River, New Jersey 08731