

November 12, 1996

Mr. Paul J. Telthorst  
Director - Licensing  
Clinton Power Station  
P. O. Box 678  
Mail Code V920  
Clinton, IL 61727

SUBJECT: ASME SECTION XI RELIEF REQUESTS REGARDING PERFORMANCE OF LEAKAGE AND PRESSURE TESTING FOR THE FIRST 120-MONTH INSERVICE INSPECTION INTERVAL - CLINTON POWER STATION (TAC NO. M96230)

Dear Mr. Telthorst:

By letter dated July 29, 1996 (U-602614), Illinois Power submitted two requests for relief from the requirements of Section XI of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, 1980 Edition through Winter 1981 Addenda. These requests were with regard to the performance of leakage and pressure testing for primary containment isolation valves and selected ASME Code Class 2 pressure retaining components penetrating the drywell and primary containment. As stated in your letter, inspection activities for the first 120-month inservice inspection interval are due to be completed during the sixth refueling outage at Clinton Power Station, currently scheduled to begin October 13, 1996.

Relief Request 1004 was a request to allow a change in the required frequency of pressure testing selected ASME Code Class 2 pressure retaining components penetrating the drywell and primary containment. As stated in the enclosed safety evaluation, the staff has determined that the affected components are not required to be tested by the Code and, therefore, a relief request is not necessary.

Relief Request 2037 was a request to use Part 10, Paragraph 4.2.2.2, "Containment Isolation Valves," of ASME/ANSI OMA 1988 Addenda to ASME/ANSI OM 1987 (OM-10) for leakage rate testing of primary containment isolation valves. This request, which will allow the use of extended valve leak rate test frequencies allowed by 10 CFR Part 50, Appendix J - Option B, is approved pursuant to 10 CFR 50.55a(f)(4)(iv).

Sincerely,  
Original signed by:  
Gail H. Marcus, Director  
Project Directorate III-3  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

**NRC FILE CENTER COPY**

Docket No. 50-461

Enclosure: As stated

cc w/encl: See next page

DISTRIBUTION: See attached sheet.

DFO/1

DOCUMENT NAME: G:\CLINTON\CLI96230.LTR

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	LA:PDIII-3	E	PM:PDIII-3	E	SC:EMEB	BC;EMCB
NAME	DFoster-Curseen		DPickett		TScarbrough*	GBagchi**
DATE	10/4/96		10/4/96		08/07/96	09/17/96

OFFICE	PD:PDIII-3	E	OGC
NAME	GMarcus GHM		MYoung***
DATE	10/7/96		10/16/96

OFFICIAL RECORD COPY

\* Memo from TScarbrough to GMarcus dated 8/7/96 \*\*\* See previous concurrence

\*\* Memo from GBagchi to GMarcus dated 9/17/96

9611180112 961112  
PDR ADOCK 05000461  
P PDR

November 12, 1996

Mr. Paul J. Telthorst  
Director - Licensing  
Clinton Power Station  
P. O. Box 678  
Mail Code V920  
Clinton, IL 61727

SUBJECT: ASME SECTION XI RELIEF REQUESTS REGARDING PERFORMANCE OF LEAKAGE AND PRESSURE TESTING FOR THE FIRST 120-MONTH INSERVICE INSPECTION INTERVAL - CLINTON POWER STATION (TAC NO. M96230)

Dear Mr. Telthorst:

By letter dated July 29, 1996 (U-602614), Illinois Power submitted two requests for relief from the requirements of Section XI of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, 1980 Edition through Winter 1981 Addenda. These requests were with regard to the performance of leakage and pressure testing for primary containment isolation valves and selected ASME Code Class 2 pressure retaining components penetrating the drywell and primary containment. As stated in your letter, inspection activities for the first 120-month inservice inspection interval are due to be completed during the sixth refueling outage at Clinton Power Station, currently scheduled to begin October 13, 1996.

Relief Request 1004 was a request to allow a change in the required frequency of pressure testing selected ASME Code Class 2 pressure retaining components penetrating the drywell and primary containment. As stated in the enclosed safety evaluation, the staff has determined that the affected components are not required to be tested by the Code and, therefore, a relief request is not necessary.

Relief Request 2037 was a request to use Part 10, Paragraph 4.2.2.2, "Containment Isolation Valves," of ASME/ANSI OMa 1988 Addenda to ASME/ANSI OM 1987 (OM-10) for leakage rate testing of primary containment isolation valves. This request, which will allow the use of extended valve leak rate test frequencies allowed by 10 CFR Part 50, Appendix J - Option B, is approved pursuant to 10 CFR 50.55a(f)(4)(iv).

Sincerely,  
Original signed by:  
Gail H. Marcus, Director  
Project Directorate III-3  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-461

Enclosure: As stated

cc w/encl: See next page

DISTRIBUTION: See attached sheet.

DOCUMENT NAME: G:\CLINTON\CLI96230.LTR

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	LA:PDIII-3	E	PM:PDIII-3	E	SC:EMEB		BC;EMCB
NAME	DFoster-Curseen		DPickett		TScarborough*		GBagchi**
DATE	10/4/96		10/4/96		08/07/96		09/17/96

OFFICE	PD:PDIII-3	E	OGC
NAME	GMarcus GMM		MYoung***
DATE	10/7/96		10/16/96

OFFICIAL RECORD COPY

\* Memo from TScarborough to GMarcus dated 8/7/96 \*\*\* See previous concurrence  
\*\* Memo from GBagchi to GMarcus dated 9/17/96





UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

November 12, 1996

Mr. Paul J. Telthorst  
Director - Licensing  
Clinton Power Station  
P. O. Box 678  
Mail Code V920  
Clinton, IL 61727

SUBJECT: ASME SECTION XI RELIEF REQUESTS REGARDING PERFORMANCE OF LEAKAGE AND PRESSURE TESTING FOR THE FIRST 120-MONTH INSERVICE INSPECTION INTERVAL - CLINTON POWER STATION (TAC NO. M96230)

Dear Mr. Telthorst:

By letter dated July 29, 1996 (U-602614), Illinois Power submitted two requests for relief from the requirements of Section XI of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, 1980 Edition through Winter 1981 Addenda. These requests were with regard to the performance of leakage and pressure testing for primary containment isolation valves and selected ASME Code Class 2 pressure retaining components penetrating the drywell and primary containment. As stated in your letter, inspection activities for the first 120-month inservice inspection interval are due to be completed during the sixth refueling outage at Clinton Power Station, currently scheduled to begin October 13, 1996.

Relief Request 1004 was a request to allow a change in the required frequency of pressure testing selected ASME Code Class 2 pressure retaining components penetrating the drywell and primary containment. As stated in the enclosed safety evaluation, the staff has determined that the affected components are not required to be tested by the Code and, therefore, a relief request is not necessary.

Relief Request 2037 was a request to use Part 10, Paragraph 4.2.2.2, "Containment Isolation Valves," of ASME/ANSI OMa 1988 Addenda to ASME/ANSI OM 1987 (OM-10) for leakage rate testing of primary containment isolation valves. This request, which will allow the use of extended valve leak rate test frequencies allowed by 10 CFR Part 50, Appendix J - Option B, is approved pursuant to 10 CFR 50.55a(f)(4)(iv).

Sincerely,

Gail H. Marcus, Director  
Project Directorate III-3  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-461

Enclosure: As stated

cc w/encl: See next page

Distribution w/encl: Clinton Relief TAC NO. M96230 dated November 12, 1996

Docket

PUBLIC

PDIII-3 Reading

J. Roe

E. Adensam (E)

ACRS

OGC

G. Hill (2)

B. McCabe

J. Caldwell, RIII

Mr. Paul J. Telthorst  
Illinois Power Company

Clinton Power Station  
Unit No. 1

cc:

Mr. Wilfred Connell  
Vice President  
Clinton Power Station  
Post Office Box 678  
Clinton, Illinois 61727

Illinois Department  
of Nuclear Safety  
Office of Nuclear Facility Safety  
1035 Outer Park Drive  
Springfield, Illinois 62704

Mr. Daniel P. Thompson  
Manager Nuclear Station  
Engineering Department  
Clinton Power Station  
Post Office Box 678  
Clinton, Illinois 61727

Resident Inspector  
U.S. Nuclear Regulatory Commission  
RR#3, Box 229 A  
Clinton, Illinois 61727

Mr. R. T. Hill  
Licensing Services Manager  
General Electric Company  
175 Curtner Avenue, M/C 481  
San Jose, California 95125

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
801 Warrenville Road  
Lisle, Illinois 60532-4351

Chairman of DeWitt County  
c/o County Clerk's Office  
DeWitt County Courthouse  
Clinton, Illinois 61727

Mr. J. W. Blattner  
Project Manager  
Sargent & Lundy Engineers  
55 East Monroe Street  
Chicago, Illinois 60603