

From: PAUL M. BLANCH <PMBLANCH@ix.netcom.com>
To: JZ <JAZWOL@aol.com>
Date: 10/27/96 2:32pm
Subject: VY

John/David

This in in response to your letter on VY dated 10/16/96

Paul What kind of response are they looking for? Generally it covers the issues. They can submit it to VY without my name. Did you get my message about me talking to the Brattleboro Reformer on 10/26? On the DG's; I would put it like; the vernon tie is not equivalent to a DG. Example: no monthly load testing of the tie line. Another: Vy is saying that the line has a very high degree of reliability-historically. What they base that on, is they can detect voltage, not testing under load monthly. An interesting other question; I think NE electric is putting the Vernon Dam up for sale. How will the new owners' maintain the Dam and agreements with Vermont Yankee? Maybe VY should control the Dam now.

Paul M. Blanch
Energy Consultant
135 Hyde Rd.
West Hartford CT 06117
Voice 860-236-0326
Fax 860-232-9350