

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Joseph M. Farley - Unit 1	DOCKET NUMBER (2) 0 5 0 0 0 3 4 8	PAGE (3) 1 OF 0 3
--	--------------------------------------	----------------------

TITLE (4) Personnel Errors Result In Special Report Not Being Submitted For An Inoperable Fire Door

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)
0 2	1 2	8 8	8 8	0 0 3	0 0	0 2	1 9	8 8			0 5 0 0 0
											0 5 0 0 0

OPERATING MODE (9) 1	THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § (Check one or more of the following) (11)									
POWER LEVEL (10) 11010	<input type="checkbox"/> 20.402(b)	<input type="checkbox"/> 20.405(c)	<input type="checkbox"/> 50.73(a)(2)(iv)	<input type="checkbox"/> 73.71(b)						
	<input type="checkbox"/> 20.405(a)(1)(i)	<input type="checkbox"/> 50.36(c)(1)	<input type="checkbox"/> 50.73(a)(2)(v)	<input type="checkbox"/> 73.71(c)						
	<input type="checkbox"/> 20.405(a)(1)(ii)	<input checked="" type="checkbox"/> 50.36(c)(2)	<input type="checkbox"/> 50.73(a)(2)(vi)	<input checked="" type="checkbox"/> OTHER (Specify in Abstract below and in Text, NRC Form 356A)						
	<input type="checkbox"/> 20.405(a)(1)(iii)	<input checked="" type="checkbox"/> 50.73(a)(2)(i)	<input type="checkbox"/> 50.73(a)(2)(viii)(A)	Special Report per Tech. Spec. 3.7.12						
	<input type="checkbox"/> 20.405(a)(1)(iv)	<input type="checkbox"/> 50.73(a)(2)(ii)	<input type="checkbox"/> 50.73(a)(2)(viii)(B)							
<input type="checkbox"/> 20.405(a)(1)(v)	<input type="checkbox"/> 50.73(a)(2)(iii)	<input type="checkbox"/> 50.73(a)(2)(x)								

LICENSEE CONTACT FOR THIS LER (12)

NAME J. D. Woodard, General Manager - Nuclear Plant	TELEPHONE NUMBER 2 0 5 8 9 9 - 5 1 5 6
--	---

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS

SUPPLEMENTAL REPORT EXPECTED (14) <input type="checkbox"/> YES (If yes, complete EXPECTED SUBMISSION DATE)	<input checked="" type="checkbox"/> NO	EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

On 2-12-88, it was discovered that a Special Report had not been submitted as required by Technical Specification 3.7.12 Action Statement a.

This event was caused by personnel errors. The event was mistakenly believed to not be reportable and thus the plant incident report was not aggressively pursued.

The individuals who were responsible for the investigation of this event and determination of reportability requirements have been counseled.

8802260105 880219  
PDR ADOCK 05000348  
S PDR

1E-22  
11

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1)  Joseph M. Farley - Unit 1	DOCKET NUMBER (2)  0500034888	LER NUMBER (6)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
		88	003	00	02	OF 03

TEXT: If more space is required, use additional NRC Form 388A's (17)

Plant and System Identification:

Westinghouse - Pressurized Water Reactor  
Energy Industry Identification System codes are identified in the text as [XX].

Summary of Event

On 2-12-88, with the unit operating in steady state at 100% reactor power, it was discovered that a Special Report had not been submitted as required by Technical Specification 3.7.12 Action Statement a.

Description of Event

At 0900 on 11-20-87, it was determined that the fire door 152 [NF] was inoperable. This resulted from misalignment of the door in its frame. The required fire watch was established. The door could not be repaired within seven days.

Technical Specification 3.7.12 requires the fire door to be returned to operable status within seven days or a Special Report must be submitted within the following thirty days. Since FNP failed to submit the Special Report, this LER is being submitted.

Cause of Event

This event was caused by personnel errors. The event was mistakenly believed to not be reportable and thus the plant incident report was not aggressively pursued.

Reportability Analysis and Safety Assessment

This event is reportable because a Special Report required by Technical Specification 3.7.12 was not submitted as required.

There was no effect on plant operation due to this event and the health and safety of the public were not affected.

Corrective Action

The individuals who were responsible for the investigation of this event and the determination of reportability requirements have been counseled.

Fire door 152 could not be repaired and must be replaced. A replacement fire door has been ordered and is expected to be received on March 24, 1988. Repairs will be completed as soon as practicable after the door has been received. Fire watch requirements continue to be met and a fire watch will be maintained until the door is replaced and determined functional.

# LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1)  Joseph M. Farley - Unit 1	DOCKET NUMBER (2)  0 5   0 0   0 3   4 8	LER NUMBER (6)			PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			
		8   8	—   0   0   3	—   0   0	0   3	OF	0   3

TEXT (if more space is required, use additional NRC Form 365A's) (17)

Additional Information

No similar LERs have been submitted by Farley Nuclear Plant.

No component failures occurred during this event.

Alabama Power Company  
600 North 18th Street  
Post Office Box 2641  
Birmingham, Alabama 35291-0400  
Telephone 205 250-1835

R. P. McDonald  
Senior Vice President



February 19, 1988

Docket No. 50-348

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555


Dear Sir:

Joseph M. Farley Nuclear Plant - Unit 1  
Licensee Event Report No. LER 88-003-00

Joseph M. Farley Nuclear Plant, Unit 1, Licensee Event Report No. LER 88-003-00 is being submitted in accordance with 10CFR50.73.

If you have any questions, please advise.

Respectfully submitted,



R. P. McDonald

RPM/JAR:dst-D-LER

Enclosure

cc: IE, Region II

IE22  
1/1