

TABLE 15.4.1-1 (3 of 4)

Channel Description	Check	Calibrate	Test	Remarks
24. Containment Pressure	S	R	M**	Narrow range containment pressure (-3.0, +3 psig excluded)
25. Steam Generator Pressure	S***	R	M***	
26. Turbine First Stage Pressure	S**	R	M**	
27. Emergency Plan Radiation Survey Instruments	Q	R	Q	
28. Environmental Monitors	M	N.A.	N.A.	
29. Overpressure Mitigating	S	R	****	
30. PORV Position Indicator	S	R	R	
31. PORV Block Valve Position Indicator	Q	R	N.A.	
32. Safety Valve Position Indicator	M	R	N.A.	
33. PORV Operability	N.A.	R	M	Performance of a channel functional test but excluding valve operation.
34. Subcooling Margin Monitor	M	R	N.A.	
35. Undervoltage on 4KV Bus	N.A.	R	M**	For Auxiliary Feedwater Pump Initiation
36. Auxiliary Feedwater Flow Rate	See Remarks	R	N.A.	Flow Rate indication will be checked at each unit startup and shutdown
37. Degraded 4.16 KV Voltage	S	R	M**	
38. a. Loss of Voltage (4.16 KV)	S	R	M**	
b. Loss of Voltage (480 V)	S	R	M**	
39. 4160 V. Frequency	N.A.	R	N.A.	

BB02260138 880223  
PDR ADOCK 05000266  
P PDR

Unit 1-Amendment No. 28, 47, 53, 59  
Unit 2-Amendment No. 38, 39, 60, 64