

UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

January 16, 1997

MEMORANDUM TO: Thomas T. Martin, Director Division of Reactor Program Management

THRU:

Richard L. Emch, Jr., Chief Radiation Protection Section Richa

Richard L.Emch, g.

NRC FILE GENTER COPY RD-10-1 XID & R-5 Facility Line

DYOZ

Radiation Protection Section Much Emergency Preparedness and Radiation Protection Branch Division of Reactor Program Management

FROM: Charles S. Hinson, Health Physicist Emergency Preparedness and Radiation Protection Branch Division of Reactor Program Management

SUBJECT:

LWR OCCUPATIONAL DOSE DATA FOR 1995

Enclosed for your information is the 1995 occupational dose summary for operating U.S. nuclear power plant facilities. This summary contains a listing of the occupational dose for each of the 109 nuclear plants included in the 1995 tabulation, as well as a listing of the number of people receiving doses in each of 13 dose ranges for each of these plants. In addition, this report contains a ranking of PWRs and BWRs in ascending order of collective dose per reactor for 1995 and graphical representations of LWR data (average collective dose, number of workers, number of operating plants, and gross electricity generated) over the twenty-three year period between 1973 and 1995. For the five PWR and five BWR sites which had the highest per unit doses in 1994, this report contains a listing (with corresponding person-rem doses) of the major activities which contributed to these high doses. Over 85% of the collective dose at these sites was accrued during outage periods.

The number of operating reactors in 1995 remained the same as last year's total of 109 units. The average collective dose per reactor for these 109 LWRs was 199 person-cSv (person-rem). This is the same as the 1994 LWR dose average and, together with the average dose for 1994, is the lowest LWR average dose since 1969 (when there were only seven operating LWRs).

The average dose per reactor for the 72 operating PWRs in 1995 was 170 personcSv (person-rem). This represents a 28% increase over the 1994 average of 133 person-cSv (person-rem) per reactor but it is still the third lowest average PWR dose ever recorded (behind 133 person-cSv (person-rem) per reactor recorded in 1994 and 165 person-cSv (person-rem) per reactor, recorded in 1969, the first year when records were kept).

CONTACT: C. Hinson, NRR/PERB 415-1845

9701240035 970116 PDR DRG NRRA PDR

Ovin

January 16, 1997

The average dose per reactor for the 37 operating BWRs in 1995 was 256 personcSv (person-rem). This is significantly lower than the 1994 average of 327 person-cSv (person-rem) per reactor.

- 2 -

As stated earlier, the average LWR dose per reactor in 1995 of 199 person-cSv (person-rem) is the lowest measured average LWR dose since 1969 (the first year in which the NRC began tabulating these figures). The 1995 average dose is over 550 person-cSv (person-rem) per reactor less than the 1983 LWR average of 753 person-cSv (person-rem) per reactor (1983 is the year when the LWR average dose per unit last peaked). In this same time span, the average measurable dose per worker for LWRs has dropped by more than half, from 0.66 rem in 1983 to 0.25 rem in 1995.

This report was compiled by Charles Hinson, NRR, NRC, with the assistance of our contractor, SAIC, which supplied some of the data. Any questions concerning the content of this report should be directed to Charles Hinson at (301) 415-1845.

Attachment: As stated

Distribution:			
Central Files, T5C3	CMiller	REmch	TEssig
JWigginton	CHinson	CWillis	JWiggins, RI
AGibson, RII	GGrant, RIII	TGwynn, RIV	JWhite, RI
KBarr, RII	TKozak, RIII	JPotter, RII	BMurray, RIV
RShortridge, RII	RBores, RI	WRankin, RII	KRaglin, TTD
NShah, RIII	JNoggle, RI	RAnderson, TTC	JHickey, T8A33
JMcCormick-Barger,	RIII	BMorris, T3D2	TERB R/F
TERB S/F(LWR)	ARoecklein, T9C24	FCombs, T8F5	MThomas, T9C24
JGlenn, T9C24	PUBLIC	WBeecher, 02G5	EJordan, T4D18

DOCUMENT NAME: G:\95DOSE

To receive a copy of this document, indicate in the box: "C" = Copy w/o attachment, "E" = Copy w/attachment, "N" = No copy

OFC	PERB	E	SC/PERB	E						
NAME	CHinson:TLC (3H	REmch RZC	P						
DATE	1 110/97		1116197							
Window and the first of the state of the sta	AND ADDRESS OF A DESCRIPTION OF A DESCRIPTION OF A DESCRIPT	Colonic Contraction	and the second	A. P. P. W.	STAL SPACES AAA	2.4	second of the local second in the local second product of the second of the second second second second second	CALLS BE AND AND AND	the second particular state of a same of any and a proof of a second research and a same second research and a	

OFFICIAL RECORD COPY

January 16, 1997

The average dose per reactor for the 37 operating BWRs in 1995 was 256 personcSv (person-rem). This is significantly lower than the 1994 average of 327 person-cSv (person-rem) per reactor.

As stated earlier, the average LWR dose per reactor in 1995 of 199 person-cSv (person-rem) is the lowest measured average LWR dose since 1969 (the first year in which the NRC began tabulating these figures). The 1995 average dose is over 550 person-cSv (person-rem) per reactor less than the 1983 LWR average of 753 person-cSv (person-rem) per reactor (1983 is the year when the LWR average dose per unit last peaked). In this same time span, the average measurable dose per worker for LWRs has dropped by more than half, from 0.66 rem in 1983 to 0.25 rem in 1995.

This report was compiled by Charles Hinson, NRR, NRC, with the assistance of our contractor, SAIC, which supplied some of the data. Any questions concerning the content of this report should be directed to Charles Hinson at (301) 415-1845.

Attachment: As stated

LWR OCCUPATIONAL DOSE DATA FOR 1995

This is a compilation and analysis of occupational radiation doses reported from light-water-cooled reactors (LWRs) for the year 1995. The information was derived from individual worker dose reports submitted to the Commission in accordance with 10 CFR 20.2206.

In 1995 the total number of LWRs included in the list of operating reactors remained the same as last year's total of 109 units (a reactor is added to this list after it has completed its first full year of commercial operation). Reactors which are no longer included in the compilation of reactor data are: Indian Point 1, Rancho Seco, San Onofre 1, Three Mile Island 2, Trojan, and Yankee-Rowe (all pressurized water reactors [PWRs]); Dresden 1, Humboldt Bay, and LaCrosse (all boiling water reactors [BWRs]); and Fort St. Vrain (a high temperature gas cooled reactor).

The total collective dose for all 109 LWRs included in the 1995 listing was 21,674 person-cSv (person-rem) (see Table 1a). This is slightly lower than last year's total of 21,695 person-cSv (person-rem). [Note: In last year's dose report, the 1994 annual dose for Farley 1 and 2 was mistakenly reported as being 89 person-cSv (person-rem). In actuality, Farley's dose in 1994 was 250 person-cSv (person-rem). This correction changes the total LWR collective dose from the previously reported 21,534 person-cSv (person-rem) to the correct value of 21,695 person-cSv (person-rem).] The average collective dose per reactor for LWRs in 1995 was 199 person-cSv (person-rem).] The average collective dose per reactor for LWRs in 1995 was 199 person-cSv (person-rem). This is the same value as the 1994 LWR average dose per reactor (see Figure 1) and it is, along with last year's average, the lowest LWR average dose since 1969 (when there were only seven LWRs operating). The number of workers with measurable dose per reactor increased slightly from 764 in 1994 to 803 in 1995 (see Figure 1). The number of operating reactors and the electrical generation data are shown in Figure 2. The average measurable dose per worker for LWRs has decreased to 0.25 cSv (rem) from the 1994 value of 0.26 cSv (rem) (see Figure 3). This

average dose per worker is 30% of what the average worker dose was 20 years ago. The collective dose per gross megawatt-year (MWe-year) has decreased slightly from a value of 0.28 in 1994 to 0.27 in 1995 (see Figure 3). This is the lowest average yearly value yet measured for this number.

In 1995, the total collective dose for PWRs was 12,207 person-cSv (person-rem) for 72 reactors. The resulting average collective dose per reactor for PWRs in 1995 was 170 person-cSv (person-rem) per reactor (see Figure 1). This represents a 28% increase over the 1994 value of 133 person-cSv (person-rem) per reactor but it is still the third lowest average PWR dose ever recorded (behind 133 person-cSv (person-rem) recorded in 1994 and 165 person-cSv (person-rem) per reactor, recorded in 1969, the first year when records were kept). The average number of personnel with measurable doses per PWR increased from 613 in 1994 to 720 in 1995. The average measurable dose per worker for PWRs in 1995 is 0.24 cSv (rem). This is slightly higher than the 1994 value of 0.22 cSv (rem).

In 1995, the total collective dose for BWRs was 9,467 person-cSv (person-rem) for 37 reactors. The resulting average collective dose per unit for BWRs in 1995 was 256 person-cSv (person-rem) per unit. This is significantly (22%) lower than the 1994 value of 327 person-cSv (person-rem) per unit. The average number of personnel with measurable doses per BWR decreased from 1,057 in 1994 to 964 in 1995. The average measurable dose per worker also decreased, from 0.31 cSv (rem) in 1994 to 0.27 cSv (rem) in 1995.

The compilation in Table 1a represents a breakdown of the collective dose incurred at each LWR that had completed at least one full year of commercial operation by the end of 1995. Table 1a also lists the reactor type and the annual whole body dose distributions for each of the 109 LWRs in this year's compilation. Table 1b presents the same type of dose breakdown for those LWRs which are either no longer in operation or have been in operation for less than one year. The collective dose figures listed in Table 1 are actual total dose figures submitted by the licensee in response to the requirements of 10 CFR 20.2206.

Figure 1 shows the average collective dose figures for PWRs, BWRs, and LWRs for the years 1973-1995. For the twenty-second consecutive year, the average collective dose per reactor for BWRs has remained higher than that for PWRs. The lower half of Figure 1 shows the number of workers with measurable dose per reactor for the years 1973-1995. This number has been gradually decreasing since 1984, when it peaked at an average of 1522 personnel with measurable doses per plant. Figure 2 is a plot of the total number of operating reactors and the gross electricity generated for each of the years from 1973-1995. As can be seem from these figures, the gross electricity generated has continued to increase (growing 20% in the past eight years), even though the number of operating reactors leveled out five years ago.

Table 2a lists the 72 PWRs in ascending order of collective dose per reactor for 1995. As stated previously, the PWR average collective dose per reactor in 1995 was 170 person-cSv (person-rem). The number of PWRs which reported collective doses of 100 person-cSv (person-rem) per reactor or less was down from thirty reactors in 1994 to fifteen reactors in 1995 (21% of the PWR units in Table 2a). Ten years ago, only four PWRs reported average collective doses of 100 person-cSv (person-rem) per reactor or less. One hundred person-cSv (person-rem) is the annual dose limit that is being used as the goal for the advanced reactor designs. The five PWR sites (six individual reactors) with the highest collective doses in 1995 all exceeded 398 person-cSv (person-rem) per reactor. These reactors were Maine Yankee, Indian Pt. 2, Palisades, Haddam Neck, and Zion 1 and 2. Although representing only 8% of the 72 PWRs counted in 1995, they contributed nearly 24% of the total collective dose at PWRs. Some of the activities which contributed to the collective dose accumulated at the PWR with the highest average dose per reactor in 1995 [Maine Yankee, with 653 person-cSv (person-rem)] were steam generator related work (including tube sleeving, eddy current testing, and sludge lancing), reactor coolant pump work, outage support, valve work, decontamination, refueling activities, and inservice inspection. In 1995, the collective dose per MWe-year for PWRs was 0.22. This indicates a better than 4:1 ratio of MWe-years generated to the collective dose accumulated during 1995.

Tables 2a and 3a include a listing of the "CR" values for each reactor. The "CR" value is defined as the ratio of the annual collective dose delivered at individual doses exceeding 1.5 cSv (rem) to the total annual collective dose. The United Nations

Scientific Committee on the Effects of Atomic Radiation (UNSCEAR) recommends that this parameter remain in the range between 0.05 and 0.50. There were no reactors which exceeded this recommended range in 1995.

Table 2b lists the three-year average doses per PWR in ascending order, as well as the collective dose per reactor for the last three years. Several PWRs have consistently achieved very low collective doses and therefore appear near the top of Table 2b. Some of these low dose plants, such as Seabrook, Commanche Peak 1 and 2, and South Texas 1 and 2, are relatively young plants, while others, such as Prairie Island 1 and 2 and Kewaunee, have been in operation for over two decades. The five PWR sites with the highest doses per reactor in 1995 are indicated with an asterisk to give an indication of their performance over the last three years. Several of these PWRs are consistently among the highest dose plants as evidenced by their high three-year dose averages. Table 4b gives a breakdown of some of the major activities which contributed to the collective dose received at these high dose plants in 1995. It appears that the activities which most frequently contributed to these high collective doses in 1995 were steam generator related work, valve related maintenance and repair work, refueling activities, scaffolding and insulation installation and removal, inservice inspections, health physics coverage, and reactor coolant pump maintenance.

Table 3a lists the 37 BWRs in ascending order of collective dose per reactor for 1995. The average BWR dose per reactor in 1995 was 256 person-cSv (person-rem). Six BWR units--Fermi 2, Monticello, Big Rock Point, Perry, River Bend 1, and Oyster Creek--reported collective doses in 1995 which were less than 100 person-cSv (person-rem) per reactor. The annual collective dose for one of these reactors, Oyster Creek, has historically been one of the highest in the country. In 1995, the five BWR sites (seven individual reactors) with the highest collective doses all exceeded 379 person-cSv (person-rem) <u>per reactor</u>. These reactors were Millstone Point 1, Pilgrim, Washington Nuclear 2, Dresden 2 and 3, Nine Mile Point 1 and 2. [Note: The average dose per reactor at these five sites in 1995 was 456 person-cSv (person-rem) compared to an average of 675 person-cSv (person-rem) per reactor at these five sites in 1995 was 456 person-cSv (person-rem) compared to an average of 675 person-cSv (person-rem) per reactor at these five sites in 1995 was 456 person-cSv (person-rem) compared to an average of 675 person-cSv (person-rem) per reactor at the five highest dose reactor sites in 1994]. Although the seven reactors at these five sites represented only 19% of the 37 BWRs, they contributed a third of the total collective dose incurred at BWRs in 1995. Some of the activities which contributed to the collective dose accumulated at the BWR site with the highest collective dose per

reactor [Millstone Point 1 with a total of 620 person-cSv (person-rem)] were weld repair, in-service inspection, hangar work, insulation removal and replacement, staging work, and refueling activities.

Table 3a and Figure 3 also give the collective dose per gross MWe-year for BWRs to indicate their power generation performance as it relates to the collective dose incurred by the workers at these plants. In 1995, the collective dose per MWe-year of 0.38 for BWRs was below 0.50 for the first time. As in previous years, the collective dose per MWe-year remains higher for BWRs than for PWRs. One contributing factor for this difference is the larger power generation capacity of most PWRs.

Table 3b lists the three-year average doses per BWR in ascending order, as well as the collective dose per reactor for the last three years. The BWRs with the lowest and the third lowest three-year average doses, Fermi 2 and Limerick 1 and 2, are relatively young plants, while Big Rock Point, Vermont Yankee, and the next several BWRs near the top of Table 3b have been in operation for much longer periods of time. The five BWR sites with the highest doses per reactor in 1995 are indicated with an asterisk to give an indication of their performance over the last three years. As was the case for PWRs, several of the BWRs with the highest collective doses in 1995 are also among the plants with the highest three-year dose averages. Table 4a gives a breakdown of some of the major activities which contributed to the collective dose received at these high collective doses were in-service inspections, valve maintenance work, refueling activities, shielding installation and removal, and area and system decontamination.

As can be seen from Figure 1, the LWR average collective dose has continued on a general downward trend from the peak doses seen in the early 1980s and the 1995 LWR average dose (which has not changed from last year's value) is the lowest yearly average dose recorded since 1969. The average measurable dose per worker of 0.25 person-cSv (person-rem) is also the lowest yearly average yet recorded for this number. Along with the completion of a majority of the TMI-mandated fixes (a contributor to higher doses after the 1979 accident), one of the major reasons for this decreasing dose trend at LWRs is the increased emphasis being placed by the utilities,

industry, the NRC (through the BNL ALARA Center), and INPO on the importance of effectively applying ALARA principles at LWRs. All of the plants contacted in gathering data for this report had dedicated ALARA coordinators on their staff for the purpose of ensuring that ALARA principles and practices are factored into all maintenance and operations work to reduce overall personnel exposures. All plants contacted maintained detailed records of job-specific doses incurred during both outage and non-outage periods. Many of these plants also recorded good practices and identified areas for improvement associated with high dose tasks. Such a detailed job and dose tracking system is a vital part of a good ALARA program because it provides a good lessons learned data base for future recorde and use. Most plants contacted made use of this type of historical data to set aggressive dose goals.

Tables 4a and 4b list the major activities contributing to the doses for the five BWR and five PWR sites, respectively, which had the highest collective doses in 1995. These tables also list the outage dose and duration for each of these LWRs in 1995. As can be seen from these data, on the average, over 85% of the annual collective dose for these plants is accrued during outages. This supports the findings from an earlier study (Memo from C. Hinson (NRC), "Representative Daily Collective Doses at PWRs and BWRs During Both Outage and Non-Outage Conditions", March 1, 1990) which showed that the average daily outage doses exceeded the average daily non-outage doses by a factor of 31 for PWRs and by a factor of 9 for BWRs. In addition, the ten LWR sites (thirteen units) which had the highest collective doses in 1995 spent an average of 113 days down per unit for outage work in 1995 (compared with 100 outage days per unit in 1994).

One way to reduce a plant's annual collective dose is to reduce the frequency and duration of plant outages by detailed outage planning and scheduling of jobs to minimize critical path time. There are several ways in which outage doses can be reduced. The use of permanent scaffolding to access high dose rate areas where frequent maintenance/inspection is performed would eliminate both the down time necessary to erect and take down this scaffolding each outage and also the corresponding personnel doses associated with scaffolding erection and tear-down. Wider use of permanent scaffolding or platforms in high dose rate areas (such as around steam generators, recirculation piping, and reactor coolant pumps) can also contribute to the lowering of plant collective doses. In plant areas where the

installation of permanent scaffolding is not practical, the use of transportable scissortype lifts, such as "lift-a-lofts", in place of standard scaffolding may result in savings of both outage time and personnel dose. If standard scaffolding is used, then time and dose can be reduced by storing these scaffolding materials in designated areas near where the scaffolding is normally used (scaffolding normally used in containment should be stored inside of containment, if possible, between outages).

Another means of reducing outage doses is to improve the use of shielding. Use of permanent shielding versus temporary shielding in high dose rate areas would reduce the doses associated with the installation and removal of temporary shielding during outages. In instances where it is not feasible to install permanent shielding, the installation of temporary shielding could be facilitated by installing permanent hooks/hangers in areas where this temporary shielding is required. Use of such hooks/hangers would reduce the time needed to install this shielding in radiation areas. Some areas where hooks/hangers for temporary shielding have been installed are in the vicinity of the recirculation system piping and around some unshielded turbine components at BWRs. Prior to installing any temporary or permanent shielding, one should evaluate the effects of shielding weight on plant structures and components. Inflatable shields which can be filled with water or lead shot have been used at many facilities. The advantages of using this type of shielding are that it is portable and a large uninflated shield can be easily carried by an individual to the installation area and filled in-situ. Other facilities have reported success using prefabricated plate lead or lead-impregnated molded plastic. This type of shielding can be specifically molded for the component to be shielded. Because this shielding is custom-made for a specific component, it provides much more effective shielding than bulk shielding. Several facilities have realized considerable dose savings by using reactor head shields (during refuelings) and steam generator manway shields (for steam generator tube work). By practicing installation on mockups prior to shielding the actual component, shield installation time in the field can be reduced.

The removal and reinstallation of component insulation to permit in-service inspection and testing can also be a fairly dose-intensive job. Providing temporary storage areas for this insulation can reduce the amount of insulation which is misplaced or damaged due to improper storage. Storage of this insulation near the work area will minimize transit time for transporting this insulation and reduce worker doses. Proper labeling

of insulation will facilitate retrieval and reinstallation of the insulation. Component/system flushing or decontamination prior to maintenance of the component or system can greatly reduce area dose rates and result in lower personnel doses. Several facilities are considering decontamination of the entire reactor coolant system. Indian Point 2 performed the first full-scale chemical decontamination of the entire reactor coolant system in 1995 in an attempt to reduce the high containment source term. This high source term has been one of the reasons why the annual doses at Indian Point 2 have been amoung the highest in the country over the past several years. This full system decontamination resulted in an average contact decontamination factor of 7.8 and an estimated dose savings of over 600 person-cSv (person-rem). Robotics, which are playing a larger role every year in facilitating work functions at nuclear power plants, have led to a reduction in the overall doses received by plant personnel. Use of robots to perform such tasks as steam generator tube plugging, sleeving, and eddy current testing in PWRs has led to a tenfold reduction in personnel doses accrued during the performance of these tasks. Robotics have also been used to reduce doses during in-service inspection work, control rod drive changeout, and pipe welding. Mobile robots have been used by many utilities to perform remote surveillance and sampling functions in hostile or high dose environments.

Many facilities have installed remote video cameras with tilt and pan capabilities in various parts of the plant. These cameras are used to observe jobs being performed in high radiation areas. They have also been used for remote area surveillance, thereby minimizing the need for walkdowns in certain parts of the plant. Several plants contacted use powerful zoom cameras attached to telescoping poles for inservice inspections and valve inspections. In many cases, the use of these cameras has precluded the need for the erection of scaffolding. Many plants which have recently replaced their steam generators have used a series of remote closed-circuit video cameras during the replacement project to monitor various job evolutions from low dose areas. The job evolutions recorded on these video cameras will be used as training films for other utilities planning to replace their steam generators. Like the use of remote video cameras, teledosimetry is being used at more and more utilities. The use of teledosimetry permits health physics personnel located in low dose rate areas to accurately monitor the doses of people working in higher dose rate areas, thereby reducing the overall collective dose to perform the job.

Some other methods of reducing doses during outages are; 1) scheduling jobs to be performed on the same component or in the same area so that they are performed at the same time to eliminate duplication of setup preparations, 2) optimizing work sequences, 3) using skilled workers to perform difficult jobs, 4) providing extensive mockup training using accurate mockups for dose intensive or difficult jobs, 5) minimizing the number of work crew personnel used so that only the number of personnel necessary to perform the job are used, and 6) ensuring cooperation between different groups which may be working together on the same job. Many of the utilities contacted tracked job doses for repetitive jobs performed from one outage to the next. One plant, Oyster Creek, uses a system whereby an exposure tracking number is assigned to each maintenance job performed. Using this number, one can identify the building, elevation, room number, system, and component on which the maintenance was performed. By keeping detailed records of past jobs performed, and by identifying areas for improvement following the completion of each job, licensees will be able to lower job doses by implementing lessons learned from previous jobs.

The preceding paragraphs describe several dose reduction features which can be implemented to reduce doses to plant personnel during plant outages. One way in which overall plant dose rates can be significantly reduced is to reduce the sources of radiation in the plants. The primary source of radiation fields in nuclear power plants is cobalt-60, which is formed as a result of neutron absorption by cobalt-59. Cobait-59 is the major constituent of Stellite, a hardfacing material used in valve seats, pump journals, and other wear resistant components. Therefore, an effective way to reduce the overall source of radioactivity at nuclear power plants is to reduce the amount of cobalt containing material in contact with the primary coolant system. For plants still in the design stage, this can be accomplished by specifying the use of non- or low Stellite plant components. For operating plants, however, components contributing large amounts of cobalt to the reactor coolant system need to be identified and replaced with components with little or no cobalt content. Several plants contacted have included cobalt content information in the work management system component data so that engineers can identify cobalt reduction opportunities. For some components, non-cobalt replacement materials need to be developed which possess the same wear characteristics as the component to be replaced. Many utilities have already embarked on programs to reduce the sources of cobalt in their plants. These programs include plans for replacing selected valves and piping, control

blades at BWRs, turbine blades, and fuel assembly hardware at PWRs. In an attempt to expedite overall source term reduction, several BWRs have accelerated their programs to replace their existing control blades (which contain cobalt-based pins and rollers) with control blades which contain little or no cobalt. PWRs which have replaced their steam generators in recent years have specified that the tubing in the replacement steam generators be fabricated of low cobalt Inconel 690. As more plants implement such source reduction programs, overall dose rates at LWRs should continue to decline.

In addition to the implementation of ALARA design features, an essential element of a good ALARA program is to have a strong management commitment to maintain plant personnel doses ALARA. Without the support of the corporate office and upper management, it is difficult to operate an effective ALARA program. Performing job planning (including ALARA reviews) well in advance and establishing realistic dose goals are other means of reducing personnel doses. Since most of the collective dose at plants is accrued during outage periods, establishing a detailed fixed outage work scope several months before the outage provides the health physics department with a knowledge of exactly what jobs will be performed during the upcoming outage and allows them adequate time to perform the necessary ALARA job reviews and schedule health physics support and coverage for outage jobs, where needed. As the current generation of LWRs age, plants will be faced with increase J maintenance needs. A good ALARA program is necessary to prevent LWR doses from increasing as the maintenance requirements at these plants gradually increase over the years.

Figure 1 Average Collective Dose and Number of Workers per Reactor 1973 – 1995





Year

Figure 2 Number of Operating Reactors and Gross Electricity Generated 1973 - 1995





Figure 3 Average Measurable Dose per Worker and Collective Dose per Megawatt-Year 1973 – 1995



Average Measurable Dose per Worker



Year

				TA	BLE 1a			
ANNUAL	WHOLE	BODY	DOSES	AT	LICENSED	NUCLEAR	POWER FACILITIES	
				C	Y 1995			

PLANT NAME					Individual	IS WITH VAL	hole 3od	y Doses	in the R	enges (i	cSv or n	ems)				TOTAL	NUMBER	TOTAL
	TYPE	No Mees. Exposure	Mess <0.10	0.10- 0.25	0.25- 0.50	0.50-0.75	0.75-1.00	1.00-2.00	2 00- 3 00	3.00-	4.00-5.00	5 00-	6 00- 7 00	7 00-	>12.0	NUMBER MON- TORED	WITH MEAS. DOSE	DOSE (person- cSv. rem)
ARKANSAS 1,2	PWR	1.437	1 244	532	301	107	20											
BEAVER VALLEY 12	PWR	1,221	49.4	305	350	107	38	36		÷						3,698	2 259	356
BIG ROCK POINT	BWR	124	113	36	330	103	64	69	. 1		-					2 757	1538	453
BRAIDWOOD 1,2	PWR	1 224	10.4	324	236		6	18	-						*	329	205	5.4
BROWNS FERRY 1,2,3	BWR	2 400	1 285	877	230	04	15	12	-	*	· · ·	*			-	2 358	1 134	236
BRUNSWICK 1,2	BWR	1 534	1 237	484	430	175	23	2	-	-		× .				4.940	2 540	400
BYRON 1,2	PWR	1 349	306	301	9/3	207	151	108	-	*			*	÷ .		4 191	2857	883
CALLAWAY 1	PWR	954	574	201	203	133	50	34	-				÷	÷		2.458	1 107	3/08
CALVERT CLIPPS 1.2	PWR	1 807	585	208	109	50	19	11		*		*				2 020	1.082	107
CATAWBA 1.2	PWR	1 720	75.3	400	200	19	40	7		-			+			2 810	1 203	735
CUNTON	BWR	928	368	483	387	129	73	57			-	+				3.812	1 892	230
COMANCHE PEAK 1,2	PWR	5.88	386	307	322	138	29	18	-	*						2 110	1 182	318
COOK 1,2	PWR	1 159	870	2.30	131	70	22	5	-							1.537	951	170
COOPER STATION	BWR	1 121	49.4	3/3	7/4	58	16	8		-			÷			2.459	1 310	202
CRYSTAL RIVER 3	PWR	851	105	14	219	8/	24	11			-		-	*		2,218	1 095	203
DAVIS-BESSE	PWR	790	240	14		*		-	-			* 1	-	-	-	1.080	209	
DIABLO CANYON 1,2	PWR	1 730	827	337			-	-		*			* *	*		1.046	258	7
DRESDEN 2,3	BWR	2 108	027	321	222	65	32	42	-	-	*					3 354	1 815	200
DUANE ARNOLD	BUAR	787	408	244	455	281	175	215								4 588	2 482	200
FARLEY 1.2	PAR	760	570	291	211	118	88	57	*							1 916	1 120	357
FERM 2	BWR	1 440	304	3/8	342	123	87	75	3				-			2 350	1 581	485
PITZPATRICK	BWR	1 188	578	270	10		*	-	+	-	- 14					1.830	390	28
FORT CALHOUN	PWR	595	358	101	210	114	77	41	-	-	-	*	*		*	2.437	1248	337
GINNA	PWR	873	374	101	124	02	17	5		-		×	*	-		1,222	827	130
GRAND GULF	BWR	1 138	756	183	108	35	15	12	*	*						1.811	738	138
HADDAM NECK	PWR	785	286	3.39	253	115	58	38	-	*						2,727	1 589	343
HARRIS	PWR	812	200	10.3	190	130	91	124	2				*			1,791	1 008	447
HATCH 1.2	80.7	970	510	223	140	45	15	21		ia.		14				1,980	1 088	174
HOPE CREEK S	BWR	810	000	314	285	150	78	107	5		-					2 428	1 458	488
NDIAN POINT 2	PWR	850	800	304	201	82	19	18	1		*	-				2 290	1 571	108
NDIAN POINT 3	PWR	907	2001	305	327	188	115	80	6		÷			*		2 540	1 690	548
KEWAUNEE	PWR	284	300	100	54	6	2		-		×			~		1 545	636	346
ASALLE 12	RWAR	106	140	101	102	34	18	12	-	+	-	*		4	4.11	879	415	67
UMERICK 1,2	RUND	1000	506	3/8	343	247	92	57	-	+		÷			2	2.818	1833	109
WAINE YANKEE	DWR	0000	099	344	221	58	32	19	1	-		*		÷		3 889	1 581	312
ACGURE 1.2	PAN	2 283	217	228	249	160	96	192	24	3	14-	4				1 828	1 187	200
ALLSTONE POINT 1	-	2,203	183	330	103	24	3	~	-	*				-	-	3 542	1 250	138
ALLSTONE POINT 2.3	DIAVE	1 105	320	1/5	164	79	53	96	14	8			-			1 505	810	130
ONTICELLO	BWR	503	009	320	305	148	99	178	25	1	*	*	-			2 798	1 801	020
INE MILE POINT 12	BAND	1 330	00	65	51	14	-	2		÷.	-					792	200	410
	Participant and a second secon	1,438	184	346	442	246	112	153	11	-	-						200	44

TABLE 1# (Continued) ANNUAL WHOLE BODY DOSES AT LICENSED NUCLEAR POWER FACILITIES CY 1995

PLANT NAME				Number	of Individu	ale with	Whole B	lody Dose	s in the R	enges (CSV or re	(arma				TOTAL	NI BARPO	TOTAL
	TYPE	Exposure <0.	Mans <0.10	0 10	0-029 5 0	5 01	0- 0.7 75 1.1	5- 1.00 00 2.0	200-	3 00- 4 00	4 00- 5 00	5.00-	8 00- 7 00	7 00-	>12.0	NUMBER MONI- TORED	WITH MEAS DOSE	DOSE (person- cSv, rem)
NORTH ANNA 1.2	PWR	1 373		103									_					
OCONEE 1,2,3	PWR	1 751	708	403	291	11	3 5	8 37	1	÷			-		12	2 024		1. A.
OYSTER CREEK	BWR	638	100	411	288	74	6 1	9 18	- 4						12	2,829	1,551	367
PALISADES	PMR	48.4	472	1/8	55	15	5	5 3				-				3,337	1,588	304
PALO VERDE 123	PWR	1 735	403	214	206	140	102	2 98	7						-	1,299	781	80
PEACH BOTTOM 2 3	BUAR	1,123	824	398	332	181	8	3 77						- 0 -		1,894	1,230	482
PERRY	BOARD .	1,747	983	437	290	120) 87	48				1.2				3,598	1,875	482
PILORM	BAN	1,159	338	194	51		- ×		1			-				3,687	1,940	398
POINT BEACH 1 2	CSB/ID	853	325	284	277	724	124	60		÷4.			- 2			1,748	587	64
PRAIRIE ISLAND 12	Charm .	43/	171	120	101	78	39	39					- 2	- T		2,147	1,294	482
QUAD CITIES 1 2	(Port R	561	220	119	104	43	12	1								965	548	190
RIVER BENO 1	BIOLE	1,213	629	438	392	273	145	184					-	-		1,060	499	107
ROMNSON 2	DAAM	1,522	414	148	83	14	7	3		6	÷		-			3,254	2,041	738
SAL PM 12	Pere	882	482	258	200	75	19	16							- C	2,189	087	85
SAN CHOREE 3 -	P-BRM	622	689	277	153	47	15	14					-		-	1,920	1,058	215
SEASE CHOFILE 2,3	PARK	3,304	783	448	379	220	82	22	1				-		*	1,817	1,195	218
CECH COVALLA 2	PANK	1,293	445	243	99	13			- C -			-				5,218	1,014	455
DEGUDTAN 12	PWR	1,684	727	408	272	133	68	33	1.1			-		*		2,093	800	102
SCOTH TEXAS 1,2	PWWR	1,711	708	372	249	94	41	10			*					3,302	1,618	358
ST. LOCKE 1,2	PWR	1,083	583	368	374	114	85	50	· .						*	3,196	1.485	291
S-UNAWAE PC 1	PWR	801	217	37	3		05	28		*	*				-	2,581	1.498	413
SURRY 1,2	PWR	1,009	957	358	343		5.0	-	· · .	-			+	2 4	18 a	1,058	257	13
SUSQUEHANNA 1,2	BWR	1,589	636	431	336	183	30	40	8	-		-				2,892	1 883	400
THREE NELE ISLAND 1	PWR	785	663	273	174	57	22	01		*	*	-			A	3,342	1.773	478
TURKEY POINT 3,4	PWR	1,197	505	328	218	87	47			*			*	14.11 C	A 1.1	2.005	1 220	212
VERMONT YANKEE	BWR	1,254	235	245	101	79	10	1	*						-	2.339	1 142	213
OGTLE 1,2	PWR	853	408	22.4	180	-	18	8				×	*		*	1.991	737	183
NASHINGTON NUCLEAR 2	BWR	1,218	772	290	280	100	15	14		*	*		14			1.808	053	102
WATERFORD 3	PWR	1.083	629	282	137	191	104	57	-	*	*	*	× .	÷.		2 810	1.604	199
NOLF CREEK 1	PWR	957	208	202	137	28	8	7	* -		÷				1	2 180	1,000	450
20N 1,2	PWR	1 408	508	20	8	1	-	-	×	*		*				1 100	1,082	153
		1,400	500	302	386	225	181	221	4	•	-	*	*		÷. 1	3,303	1,807	14
OTALS: 37 BWRs		31 335	15 284	7 044														
OTALS: 72 PWRs		49 807	23 311	17 360	0,332	3,117	1,587	1,380	32	1	-	-	* .			88 984	35 850	in the later
OTALS: 108 LWR.		81 032	18 575	12,238	8,947	3,787	1,789	1,717	83	4	-	÷ 1				101 584	35,659	9,487
			20,013	20,243	13,2/8	0,884	3,338	3.077	125	4						101,004	51,887	12,297

TABLE 16 ANNUAL WHOLE BODY DOSES AT LICENSED NUCLEAR POWER FACILITIES FACILITIES NOT IN OPERATION OR IN OPERATION LESS THAN ONE YEAR CY 1995

			N	umber of	Individua	is with VA	Vhole Boo	fy Doses	in the R	anges (d	Sv or re	(eme				-		TOTAL
	TYPE	No Mses. Exposure	Meas. <0.10	0 10- 0 25	0 25- 0 5	0 50- 0 75	0 75- 1 00	1 00-2 00	2 00- 3 00	3 00- 4 00	4 00- 5 00	5.00- 6.00	8.00- 7.00	7.00-	>12.0	NUMBER MONI- TORED	NUMBER WITH MEAS DOSE	COLLECTIVE DOSE (person- cSv, rem)
BELLEPONTE	PWR							and the second data in the second										
DRESDEN 1 *	BWAR	Reported with I	Dennders 2.2														1.00	
PORT ST. VRAIN *	HTOR	400	010000m 2,3															
LANDOL DT BAY *	814/9	400	82	52	40	29	15	43	34	3	÷ .					79.0		
NOIAN DOWNT 1 *	CRAIR	156	39	3	*	÷	÷	-			-					/38	278	210
ACBORDE -	1- SALE	reported with i	ndian Point 2										-			196	42	2
	BWR	80	17	12	2													
ouverno seco-	PWR	177	15	1	-											111	31	3
SAN ONOPRE 1-	PWR	Reported with 5	ten Onofre 2	3						-		~		*		193	16	1
MREE MLE ISLAND 2"	PWR	124	109	43	27													
ROJAN *	PWR	220	48	27	32	10					*					315	191	2
NATTS BAR 1,2	PWR							0		~						361	141	44
ANKEE-ROWE .	PWR																	
																	×.	
OTAL REPORTING 8		1,217	290	138	101	57	27	49	34	3						1,916	898	282

* Indicates plants that are no longer in commercial operation.

TABLE 2a PRESSURIZED WATER REACTORS LISTED IN ASCENDING ORDER OF COLLECTIVE DOSE PER REACTOR 1995

Site Name	Collective Dose per Reactor (rems or cSv)	Collective Dose per Site (rems or cSv)	Average Dose per Worker (rems or cSv)	Collective Dose per MW-Yr (rems or cSv)	CR
DAVIS-BESSE	7	7	0.03	0.0	0.00
CRYSTAL RIVER 3	8	8	0.04	0.0	0.00
SUMMER 1	13	13	0.05	0.0	0.00
WOLF CREEK 1	14	14	0.06	0.0	0.00
PRAIRIE ISLAND 1,2	54	107	0.21	0.1	0.00
INDIAN POINT 3	67	. 67	0.11	0.4	0.00
COMANCHE DEAK 10	69	138	0.11	01	0.00
POINT REACH 1,2	90	179	0.19	01	0.00
VOCTLE 12	95	190	0.35	0.2	0.00
OCONEE 122	100	199	0.21	0.1	0.00
COOK 1 2	101	304	0.19	0.1	0.00
SEARBOOK	102	203	0.15	0.1	0.00
TURKEY DOINT 2 4	102	102	0.13	0.1	0.00
KEWALINEE	108	215	0.19	0.2	0.00
SALEM 1 2	109	109	0.26	0.2	0.00
CALVERT CLIEFS 1 2	109	218	0.18	0.4	0.02
BRAIDWOOD 1 2	118	235	0.20	0.2	0.00
GINNA	118	236	0.21	0.1	0.01
FORT CALHOUN	136	136	0.18	0.3	0.06
DIABLO CANYON 1 2	139	139	0.22	0.3	0.00
SOUTH TEXAS 12	143	286	0.18	0.1	0.06
BYRON 12	140	291	0.20	0.1	0.00
WATERFORD 3	153	306	0.28	0.2	0.06
PALO VERDE 123	161	153	0.14	0.2	0.00
HARRIS	174	402	0.26	0.1	0.05
SEQUOYAH 1.2	179	1/4	0.16	0.2	0.01
NORTH ANNA 1.2	184	350	0.22	0.2	0.02
CALLAWAY 1	187	187	0.24	0.2	0.05
ARKANSAS 1,2	193	386	0.10	0.2	0.00
SURRY 1,2	203	406	0.22	0.3	0.03
ST. LUCIE 1,2	207	413	0.22	0.3	0.10
MILLSTONE POINT 2,3	208	416	0.25	0.3	0.07
THREE MILE ISLAND 1	213	213	0.17	0.3	0.51
ROBINSON 2	215	215	0.20	0.3	0.00
BEAVER VALLEY 1,2	227	453	0.29	0.3	0.00
SAN ONOFRE 2,3	228	455	0.24	03	0.02
ATAWBA 1,2	231	462	0.24	0.2	0.00
ARLEY 1,2	232	463	0.29	04	0.08
LION 1,2	399	797	0.44	0.5	0.15
ADDAM NECK	442	442	0.44	1.0	0.14
ALISADES	462	462	0.38	0.8	0.10
NDIAN POINT 2	548	548	0.32	0.9	0.07
MINE TANKEE	653	653	0.56	27.7	0.26
lumber of Reactors: 72	170	12,207	0.24	0.2	

2

TABLE 2b PRESSURIZED WATER REACTORS LISTED IN ASCENDING ORDER OF THREE YEAR AVERAGE COLLECTIVE DOSE PER REACTOR 1993 - 1995

	Collecti	ive Dose Per	Three Year		
Site Name	1993	1994	on-cSv) 1995	Average Collective Dose Per Reactor	
PRAIRIE ISLAND 1 2	50				
INDIAN POINT 3	53	55	54	54	
SEABROOK	60	58	67	62	
COMANCHE PEAK 1 2	1.30	113	102	74	
POINT BEACH 1.2	02	45	90	76	
KEWAUNEE	100	85	95	91	
SOUTH TEXAS 1.2	126	12	109	96	
CRYSTAL RIVER 3	60	229	146	98	
FORT CALHOUN	157	220	8	99	
OCONEE 1,2,3	79	170	139	106	
WATERFORD 3	15	101	101	120	
COOK 1,2	22	240	103	120	
VOGTLE 1,2	184	109	102	121	
BRAIDWOOD 1,2	137	149	118	131	
SALEM 1,2	204	94	109	135	
ARKANSAS 1,2	134	86	193	136	
CALLAWAY 1	225	14	187	130	
MARRIS	31	222	174	142	
WOLF CREEK 1	183	235	14	142	
THREE MILE ISLAND 1	206	40	213	152	
GINNA	193	138	136	155	
DAVIS PEODE	138	238	108	161	
MCGUIDE 1 2	348	144	7	166	
RVRON 12	232	199	69	166	
SEOLIOVALIA 2	216	140	153	170	
PALO VERDE 1 2 2	186	146	179	170	
FARLEY 1 2	197	154	161	171	
CATAWRA 1 2	167	125	232	174	
CALVERT CLIEFS 1 2	198	104	231	178	
BEAVER VALLEY 1.2	203	227	118	182	
DIABLO CANYON 12	141	22	227	186	
MILLSTONE POINT 23	270	295	143	193	
SURRY 1.2	192	190	208	194	
ROBINSON 2	337	63	203	195	
AN ONOFRE 2.3	384	16	215	205	
SUMMER 1	297	374	228	209	
ST. LUCIE 1.2	246	253	13	228	
ORTH ANNA 1.2	454	97	184	235	
ALISADES	289	60	462	245	
ION 1,2	322	153	390-	201	
ADDAM NECK	408	135	442*	235	
AINE YANKEE	377	84	653*	371	
NDIAN POINT 2	675	48	548*	424	
nnual PWRAverages:	199	133	170		
otal Reactors Included:	71	72	72		

* Indicates high dose-per-reactor sites for 1995

TABLE 3a BOILING WATER REACTORS LISTED IN ASCENDING ORDER OF COLLECTIVE DOSE PER REACTOR 1995

Site Name	Collective Dose per Reactor (rems or cSv)	Collective Dose per Site (rems or cSv)	Average Dose per Worker (rems or cSv)	Collective Dose per MW-Yr (rems or cSv)	CR	
FERMI 2	28	20	0.45	W Sardin Davy 43 Mart is the for all participants of the second state		-
MONTICELLO	20	20	0.07	0.0	0.00	
BIG ROCK POINT	54	44	0.22	0.1	0.00	
PERRY	64	54	0.26	0.9	0.18	
RIVER BEND 1	85	04	0.11	0.1	0.00	
OYSTER CREEK	90	00	0.13	0.1	0.00	
LIMERICK 1,2	130	260	0.12	0.1	0.00	
BROWNS FERRY 1,2,3	136	409	0.16	0.1	0.02	
VERMONT YANKEE	182	182	0.10	0.4	0.00	
HOPE CREEK 1	196	196	0.25	0.4	0.00	
PEACH BOTTOM 2,3	199	398	0.12	0.2	0.07	
COOPER STATION	228	228	0.21	0.2	0.03	
SUSQUEHANNA 1,2	238	476	0.27	0.5	0.02	
HATCH 1,2	244	488	0.33	0.3	0.05	
LASALLE 1,2	256	512	0.32	0.3	0.10	
CLINTON	316	316	0.27	0.3	0.02	
FIIZPATRICK	327	327	0.26	0.6	0.01	
BRUNSWICK 1,2	342	683	0.26	0.5	0.03	
GRAND GULF	342	342	0.22	0.4	0.00	
DUANE ARNOLD	357	357	0.32	0.8	0.01	
QUAD CITIES 1,2	368	736	0.36	07	0.01	
DRESDEN 00	380	759	0.33	0.5	0.12	
AASHINGTON MUCH SAD	438	875	0.35	1.4	0.07	
COM NUCLEAR 2	456	456	0.27	0.6	0.03	
	482	482	0.37	0.9	0.00	
VILLOTONE POINT 1	620	620	0.68	1.2	0.16	
Number of Reactors: 37	256	9,467	0.27	0.4	and the second second second second second	

TABLE 3b BOILING WATER REACTORS LISTED IN ASCENDING ORDER OF THREE YEAR AVERAGE COLLECTIVE DOSE PER REACTOR 1993 - 1995

Collecti	ve Dose Per	Three Year		
1993	1994	1995	Average Collective Dose Per Reactor	
35	212	20		-
152	110	28	92	
109	120	54	108	
217	130	130	125	
68	30	162	146	
168	320	196	207	
301	70	238	209	
200	295	228	233	
332	200	136	237	
276	200	342	243	
217	290	199	255	
180	15	380*	257	
498	519	85	261	
232	200	316	292	
407	322	327	294	
407	120	357	295	
325	390	44	311	
278	432	244	337	
427	691	64	344	
421	303	256	349	
425	391	620*	364	
435	200	482*	372	
430	500	342	426	
410	844	90	450	
420	564	368	452	
020	41/	438*	561	
409	866	456*	597	
330	307	250		
37	37	37		
	Collecti (Perso 1993 35 152 109 217 98 168 391 290 332 276 317 180 498 232 407 494 335 278 427 81 435 436 416 425 828 469 330 37	Collective Dose Per (Person-rem or Personants) 1993 1994 35 213 152 119 109 138 217 38 98 326 168 221 391 79 290 285 332 56 276 290 317 75 180 519 498 63 232 322 407 120 494 395 335 432 278 691 427 363 81 391 435 200 436 500 416 844 425 564 828 417 469 866 330 327 37 37	Collective Dose Per Reactor (Person-rem or Person-cSv)199319941995 35 21328152119541091381302173818298326196168221238391792282902851363325634227629019931775380°1805198549863316232322327407120357494395443354322442786916442736325681391620°435200482°43650034241684490425564368828417438°469866456°330327256373737	Collective Dose Per Reactor (Person-rem or Person-cSy) Three Year Average Collective Dose Per Reactor 35 213 28 92 152 119 54 108 109 138 130 125 217 38 182 146 98 326 196 207 168 221 238 209 391 79 228 233 290 285 136 237 332 56 342 243 276 290 199 255 317 75 380* 257 180 519 85 261 498 63 316 292 232 322 327 294 407 120 357 295 494 395 44 311 335 432 244 337 278 691 64 344 427 363 </td

* Indicates high dose-per-reactor sites for 1995

TABLE 4a ACTIVITIES CONTRIBUTING TO HIGH COLLECTIVE DOSES AT SELECTED PLANTS IN 1995

BWR's with High Collective Doses

Millstone Point 1 (620 rem)

Outage dose/duration: 500 rem/59 days Average daily outage dose: 8.47 rem/day Average daily operating dose: N/A

.W d repair (dryweli) (152.5 rem) (in-service inspection) (drywell) (76.5 rem) -Hanger work (dryweli) (28.6 rem) -insulation removal/replacement (drywell) (26.4 rem) -Staging (drywell) (24.9 rem) -Refueling (18.9 rem) -Cleanup valve replacement (drywell) (13.7 rem) Shielding (drywell) (10.9 rem)

Dresden 2, 3 (876 rem)

Outage dose/duration (U2): 686 rem/210 days Outage dose/duration (U3): 23 rem/127 days Average daily outage dose(U2): 3.26 rem/day Average daily outage dose(U3): 0.18 rem/day Average daily operating dose (U2+3): 0.62 rem/day

Unit 2

-RWCU (reactor water cleanup system) pipe and heat exchanger replacement (91.1 rem) -Valve work/replacement (Total of 87.6 rem)

Two 16" MOVs (motor-operated valves) replaced - 52.2 rem

MSIV (main steam isolation valve) repair - 18.2 rem Electromagnetic and safety relief valve repair - 17.2 rem

-ISI (in-service inspection) in drywell (70.4 rem) Shielding (Total of 47.1 rem)

Perm. recirculation ring header shielding installation - 31.2 rem

Temporary drywell shielding installation/removal - 16.9 rem

Outage activities support (Total of 46.7 rem) HP support - 29,2 rem

Operations support - 17.4 rem

Chemical decontamination (recirc and RWCU) (23.7 rem) -installed instrument caps on LPCI (low pressure coolant

injection) recirc. risers for injecting decon solution (13.7 rem)

Inspect/clean main condenser water boxes (11.8 rem) Insulation removal/replacement in drywell (10.5 rem) CRD (control rod drive) removal/installation (10.3 rem) Unclog drain line at bottom of reactor vessel (9.4 rem)

Pilgrim (482 rem)

Outage dose/duration: 410 rem/73 days Average daity outage dose: 5.62 rem/day Average daily operating dose: 0.25 rem/day

-ISI (in-service inspection) (includes doses due to scaffolding and insulation) (74.5 rem) Refueling (Total of 69 rem) Reactor head removal/replacement, cavity decon. - 44.9 rem Modifications (63.9 rem) MOV (motor-operated valve) repair/replacement (49.5 rem) Corrective maintenance (43.5 rem) Health physics support (22.6 rem) Miscellaneous support (19.1 rem) Shielding (16.6 rem)

Operations support (15.5 rem) Preventive maintenance (13 rem) -Decontamination (6.8 rem)

WNP 2 (456 rem)

Outage dose/duration: 297 rem/49 days Average daily outage dose: 6.06 rem/day Average daily operating dose: 0.5 rem/day

Shielding (drywell) installation/removal (30 rem) Reactor disassembly/reassembly (Total of 28.5 rem) Reactor reassembly - 14.3 rem Reactor disassembly - 10.3 rem

Chemical decontamination of RWCU (reactor water cleanup system) (20.6 rem)

481 (in-service inspection) for erosion/corrosion (19.5 rem)

Main steam relief valve removal/replacement (14.8 rem)

TABLE 4a (Continued) ACTIVITIES CONTRIBUTING TO HIGH COLLECTIVE DOSES AT SELECTED PLANTS IN 1995

BWR's with High Collective Doses

Nine Mile Pt 1, 2 (759 rem)

Outage dose/duration (U1): 312 rem/56 days Outage dose/duration (U2): 325 rem/55 days Average daily outage dose (U1): 5.91 rem/day Average daily outage dose (U2): 5.57 rem/day Average daily operating dose : N/A

Unk 1

-ISI (in-service inspection) (94.4 rem) -Valve work/replacement (Total of 62.2 rem) EC (emergency cooling) check valvi repair - 23.6 rem Drywell Limitorque valve work - 19.4 rem Modifications to pressure relief valves - 7.3 rem -CRD (control rod drive) exchanges (16.8 rem) -Health physics surveys and support (16 rem) -Refueling (including reactor head removal/replacement,

ISI, decon, fuel sipping) (12.3 rem) -RP cooler replacement (11.5 rem) -Operations (drywell) (9.6 rem) -Shielding (drywell) (8.9 rem) -Insulation work (8.2 rem) -Housekeeping (drywell) (5.1 rem)

Unit 2

-ISI (Total of 88 rem) Inside bioshield - 43.8 rem Outside bioshield - 34.5 rem Snubber related work (Total of 47.4 rem) Snubber reduction modifications - 26.1 rem Snubber functional testing - 21.3 rem -Valve work/replacement (Total of 38.5 rem) MOV (motor-operating valve) testing - 17.2 rem SRV (safety relief valve) change out - 9.7 rem -Retueling (Total of 17.7 rem) Reactor head removal/replacement - 11.5 rem Operations and support - 6.2 rem -CRD exchanges (12.5 rem) Health physics surveys and job coverage (10.9 rem) -Temporary shielding (7.1 rem) -Neutron monitor replacement/repair (7 rem) -Decontamination (drywell) (6.7 rem)

TABLE 4b ACTIVITIES CONTRIBUTING TO HIGH COLLECTIVE DOSES AT SELECTED PLANTS IN 1995

PWR's with High Collective Doses

Maine Yankee (653 rem)	Indian Point 2 (548 rem)*
Outage dose/duration*: 967 rem/358 days Average daily outage dose: 1.86 rem/day Average daily operating dose: N/A "Outage extended from 1/23/95 to 1/16/96 -Steam generator related work (Total of 272.1 rem) Tube sleeving (17,000 tubes sleeved) - 142.3 rem ECT (eddy current testing) - 83.2 rem Sludge lancing and inspections - 38 rem Manual hard rolling - 7.4 rem -RCP (Reactor Coolant Pump) work (Total of 90.3 rem) Rotating assembly replacement - 46.3 rem Motor removal/installation - 21 rem Seal replacement - 13.5 rem -Outage support (Total of 90 rem) Rad Controls outage support - 69.2 rem -Valve work (Total of 58.6 rem) Valve and SRV (safety relief valve) maintenance - 38.2 rem MOV (motor-operated valve) testing and repair - 21.4 rem -Decontamination (Total of 48.6 rem) Reactor coolant system loop - 32.4 rem -Refueling Operation (Total of 42.3 rem) Reactor head removal/replacement - 29.2 rem CEA (control element assembly) shaft replacement - 8.3 rem -SI (in-service inspection) (22.1 rem) -Pressurizer inconel inspection (14.4 rem) -Temporary shielding (9 rem)	Outage dose/duration: 499.9 rem/122 days Average daily operating dose: 4.1 rem/day Average daily operating dose: 0.20 rem/day Indian Point performed a full system decontamination in 1996 -Modifications (Total of 67.8 rem) Steam generator nozzle ring installation - 16.3 rem Reactor vessel head split pin repair - 14.9 rem -Refueling (65.7 rem) -Maintenance (51.2 rem) -Radiation protection (47.3 rem) -Radiation protection (47.3 rem) -Radiation protection (47.3 rem) -Radiwasts (40.4 rem) -Steam generator work (Total of 36.6 rem) Primary side (eddy current testing) - 32.5 rem Secondary side (sludge lancing) - 4.1 rem -Scaffolding and insulation installation/removal (34 rem) -Supervisory plant tours (33.1 rem) -Isl (in-service inspection) (23.7 rem) -Full system decontamination (21 rem) -RCP (Reactor Ccolant Pump) work (20 rem) -Operations (20.3 rem) -MOV (motor-operated valve) work (16.5 rem) -Services (lighting, air) (10.6 rem)

Palisades (462 rem)

Outage dose/duration: 421 rem/93 days Average daily outage dose: 4.53 rem/day Average daily operating dose: 0.15 rem/day -Refueling (Total of 68.8 rem) Reactor head removal/replacement - 50.8 rem Fuel movement - 6.3 rem -ISI (in-service inspection) (Total of 55.2 rem) Inconel weld inspections (26.1 rem) -Valve work (38.5 rem) -Insulation removal/replacement (34.6 rem) -Steam generator work (Total of 32 rem) Nozzie dam installation/removal - 12.2 rem ECT (eddy current testing) - 8.3 rem -Scaffolding installation/removal (30.6 rem) Health Physics surveys (19.2 rem) Mechanical maintenance (16.4 rem) -Pump work (11.1 rem) -Ventilation system maintenance (10.5 rem) -Decontamination and cleanup (8.5 rem) -Temporary shielding (7.3 rem) -Electrical maintenance (7.1 rem)

TABLE 4b (Continued) ACTIVITIES CONTRIBUTING TO HIGH COLLECTIVE DOSES AT SELECTED PLANTS IN 1995

PWR's with High Collective Doses

Zion 1, 2 (797 rem)

Outage dose/duration (U1): 460 rem/99 days Outage dose/duration (U2): 167 rem/103 days Average daily outage dose (U1): 4.65 rem/day Average daily outage dose (U2): 1.62/day Average daily operating dose: N/A

UNIT 1

-Steam generator work (183.7 rem) -Valve work (74.1 rem) -Scaffolding installation/removal (36.6 rem) -ISI (in-service inspection) (34.4 rem) -Radiation protection support (30.6 rem) -Refueling (Total of 24.3 rem) Reactor head disassembly/assembly - 21 rem Fuel shuffle and inspection - 3.3 rem -Snubber/hanger work (23.5 rem) -Shielding (15.9 rem) -Flange work (15.4 rem) -Reactor coolant pump work (11.2 rem) -Operating department routines (10.2 rem)

Unit 2

-Steam generator work (42.7 rem) -Valve work (24.6 rem) -Scaffolding installation/removal (20.8 rem) -Isi (17.7 rem) -Rediation protection support (15.9 rem) -Refueling (Total of 15.9 rem) Reactor head disassembly/assembly - 12 rem Fuel shuffle and inspection - 3.9 rem -Snubber/hanger work (13.9 rem) -Shielding (5.7 rem) -Reactor coolant pump work (6 rem)

Haddam Neck (442 rem*)

Outage dose/duration: 454 rem/81 days Average daily outage doss: 5.6 rem/day Average daily operating dose: 0.07 rem/day *442 rem total year dose measured by TLD. 454 rem outage dose measured by pocket ion chamber -Steam generator related work (Total of 121.8 rem) Eddy current and ultrasonic testing - 42 rem Tube plugging and rerolls - 31.5 rem Equipment setup/teardown - 14.4 rem Remove/install manways - 11.2 rem install/remove nozzle covers - 6.6 rem HP surveys/job coverage - 5.7 rem -Valve related work (Total of \$8.5 rem) MOV (motor-operated valve) testing and repairs -26.3 rem Misc. valve repair - 22.2 rem Gate valve pressure locking fix - 20 rem Inspection and repair of service water system piping (62.3 rem) -ISI (in-service inspection) (Total of 46.6 rem) UT (ultrasonic tests)/iiquid penetrant exams - 16.5 rem

Insulation removal/replacement - 10.1 rem Scaffolding installation/removal - 6.4 rem -Refueling (40.6 rem) -Operations (21.3 rem) -HP coverage (19.2 rem) -Facilities and waste management (8.8 rem) -Shielding (7.1 rem) -RCP (Reactor Coolant Pump) seal replacement (5.4 rem)