



A Centenor Energy Company

DONALD C. SHELTON
Vice President - Nuclear
(419) 248-2300

Docket No. 50-346

License No. NPF-3

Serial No. 1472

February 17, 1988

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Subject: Supplement to License Amendment Application to Delete the
Technical Specification and Basis Section on Chlorine Detection
Systems (TAC No. 66734).

Gentlemen:

On January 15, 1988 (Serial No. 1457), Toledo Edison submitted a License Amendment Application to Delete Technical Specification and Basis Section 3/4.3.3.7, Chlorine Detection Systems. In addition to those proposed changes, Toledo Edison requests deleting the phrase "Control Room Ventilation Air Intake Chlorine Concentration - High test signal" from Surveillance Requirement 4.7.6.1.e.2, of Technical Specification 3/4.7.6, Control Room Emergency Ventilation System, as shown on the attached Technical Specification pages. This request was inadvertently left out of the License Amendment Application submittal; however, because this is a duplicate requirement, the Safety Evaluation and the Significant Hazards Consideration will not be affected by this additional request. Therefore, Toledo Edison requests this change be included with the Chlorine Detection Systems Technical Specification Amendment and Basis Change.

This letter provides supplemental information to our January 15, 1988 application, therefore no fee per 10CFR170.12(c) is incurred.

Very truly yours,

A handwritten signature in dark ink, appearing to be 'D. Shelton', written over a horizontal line.

CAB:bam

Attachments

cc: DB-1 Resident Inspector
A. B. Davis, Regional Administrator
A. W. DeAgazio, NRC/NRR Davis-Besse Project Manager
State of Ohio

A003
1/1