



Log # TXX-88260
File # 10110
908.3
Ref. # 10CFR50.55(e)

February 25, 1988

William G. Council
Executive Vice President

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
REACTOR COOLANT PUMP (RCP) MOTOR BACKUP CIRCUITRY
SDAR: CP-87-45 (FINAL REPORT)

Gentlemen:

On January 11, 1988, we notified you by our letter, logged TXX-88061, of a deficiency involving RCP motor backup circuitry which we deemed reportable under the provisions of 10CFR50.55(e). This report is submitted to provide the corrective action completion schedule.

Our previously specified corrective action includes the addition of a second set of electrically independent current transformers with relays and interconnecting wiring with the 125 V DC power to the primary and backup protection circuits being supplied from independent sources.

Unit 1 corrective actions will be completed prior to plant heatup (currently scheduled for December 1988). Unit 2 corrective actions will be completed prior to Unit 2 fuel loading.

Very truly yours,

A handwritten signature in cursive script that reads "W. G. Council".

W. G. Council

VIP/grr

c-Mr. R. D. Martin, Region IV
Resident Inspectors, CPSES (3)

8802290333 880225
PDR ADOCK 05000445
S DCD

Five Street L.B. #1 Dallas, Texas 75201

IE27
1/0