



Log # TXX-88239
File # 10110
909.4
Ref. # 10CFR50.55(e)

William G. Council
Executive Vice President

February 24, 1988

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
DOCKET NOS. 50-445 AND 50-446
SAFEGUARDS AREA FAN COOLERS
SDAR: CP-86-22 (FINAL REPORT-UNIT 1)
(INTERIM REPORT-UNIT 2)

Gentlemen:

On July 8, 1987, by our letter logged TXX-6551, we notified you of a deficiency involving the capacity of the present fan cooler design in the safeguards area to adequately handle the heat load in several rooms, which we deemed reportable under the provisions of 10CFR50.55(e). The purpose of this letter is to update the status of the corrective action implementation schedule. Our last report was logged TXX-6865, dated October 21, 1987.

The Unit 1 chilled water rebalancing and Engineering review of appropriate Startup Test Procedure Acceptance criteria are scheduled for completion by June 30, 1988. This is our final report for Unit 1. The records for Unit 1 will be on site for inspectors review after that date.

Our next report for Unit 2 will be submitted no later than July 15, 1988. In that report we intend to discuss, as required, the results of our calculations for Unit 2, the Unit 2 corrective actions required to resolve this condition and the Unit 2 corrective action implementation schedule.

Very truly yours,

W. G. Council

GLB/grr

c-Mr. R. D. Martin, Region IV
Resident Inspectors, CPSES (3)

BB03010087 860224
PDR ADOCK 05000445
S PDR

LE27
1/0