

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT FOR YEAR 1986  
AIRBORNE AND LIQUID EFFLUENTS

UNIT NUMBER: 1 TYPE: BWR LICENSEE: CAROLINA POWER & LIGHT  
 DOCKET NO.: 50-325 LICENSED POWER (MWT): 2436.00  
 COMMERCIAL OPERATION: 03/10/77 INITIAL CRITICALITY: 10/00/76  
 COOLING WATER SOURCE: CAPE FEAR RIVER  
 UNIT NUMBER: 2 TYPE: BWR LICENSEE: CAROLINA POWER & LIGHT  
 DOCKET NO.: 50-324 LICENSED POWER (MWT): 2436.00  
 COMMERCIAL OPERATION: 11/03/75 INITIAL CRITICALITY: 03/20/75  
 COOLING WATER SOURCE: CAPE FEAR RIVER

AIRBORNE EFFLUENTS  
NUCLIDES RELEASED

NUCLIDES RELEASED	ACTIVITY (CI)
H-3	7.07E+00
AR-41	4.46E+01
CR-51	1.87E-02
MN-54	1.91E-03
CO-57	2.10E-07
CO-58	4.66E-04
FE-59	1.50E-04
CO-60	4.74E-03
ZN-65	6.37E-05
KR-85M	1.01E+01
KR-87	5.09E+00
KR-88	1.28E+01
SR-89	1.71E-03
SR-90	8.67E-06
NB-95	1.90E-06
AG-110M	4.19E-05
I-131	1.52E-02
I-132	4.33E-02
I-133	6.18E-02
XE-133	2.24E+04
XE-133M	<del>1.09E+03</del> 9.67E+02 ←
CS-134	1.22E-04
I-135	5.20E-02
XE-135	2.12E+04
XE-135M	6.69E+01
CS-137	6.97E-04
XE-137	2.81E+02
XE-138	1.34E+02
BA-140	1.95E-03
BA-LA-140	3.04E-04
LA-140	1.39E-03
CE-144	1.68E-05

LIQUID EFFLUENTS  
NUCLIDES RELEASED

NUCLIDES RELEASED	ACTIVITY (CI)
NA-24	1.16E-03
AR-41	2.59E-05
CR-51	2.95E-02
MN-54	1.74E-02
FE-55	2.76E-02

N/A=NOT APPLICABLE  
 N/D=NOT DETECTED  
 N/R=NOT REPORTED

8803160030 880309  
 PDR ADDCK 05000324  
 R PDR

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT FOR YEAR 1986  
AIRBORNE AND LIQUID EFFLUENTS

LIQUID EFFLUENTS NUCLIDES RELEASED	ACTIVITY (CI)
MN-56	7.08E-05
CO-58	1.50E-03
FE-59	2.98E-04
CO-60	3.64E-02
ZN-65	2.39E-05
AS-76	3.38E-04
KR-85	5.16E-04
KR-87	8.88E-06
SR-90	6.99E-05
Y-91M	1.93E-05
SR-92	6.93E-05
Y-92	1.19E-04
NB-95	4.07E-06
NB-95M	4.54E-06
NB-97	3.51E-04
TC-99M	6.53E-05
RU-103	2.65E-05
TC-104	1.17E-05
RU-105	7.00E-05
AG-110M	1.95E-04
I-131	5.72E-04
I-133	3.78E-04
XE-133	1.35E-02
XE-133M	3.18E-04
CC-134	1.36E-03
XE-135	3.22E-02
XE-135M	1.90E-05
CS-137	8.12E-03
LA-140	1.49E-05
CE-141	3.11E-06
CE-144	1.42E-05
W-187	1.76E-05

TOTAL AIRBORNE TRITIUM RELEASE	7.07E+00
TOTAL LIQUID TRITIUM RELEASE	5.78E+00

VOLUME OF LIQUID WASTE RELEASED (PRIOR TO DILUTION)	LITERS	1.88E+07
VOLUME OF DILUTION WATER USED DURING PERIOD	LITERS	7.00E+10

N/A=NOT APPLICABLE  
N/D=NOT DETECTED  
N/R=NOT REPORTED

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT FOR YEAR 1986  
SOLID EFFLUENTS

SOLID WASTE DISPOSITION		MODE OF TRANSPORTATION		DESTINATION	
NUMBER OF SHIPMENTS					
82		SOLE USE		BARNWELL SC	
5		SOLE USE		RICHLAND WA	

ESTIMATE OF MAJOR NUCLIDE COMPOSITION (BY TYPE OF WASTE)		JAN-JUNE	JULY-DEC
<b>A</b>			
CO-58	X	1.20E+00	3.12E+00
CO-60	X	4.38E+01	3.45E+01
CR-51	X	1.09E+00	1.02E+01
CS-137	X	4.01E+00	3.94E+00
FE-55	X	2.95E+01	2.72E+01
MN-54	X	1.56E+01	1.67E+01
NI-63	X	2.82E+00	2.34E+00
<b>B</b>			
CO-60	X	2.90E+01	4.12E+01
CS-137	X	4.68E+00	5.35E+00
FE-55	X	5.50E+01	4.23E+01
MN-54	X	7.55E+00	5.82E+00
NI-63	X		9.98E-01
SR-89	X	2.09E+00	2.80E+00
<b>D</b>			
CO-60	X		2.78E+01
FE-55	X		4.47E+01
PU-241	X		4.65E+00
SR-89	X		1.41E+01
SR-90	X		8.64E+00

TYPE OF WASTE	UNIT	YEAR TOTAL
A. SPENT RESINS, FILTER SLUDGES, EVAPORATOR BOTTOMS, ETC.	M3	3.26E+02
	CI	1.81E+03
B. DRY COMPRESSIBLE WASTE, CONTAMINATED EQUIPMENT, ETC.	M3	5.88E+02
	CI	3.28E+01
C. IRRADIATED COMPONENTS, CONTROL RODS, ETC.	M3	
	CI	
D. OTHER	M3	8.30E+00
SOLIDIFIED OIL	CI	87E-02

N/A=NOT APPLICABLE  
N/D=NOT DETECTED  
N/R=NOT REPORTED

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT FOR 1986  
SUPPLEMENTAL INFORMATION

UNIT NUMBER 1 TYPE BWR  
DOCKET NO. 50-325  
COMMERCIAL OPERATION 03/18/77  
COOLING WATER SOURCE CAPE FEAR RIVER

LICENSEE CAROLINA POWER & LIGHT  
LICENSED POWER (MWT) 2435.  
INITIAL CRITICALITY 10/08/76

UNIT NUMBER 2 TYPE BWR  
DOCKET NO. 50-324  
COMMERCIAL OPERATION 11/03/75  
COOLING WATER SOURCE CAPE FEAR RIVER

LICENSEE CAROLINA POWER & LIGHT  
LICENSED POWER (MWT) 2436.  
INITIAL CRITICALITY 03/20/75

MAXIMUM PERMISSIBLE CONCENTRATIONS(MICROCURIES/ML)

## MEASUREMENTS AND APPROXIMATIONS OF TOTAL RADIOACTIVITY

## FISSION AND ACTIVATION GASES

ANALYSIS FOR SPECIFIC RADIONUCLIDES IN REPRESENTATIVE GRAB SAMPLES AND PARTICULATE FILTER  
BY GAMMA SPECTROSCOPY

## IODINES

ANALYSIS FOR SPECIFIC RADIONUCLIDES COLLECTED ON CHARCOAL CARTRIDGES BY GAMMA SPECTROSCOPY

## PARTICULATES

ANALYSIS FOR SPECIFIC RADIONUCLIDES COLLECTED ON FILTER PAPERS BY GAMMA SPECTROSCOPY

## LIQUID EFFLUENTS

ANALYSIS FOR SPECIFIC RADIONUCLIDES BY INDIVIDUAL RELEASES AND COMPOSITE SAMPLE BY  
GAMMA SPECTROSCOPY

## EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT FOR 1986

## SUPPLEMENTAL INFORMATION

AVERAGE ENERGY(MEV/DISINTEGRATION)	FIRST SIX MONTHS	
	BETA	GAMMA
BATCH RELEASES		FIRST SIX MONTHS
A. LIQUID		
1. NUMBER OF BATCH RELEASES-		134
2. TOTAL TIME PERIOD FOR BATCH RELEASES(MIN)-		1.37E 4
3. MAXIMUM TIME PERIOD FOR A BATCH RELEASE(MIN)-		2.09E 2
4. AVERAGE TIME PERIOD FOR BATCH RELEASES(MIN)-		1.02E 2
5. MINIMUM TIME PERIOD FOR A BATCH RELEASE(MIN)-		1.00E 0
6. AVERAGE STREAM FLOW DURING PERIODS OF RELEASE OF EFFLUENT INTO A FLOWING STREAM(LTS/MIN)-		1.66E 6
B. GASEOUS		
1. NUMBER OF BATCH RELEASES-		0
2. TOTAL TIME PERIOD FOR BATCH RELEASES(MIN)-		0.00E 0
3. MAXIMUM TIME PERIOD FOR A BATCH RELEASE(MIN)-		0.00E 0
4. AVERAGE TIME PERIOD FOR BATCH RELEASES(MIN)-		0.00E 0
5. MINIMUM TIME PERIOD FOR A BATCH RELEASE(MIN)-		0.00E 0
ABNORMAL RELEASES		
A. LIQUID		
1. NUMBER OF RELEASES		0
2. TOTAL ACTIVITY RELEASED(CURIES)		0.00E 0
B. GASEOUS		
1. NUMBER OF RELEASES		1
2. TOTAL ACTIVITY RELEASES(CURIES)		1.20E- 5

N/D=NOT DETECTABLE

N/A=NOT APPLICABLE

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT FOR 1986

SUPPLEMENTAL INFORMATION

AVERAGE ENERGY(MEV/DISINTEGRATION)

	SECOND SIX MONTHS	
	BETA	GAMMA
BATCH RELEASES		SECOND SIX MONTHS
A. LIQUID		
1. NUMBER OF BATCH RELEASES-		148
2. TOTAL TIME PERIOD FOR BATCH RELEASES(MIN)-		1.76E 4
3. MAXIMUM TIME PERIOD FOR A BATCH RELEASE(MIN)-		1.62E 2
4. AVERAGE TIME PERIOD FOR BATCH RELEASES(MIN)-		1.19E 2
5. MINIMUM TIME PERIOD FOR A BATCH RELEASE(MIN)-		1.30E 1
6. AVERAGE STREAM FLOW DURING PERIODS OF RELEASE OF EFFLUENT INTO A FLOWING STREAM(LTS/MIN)-		2.03E 6
B. GASEOUS		
1. NUMBER OF BATCH RELEASES-		0
2. TOTAL TIME PERIOD FOR BATCH RELEASES(MIN)-		0.00E 0
3. MAXIMUM TIME PERIOD FOR A BATCH RELEASE(MIN)-		0.00E 0
4. AVERAGE TIME PERIOD FOR BATCH RELEASES(MIN)-		0.00E 0
5. MINIMUM TIME PERIOD FOR A BATCH RELEASE(MIN)-		0.00E 0
ABNORMAL RELEASES		
A. LIQUID		
1. NUMBER OF RELEASES		0
2. TOTAL ACTIVITY RELEASED(CURIES)		0.00E 0
B. GASEOUS		
1. NUMBER OF RELEASES		0
2. TOTAL ACTIVITY RELEASES(CURIES)		0.00E 0

N/D=NOT DETECTABLE

N/A=NOT APPLICABLE

INSTALLATION-BUNSWICK

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT FOR 1986  
GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES

	UNIT	QUARTER 1	QUARTER 2	EST TOTAL ERROR %
<b>A. FISSION AND ACTIVATION GASES</b>				
1. TOTAL RELEASE	CI	6.70E 3	1.39E 4	4.00E 1
2. AVERAGE RELEASE RATE FOR PERIOD	UCI/SEC	8.67E 2	1.77E 3	
3. PERCENT OF TECHNICAL SPECIFICATION LIMIT	X	1.51E- 1	2.18E- 1	
<b>B. IODINES</b>				
1. TOTAL IODINE-131	CI	8.03E- 5	3.97E- 4	4.00E 1
2. AVERAGE RELEASE RATE FOR PERIOD	UCI/SEC	1.03E- 5	5.05E- 5	
3. PERCENT OF TECHNICAL SPECIFICATION LIMIT	X			
<b>C. PARTICULATES</b>				
1. PARTICULATES WITH HALF-LIVES >8 DAYS	CI	2.92E- 3	4.51E- 3	
2. AVERAGE RELEASE RATE FOR PERIOD	UCI/SEC	3.75E- 4	5.73E- 4	
3. PERCENT OF TECHNICAL SPECIFICATION LIMIT	X			
4. GROSS ALPHA RADIOACTIVITY	CI	5.56E- 5	6.52E- 5	
<b>D. TRITIUM</b>				
1. TOTAL RELEASE	CI	1.44E 0	1.51E 0	
2. AVERAGE RELEASE RATE FOR PERIOD	UCI/SEC	1.05E- 1	1.92E- 1	
3. PERCENT OF TECHNICAL SPECIFICATION LIMIT	X			

N/D=NOT DETECTABLE

N/A=NOT APPLICABLE

INSTALLATION-BRUNSWICK

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT FOR 1986  
 GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES

	UNIT	QUARTER 3	QUARTER 4	EST TOTAL ERROR %
<b>A. FISSION AND ACTIVATION GASES</b>				
1. TOTAL RELEASE	CI	1.34E 4	1.11E 4	1.15E 2
2. AVERAGE RELEASE RATE FOR PERIOD	UCI/SEC	1.68E 3	1.40E 3	
3. PERCENT OF TECHNICAL SPECIFICATION LIMIT	X	5.19E- 1	3.76E- 1	
<b>B. IODINES</b>				
1. TOTAL IODINE-131	CI	8.89E- 3	5.24E- 3	7.00E 1
2. AVERAGE RELEASE RATE FOR PERIOD	UCI/SEC	1.12E- 3	6.59E- 4	
3. PERCENT OF TECHNICAL SPECIFICATION LIMIT	X			
<b>C. PARTICULATES</b>				
1. PARTICULATES WITH HALF-LIVES >8 DAYS	CI	9.36E- 3	1.55E- 2	7.00E 1
2. AVERAGE RELEASE RATE FOR PERIOD	UCI/SEC	1.18E- 3	1.95E- 3	
3. PERCENT OF TECHNICAL SPECIFICATION LIMIT	X			
4. GROSS ALPHA RADIOACTIVITY	CI	7.96E- 5	7.20E- 5	
<b>D. TRITIUM</b>				
1. TOTAL RELEASE	CI	1.99E 0	2.13E 0	7.00E 1
2. AVERAGE RELEASE RATE FOR PERIOD	UCI/SEC	2.50E- 1	2.68E- 1	
3. PERCENT OF TECHNICAL SPECIFICATION LIMIT	X			

N/D-NOT DETECTABLE

N/A-NOT APPLICABLE



## INSTALLATION-BRUNSWICK

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT FOR 1986  
GASEOUS EFFLUENTS-ELEVATED RELEASE

NUCLIDES RELEASED	UNIT	CONTINUOUS MODE		BATCH MODE	
		QUARTER 1	QUARTER 2	QUARTER 1	QUARTER 2
FISSION GASES					
H-3	CI	9.10E-2	2.03E-1		
AR-41	CI	2.43E-2	1.24E-1		
KR-85M	CI	1.31E-1	1.17E-0		
KR-87	CI	6.29E-1	1.46E-0		
KR-88	CI	4.10E-1	4.27E-1		
XE-135	CI	6.15E-1	2.09E-0		
XE-135M	CI	2.02E-0	7.39E-0		
XE-137	CI	1.79E-1	7.08E-1		
XE-138	CI	8.37E-0	3.47E-1		
IODINES					
I-131	CI	7.04E-4	3.20E-4		
I-132	CI	N/D	9.79E-4		
I-133	CI	1.12E-4	2.27E-3		
I-135	CI	N/D	2.59E-3		
PARTICULATES					
CR-51	CI	5.09E-5	1.76E-4		
MN-54	CI	3.58E-5	3.97E-5		
CO-58	CI	1.43E-5	2.14E-7		
CO-60	CI	2.68E-4	2.22E-4		
SR-89	CI	1.21E-5	9.29E-5		
SR-90	CI	2.19E-7	7.64E-7		
CS-134	CI	8.69E-6	2.67E-5		
CS-137	CI	5.53E-5	1.56E-4		
BA-140	CI	N/D	7.71E-5		
LA-140	CI	N/D	3.80E-5		

INSTALLATION=BRUNSWICK

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT FOR 1986  
GASEOUS EFFLUENTS-ELEVATED RELEASE

NUCLIDES RELEASED	UNIT	CONTINUOUS MODE		BATCH MODE	
		QUARTER 3	QUARTER 4	QUARTER 3	QUARTER 4
<b>FISSION GASES</b>					
H-3	CI	7.06E- 1	3.70E- 1		
AR-41	CI	1.89E 1	1.33E 1		
KR-85M	CI	5.35E 6	2.67E 0		
KR-87	CI	4.51E- 1	3.35E 0		
KR-88	CI	3.06E 0	5.34E 0		
XE-133	CI	3.96E 0	9.94E 0		
XE-135	CI	5.63E 0	4.36E 1		
XE-135M	CI	1.64E 1	3.78E 1		
XE-137	CI	9.26E 1	9.96E 1		
XE-130	CI	4.16E 1	4.91E 1		
<b>IODINES</b>					
I-131	CI	5.57E- 3	3.26E- 3		
I-132	CI	0.11E- 3	6.07E- 3		
I-133	CI	1.80E- 2	1.17E- 2		
I-135	CI	1.06E- 2	7.60E- 3		
<b>PARTICULATES</b>					
CR-51	CI	1.41E- 4	3.92E- 4		
MN-54	CI	3.36E- 5	3.60E- 5		
CO-58	CI	5.90E- 6	1.17E- 5		
CO-60	CI	5.93E- 5	5.10E- 5		
SR-89	CI	5.17E- 4	9.56E- 4		
SR-90	CI	1.96E- 6	3.67E- 6		
CS-137	CI	1.27E- 5	2.61E- 5		
BA-140	CI	6.80E- 4	1.23E- 3		
LA-140	CI	4.83E- 4	8.71E- 4		

## INSTALLATION-BRUNSWICK

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT FOR 1986  
GASEOUS EFFLUENTS-GROUND RELEASE

ISOTOPES RELEASED	UNIT	CONTINUOUS MODE		BATCH MODE	
		QUARTER 1	QUARTER 2	QUARTER 1	QUARTER 2
<b>FISSION GASES</b>					
I-131	CI	1.35E 0	1.31E 0		
CR-85M	CI	4.45E- 1	2.28E- 1		
CR-88	CI	2.11E 0	1.08E 0		
CE-133	CI	4.89E 3	1.09E 4		
CE-133M	CI	2.42E 2	6.22E 2		
CE-135	CI	1.54E 3	2.29E 3		
CE-135M	CI	1.97E 0	1.01E 0		
<b>IODINES</b>					
I-131	CI	9.93E- 6	7.73E- 5		
I-133	CI	2.40E- 5	4.60E- 4		
<b>PARTICULATES</b>					
CR-51	CI	7.61E- 4	1.02E- 3		
CR-54	CI	2.84E- 4	6.48E- 4		
CO-57	CI	2.10E- 7	N/D		
CO-58	CI	3.45E- 5	4.33E- 5		
FE-59	CI	1.36E- 5	5.20E- 5		
CO-60	CI	1.17E- 3	1.58E- 3		
CR-89	CI	3.29E- 6	1.07E- 5		
CR-90	CI	4.36E- 7	7.41E- 7		
CR-95	CI	N/D	1.90E- 6		
CS-134	CI	2.63E- 5	6.04E- 5		
CS-137	CI	1.65E- 4	2.54E- 4		
CE-144	CI	1.68E- 5	N/D		

INSTALLATION-BRUNSWICK

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT FOR 1986  
GASEOUS EFFLUENTS-GROUND RELEASE

NUCLIDES RELEASED	UNIT	CONTINUOUS MODE		ATCH MODE	
		QUARTER 3	QUARTER 4	QUARTER 3	QUARTER 4
<b>FISSION GASES</b>					
H-3	CI	1.28E 0	1.76E 0		
KR-85M	CI	7.59E- 2	N/D		
KR-88	CI	3.60E- 1	N/D		
XE-133	CI	2.34E 3	4.23E 3		
XE-133M	CI	<del>1.03E 3</del>	N/D	1.03E 2	←
XE-135	CI	1.07E 4	6.60E 3		
XE-135M	CI	3.36E- 1	N/D		
<b>IODINES</b>					
I-131	CI	3.32E- 3	1.98E- 3		
I-132	CI	1.67E- 2	1.14E- 2		
I-133	CI	1.79E- 2	1.13E- 2		
I-135	CI	2.02E- 2	1.99E- 2		
<b>PARTICULATES</b>					
CR-51	CI	6.02E- 3	1.01E- 2		
MN-54	CI	3.50E- 4	4.77E- 4		
CO-58	CI	1.24E- 4	2.32E- 4		
FE-59	CI	N/D	8.44E- 5		
CO-60	CI	5.54E- 4	8.38E- 4		
ZN-65	CI	N/D	6.37E- 5		
SR-89	CI	6.97E- 5	4.38E- 5		
SR-90	CI	6.39E- 7	2.36E- 7		
AG-110M	CI	4.19E- 5	N/D		
CS-137	CI	7.08E- 6	1.96E- 5		
BA-LA-140	CI	2.47E- 4	5.70E- 5		

INSTALLATION-BRUNSWICK

EFFLUENT AND WASTE DISPOSAL REPORT FOR 1986  
LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES

	UNIT	QUARTER 1	QUARTER 2	EST TOTAL ERROR %
<b>A. FISSION AND ACTIVATION PRODUCTS</b>				
1. TOTAL RELEASE (NOT INCLUDING TRITIUM, GASES, ALPHA)	CI	3.39E- 2	4.89E- 2	3.50E 1
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	UCI/ML	4.81E- 9	3.13E- 9	
3. PERCENT OF APPLICABLE LIMIT	%	1.28E- 1	8.60E- 2	
<b>B. TRITIUM</b>				
1. TOTAL RELEASE	CI	1.36E 0	1.27E 0	3.50E 1
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	UCI/ML	1.93E- 7	8.14E- 8	
3. PERCENT OF APPLICABLE LIMIT	%	6.43E- 3	2.71E- 3	
<b>C. DISSOLVED AND ENTRAINED GASES</b>				
1. TOTAL RELEASE	CI	7.42E- 4	1.45E- 3	3.50E 1
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	UCI/ML	1.05E-10	9.29E-11	
3. PERCENT OF APPLICABLE LIMIT	%	5.25E- 4	4.65E- 5	
<b>D. GROSS ALPHA RADIOACTIVITY</b>				
1. TOTAL RELEASE	CI	7.83E- 4	3.79E- 4	1.50E 1
<b>E. VOLUME OF WASTE RELEASED(PRIOR TO DILUTION)</b>				
	LITERS	3.99E 6	4.28E 6	1.25E 1
<b>F. VOLUME OF DILUTION WATER USED DURING PERIOD</b>				
	LITERS	7.05E 9	1.56E 10	1.30E 1

N/D=NOT DETECTABLE

N/A=NOT APPLICABLE

INSTALLATION=BRUNSWICK

EFFLUENT AND WASTE DISPOSAL REPORT FOR 1986  
LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES

	UNIT	QUARTER 3	QUARTER 4	EST TOTAL ERROR %
<b>A. FISSION AND ACTIVATION PRODUCTS</b>				
1. TOTAL RELEASE (NOT INCLUDING TRITIUM, GASES,ALPHA)	CI	1.81E- 2	2.50E- 2	3.50E 1
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	UCI/ML	9.10E-10	9.12E-10	
3. PERCENT OF APPLICABLE LIMIT	X	2.00E- 2	2.50E- 2	
<b>B. TRITIUM</b>				
1. TOTAL RELEASE	CI	7.51E- 1	2.40E 0	4.00E 1
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	UCI/ML	3.77E- 8	8.76E- 8	
3. PERCENT OF APPLICABLE LIMIT	X	1.25E- 3	2.92E- 3	
<b>C. DISSOLVED AND ENTRAINED GASES</b>				
1. TOTAL RELEASE	CI	5.10E- 3	3.92E- 2	3.50E 1
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	UCI/ML	2.56E-10	1.43E- 9	
3. PERCENT OF APPLICABLE LIMIT	X	1.20E- 4	7.15E- 4	
<b>D. GROSS ALPHA RADIOACTIVITY</b>				
1. TOTAL RELEASE	CI	1.54E- 3	0.00E 0	4.00E 1
<b>E. VOLUME OF WASTE RELEASED(PRIOR TO DILUTION)</b>				
	LITERS	3.71E 6	6.80E 6	1.25E 1
<b>F. VOLUME OF DILUTION WATER USED DURING PERIOD</b>				
	LITERS	1.99E 10	2.74E 10	1.30E 1

## INSTALLATION-BRUNSWICK

EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT FOR 1986  
LIQUID EFFLUENTS

ISOTOPES RELEASED	UNIT	CONTINUOUS MODE		BATCH MODE	
		QUARTER 1	QUARTER 2	QUARTER 1	QUARTER 2
IA-24	CI			1.15E-3	N/D
R-51	CI			3.78E-3	8.47E-3
IN-54	CI			4.88E-3	6.75E-3
E-55	CI			1.14E-2	1.07E-2
O-58	CI			6.27E-4	4.15E-4
E-59	CI			1.42E-4	3.49E-5
O-60	CI			9.90E-3	1.82E-2
IN-65	CI			1.63E-5	7.60E-6
CS-76	CI			2.28E-5	5.32E-5
R-90	CI			1.30E-5	4.75E-6
R-92	CI			5.17E-6	1.47E-5
IB-95	CI			4.07E-6	N/D
IB-95M	CI			N/D	4.54E-6
IB-97	CI			1.94E-4	1.28E-4
IC-99M	CI			5.99E-5	N/D
U-103	CI			2.65E-5	N/D
I-131	CI			N/D	2.37E-5
I-133	CI			4.89E-5	2.99E-5
CE-133	CI			9.57E-5	2.20E-4
CS-134	CI			2.74E-4	6.40E-4
CE-135	CI			6.46E-4	1.23E-3
CS-137	CI			1.38E-3	3.42E-3
E-141	CI			3.11E-6	N/D
E-144	CI			1.42E-5	N/D

N/D=NOT DETECTABLE

N/A=NOT APPLICABLE

INSTALLATION-BRUNSWICK

EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT FOR 1986  
LIQUID EFFLUENTS

NUCLIDES RELEASED	UNIT	CONTINUOUS MODE		BATCH MODE	
		QUARTER 3	QUARTER 4	QUARTER 3	QUARTER 4
NA-24	CI			N/D	5.38E- 6
AR-41	CI			2.59E- 5	N/D
CR-51	CI			9.95E- 4	1.63E- 2
MN-54	CI			4.27E- 3	1.46E- 3
FE-55	CI			4.08E- 3	1.45E- 3
MN-56	CI			N/D	7.08E- 5
CO-58	CI			3.10E- 4	1.51E- 4
FE-59	CI			6.16E- 5	5.98E- 5
CO-60	CI			5.18E- 3	3.13E- 3
AS-76	CI			6.44E- 6	2.56E- 4
KR-85	CI			5.16E- 4	N/D
KR-87	CI			N/D	8.08E- 6
SR-90	CI			2.86E- 5	2.27E- 5
Y-91M	CI			1.03E- 5	N/D
SR-92	CI			N/D	4.94E- 5
Y-92	CI			7.04E- 5	4.90E- 5
NB-97	CI			N/D	2.91E- 5
TC-99M	CI			1.10E- 6	4.32E- 6
TC-104	CI			N/D	1.17E- 5
RU-105	CI			N/D	7.00E- 5
AG-110M	CI			N/D	1.95E- 4
I-131	CI			2.09E- 4	4.39E- 4
I-133	CI			1.40E- 4	1.59E- 4
XE-133	CI			5.62E- 4	1.26E- 2
XE-133M	CI			N/D	3.18E- 4
CS-134	CI			3.65E- 4	8.46E- 5
XE-135	CI			3.98E- 3	2.63E- 2
XE-135M	CI			1.40E- 5	5.00E- 6
CS-137	CI			2.33E- 3	9.86E- 4
LA-140	CI			N/D	1.49E- 5
W-187	CI			N/D	1.76E- 5

N/D=NOT DETECTABLE

N/A=NOT APPLICABLE



EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT FOR 1986  
SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

FIRST SIX MONTHS

1. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (NOT IRRADIATED)

1. TYPE OF WASTE	UNIT	6-MONTH PERIOD	EST. TOTAL ERROR, %
A. SPENT RESINS, FILTER SLUDGES, EVAPORATOR BOTTOMS, ETC.	M3	1.62E 2	
	CI	6.49E 2	1.00E 1
B. DRY COMPRESSIBLE WASTE, CONTAMINATED EQUIPMENT, ETC.	M3	3.95E 2	
	CI	2.10E 1	1.00E 1
C. IRRADIATED COMPONENTS, CONTROL RODS, ETC.	M3		
	CI		
D. OTHER (DESCRIBE)	M3		
	CI		

2. ESTIMATE OF MAJOR NUCLIDE COMPOSITION (BY TYPE OF WASTE)

A.	CO-58	X	1.20E 0
	CO-60	X	4.38E 1
	CR-51	X	1.09E 0
	CS-137	X	4.01E 0
	FE-55	X	2.95E 1
	MN-54	X	1.56E 1
	NI-63	X	2.82E 0
B.	CO-60	X	2.90E 1
	CS-137	X	4.60E 0
	FE-55	X	5.50E 1
	MN-54	X	7.55E 0
	SR-89	X	2.09E 0

3. SOLID WASTE DISPOSITION

NUMBER OF SHIPMENTS  
44

MODE OF TRANSPORTATION  
SOLE USE

DESTINATION  
BARNWELL

N/D=NOT DETECTABLE

N/A=NOT APPLICABLE

INSTALLATION-BRUNSWICK

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT FOR 1986  
SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

SECOND SIX MONTHS

A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (NOT IRRADIATED)

	UNIT	6-MONTH PERIOD	EST. TOTAL ERROR, %
1. TYPE OF WASTE			
A. SPENT RESINS, FILTER SLUDGES, EVAPORATOR BOTTOMS, ETC.	M3	1.64E 2	
B. DRY COMPRESSIBLE WASTE, CONTAMINATED EQUIPMENT, ETC.	CI	1.16E 3	1.00E 1
C. IRRADIATED COMPONENTS, CONTROL RODS, ETC.	M3	1.93E 2	
D. OTHER (DESCRIBE)	CI	1.18E 1	1.00E 1
SOLIDIFIED OIL	M3	8.30E 0	
	CI	5.87E- 2	1.00E 1

2. ESTIMATE OF MAJOR NUCLIDE COMPOSITION (BY TYPE OF WASTE)

A.	CO-58	X	3.12E 0
	CO-60	X	3.45E 1
	CR-51	X	1.02E 1
	CS-137	X	3.94E 0
	FE-55	X	2.72E 1
	MN-54	X	1.67E 1
	NI-63	X	2.34E 0
B.	CO-60	X	4.12E 1
	CS-137	X	5.35E 0
	FE-55	X	4.23E 1
	MN-54	X	5.82E 0
	NI-63	X	9.98E- 1
	SR-89	X	2.80E 0
D.	CO-60	X	2.78E 1
	FE-55	X	4.47E 1
	PU-241		4.65E 0
	SR-89		1.41E 1
	SR-90		8.64E 0

3. SOLID WASTE DISPOSITION

NUMBER OF SHIPMENTS	MODE OF TRANSPORTATION	DESTINATION
38	SOLE USE	BARNWELL SC
5	SOLE USE	RICHLAND WA

N/D=NOT DETECTABLE

N/A=NOT APPLICABLE