



Log # TXX-88286
File # 10110
903.11
Ref. # 10CFR50.55(e)

March 11, 1988

William G. Council
Executive Vice President

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
DOCKET NOS. 50-445 AND 50-446
UNQUALIFIED TERMINAL BLOCKS
SDAR: CP-87-139 (FINAL REPORT)

Gentlemen:

On December 30, 1987, we verbally notified your Mr. R. F. Warnick of a deficiency involving equipment qualification of terminal blocks inside and outside of containment. We determined this deficiency to be reportable in our last report on this issue (TXX-88028 dated January 5, 1988). This is a final report to status corrective actions taken to resolve this deficiency.

Replacement of the Weidmuller terminal blocks (as described in TXX-88028) will be completed by October 1, 1988 for Unit 1 and Unit 2 fuel load for Unit 2.

Very truly yours,

A handwritten signature in cursive script that reads 'W. G. Council'.

W. G. Council

VIP/grr

c-Mr. R. D. Martin, Region IV
Resident Inspectors CPSES (3)

FE27
1/0