



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555
June 23, 1988

COMMONWEALTH EDISON COMPANY

AND

IOWA-ILLINOIS GAS AND ELECTRIC COMPANY

DOCKET NO. 50-254

QUAD CITIES NUCLEAR POWER STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 109
License No. DPR-29


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Commonwealth Edison Company (the licensee) dated January 29, 1988, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-29 is hereby amended to read as follows:

B. Technical Specifications

The Technical Specifications contained in Appendix A and B, as revised through Amendment No.109, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Leif J. Norrholm, Acting Director
Project Directorate III-2
Division of Reactor Projects - III,
IV, V and Special Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: June 23, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 109

FACILITY OPERATING LICENSE NO. DPR-29

DOCKET NO. 50-254

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the attached pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change.

REMOVE

1.1/2.1-2a

3.2/4.2-5a

3.2/4.2-12

INSERT

1.1/2.1-2a

3.2/4.2-5a

3.2/4.2-12

The definitions used above for the APRM scram trip apply. In the event of operation with a maximum fraction limiting power density (MFLPD) greater than the fraction of rated power (FRP), the setting shall be modified as follows:

$$S \leq (.58W_0 + 50) \frac{FRP}{MFLPD}$$

The definitions used above for the APRM scram trip apply.

The ratio of FRP to MFLPD shall be set equal to 1.0 unless the actual operating value is less than 1.0, in which case the actual operating value will be used.

This may also be performed by increasing the APRM gain by the inverse ratio, MFLPD/FRP, which accomplishes the same degree of protection as reducing the trip setting by FRP/MFLPD.

- C. Reactor low water level scram setting shall be 144 inches above the top of the active fuel* at normal operating conditions.
- D. Reactor low water level ECCS initiation shall be \geq 84 inches above the top of the active fuel* at normal operating conditions.
- E. Turbine stop valve scram shall be \leq 10% valve closure from full open.
- F. Turbine control valve fast closure scram shall initiate upon actuation of the fast closure solenoid valves which trip the turbine control valves.
- G. Main steamline isolation valve closure scram shall be \leq 10% valve closure from full open.
- H. Main steamline low-pressure initiation of main steamline isolation valve closure shall be \geq 825 psig.

*Top of active fuel is defined to be 360 inches above vessel zero (See Bases 3.2).

3.2 LIMITING CONDITION FOR OPERATION BASES

In addition to reactor protection instrumentation which initiates a reactor scram, protective instrumentation has been provided which initiates action to mitigate the consequences of accidents which are beyond the operator's ability to control, or terminates operator errors before they result in serious consequences. This set of specifications provides the limiting conditions of operation for the primary system isolation function, initiation of the emergency core cooling system, control rod block and standby gas treatment systems. The objectives of the specifications are (1) to assure the effectiveness of the protective instrumentation when required by preserving its capability to tolerate a single failure of any component of such systems even during periods when portions of such systems are out of service for maintenance and (2) to prescribe the trip settings required to assure adequate performance. When necessary, one channel may be made inoperable for brief intervals to conduct required functional tests and calibrations. Some of the settings on the instrumentation that initiates or controls core and containment cooling have tolerances explicitly stated where the high end values are both critical and may have a substantial effect on safety. It should be noted that the setpoints of other instrumentation, where only the high or low end of the setting has a direct bearing on safety, are chosen at a level away from the normal operating range to prevent inadvertent actuation of the safety system involved and exposure to abnormal situations.

Isolation valves are installed in those lines that penetrate the primary containment and must be isolated during a loss-of-coolant accident so that the radiation dose limits are not exceeded during an accident condition. Actuation of these valves is initiated by the protective instrumentation which serves the condition for which isolation is required (this instrumentation is shown in Table 3.2.1). Such instrumentation must be available whenever primary containment integrity is required. The objective is to isolate the primary containment so that the guidelines of 10 CFR 100 are not exceeded during an accident.

The instrumentation which initiates primary system isolation is connected in a dual bus arrangement. Thus the discussion given in the basis for Specification 3.1 is applicable here.

The low reactor level instrumentation is set to trip at > 8 inches on the level instrument (top of active fuel is defined to the 360 inches above vessel zero) and after allowing for the full power pressure drop across the steam dryer the low-level trip is at 504 inches above vessel zero, or 144 inches above the top of active fuel. Retrofit 8x8 fuel has an active fuel length 1.24 inches longer than earlier fuel designs. However, present trip setpoints were used in the LOCA analyses*. This trip initiates closure of Group 2 and 3 primary containment isolation valves but does not trip the recirculation pumps (reference SAR Section 7.7.2). For a trip setting of 504 inches above vessel zero and a 60-second valve closure time, the valves will be closed before perforation of the cladding occurs even for the maximum break; the setting is therefore adequate.

The low low reactor level instrumentation is set to trip when reactor water level is ≥ 444 inches above vessel zero (with top of active fuel defined as 360 inches above vessel zero, -59 inches is 84 inches above the top of active fuel). This trip initiates closure of Group 1 primary containment isolation valves (reference SAR Section 7.7.2.2) and also activates the ECC subsystems, starts the emergency diesel generator, and trips the recirculation pumps. This trip setting level was chosen to be low enough to prevent spurious operation but high enough to initiate ECCS operation and primary system isolation so that no melting of the fuel cladding will occur and so that postaccident cooling can be accomplished and the guidelines of 10 CFR 100 will not be exceeded. For the complete circumferential break of a 28-inch recirculation line and with the trip setting given above, ECCS initiation and primary isolation are initiated and in time to meet the above criteria. The instrumentation also covers the full spectrum of breaks and meets the above criteria.

The high-drywell pressure instrumentation is a backup to the water level instrumentation and, in addition to initiating ECCS, it causes isolation of Group 2 isolation valves. For the breaks discussed above, this instrumentation will initiate ECCS operation at about the same time as the low low water level instrumentation; thus the results given above are applicable here also. Group 2 isolation valves include the drywell vent, purge and sump isolation valves. High-drywell pressure activates only these valves because high drywell pressure could occur as the result of non-safety-related causes such as not purging the drywell air during start-up. Total system isolation is not desirable for these conditions, and only the valves in Group 2 are required to close. The low low water level instrumentation initiates protection for the full spectrum of loss-of-coolant accidents and causes a trip of Group 1 primary system isolation valves.

* Loss of coolant accident analysis for Dresden Units 2 & 3 and Quad Cities Units 1 & 2, NEDO-24146A, April, 1979

QUAD-CITIES
DPR-29

TABLE 3.2-2

INSTRUMENTATION THAT INITIATES OR CONTROLS THE CORE AND CONTAINMENT COOLING SYSTEMS

Minimum Number of Operable or Tripped Instrument Channels ^[1]	Trip Function	Trip Level Setting	Remarks
4	Reactor low low water level	≥ 84 inches above top of active fuel*	<ol style="list-style-type: none"> 1. In conjunction with low-reactor pressure initiates core spray and LPCI. 2. In conjunction with high-drywell pressure 120-second time delay and low-pressure core cooling interlock initiates auto blowdown. 3. Initiates HPCI and RCIC. 4. Initiates starting of diesel generators.
4 ^[4]	High-drywell pressure ^[2] , ^[3]	≤ 2.5 psig	<ol style="list-style-type: none"> 1. Initiates core spray, LPCI, HPCI, and SBGTS. 2. In conjunction with low low water level, 120-second time delay, and low-pressure core cooling interlock initiates auto blowdown. 3. Initiates starting of diesel generators. 4. Initiates isolation of control room ventilation.
2	Reactor low pressure	300 psig \leq 350 psig	<ol style="list-style-type: none"> 1. Permissive for opening core spray and LPCI admission valves. 2. In conjunction with low low reactor water level initiates core spray and LPCI.
	Containment spray interlock		Prevents inadvertent operation of containment spray during accident conditions.
2 ^[3] 4 ^[3]	2/3 core height containment high pressure	$\geq 2/3$ core height 0.5 psig \leq 1.5 psig	
2	Timer auto blowdown	≤ 120 seconds	In conjunction with low low reactor water level, high-drywell pressure, and low-pressure core cooling interlock initiates auto blowdown.
4	Low-pressure core cooling pump discharge pressure	100 psig \leq 150 psig	Defers APR actuation pending confirmation of low-pressure core cooling system operation.
2/BUS ^[5]	Undervoltage on emergency buses	3045 \pm 5% volts	<ol style="list-style-type: none"> 1. Initiates starting of diesel generators. 2. Permissive for starting ECCS pumps. 3. Removes nonessential loads from buses. 4. Bypasses degraded voltage timer.

* Top of active fuel is defined at 360" above vessel zero for all water levels used in the LOCA analysis



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

COMMONWEALTH EDISON COMPANY

AND

IOWA-ILLINOIS GAS AND ELECTRIC COMPANY

DOCKET NO. 50-265

QUAD CITIES NUCLEAR POWER STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 105
License No. DPR-30


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Commonwealth Edison Company (the licensee) dated January 29, 1988, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-30 is hereby amended to read as follows:

B. Technical Specifications

The Technical Specifications contained in Appendix A and B, as revised through Amendment No. 105, are hereby incorporated in this license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Leif J. Morrholm, Acting Director
Project Directorate III-2
Division of Reactor Projects - III,
IV, V and Special Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: June 23, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 105

FACILITY OPERATING LICENSE NO. DPR-30

DOCKET NO. 50-265

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the attached pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change.

REMOVE

1.1/2.1-2a

3.2/4.2-5a

3.2/4.2-12

INSERT

1.1/2.1-2a

3.2/4.2-5a

3.2/4.2-12

The definitions used above for the APRM scram trip apply. In the event of operation with a maximum fraction limiting power density (MFLPD) greater than the fraction of rated power (FRP), the setting shall be modified as follows:

$$S \leq (.5BW_D + 50) \frac{FRP}{MFLPD}$$

The definitions used above for the APRM scram trip apply.

The ratio of FRP to MFLPD shall be set equal to 1.0 unless the actual operating value is less than 1.0, in which case the actual operating value will be used.

This adjustment may also be performed by increasing the APRM gain by the inverse ratio, MFLPD/FRP, which accomplishes the same degree of protection as reducing the trip setting by FRP/MFLPD.

- C. Reactor low water level scram setting shall be 144 inches above the top of the active fuel* at normal operating conditions.
- D. Reactor low water level ECCS initiation shall be \geq 84 inches above the top of the active fuel* at normal operating conditions.
- E. Turbine stop valve scram shall be \leq 10% valve closure from full open.
- F. Turbine control valve fast closure scram shall initiate upon actuation of the fast closure solenoid valves which trip the turbine control valves.
- G. Main steamline isolation valve closure scram shall be \leq 10% valve closure from full open.
- H. Main steamline low-pressure initiation of main steamline isolation valve closure shall be \geq 825 psig.

*Top of active fuel is defined to be 360 inches above vessel zero (See Pares 3.2).

3.2 LIMITING CONDITION FOR OPERATION BASES

In addition to reactor protection instrumentation which initiates a reactor scram, protective instrumentation has been provided which initiates action to mitigate the consequences of accidents which are beyond the operator's ability to control, or terminates operator errors before they result in serious consequences. This set of specifications provides the limiting conditions of operation for the primary system isolation function, initiation of the emergency core cooling system, control rod block and standby gas treatment systems. The objectives of the specifications are (1) to assure the effectiveness of the protective instrumentation when required by preserving its capability to tolerate a single failure of any component of such systems even during periods when portions of such systems are out of service for maintenance and (2) to prescribe the trip settings required to assure adequate performance. When necessary, one channel may be made inoperable for brief intervals to conduct required functional tests and calibrations. Some of the settings on the instrumentation that initiates or controls core and containment cooling have tolerances explicitly stated where the high and low values are both critical and may have a substantial effect on safety. It should be noted that the setpoints of other instrumentation, where only the high or low end of the setting has a direct bearing on safety, are chosen at a level away from the normal operating range to prevent inadvertent actuation of the safety system involved and exposure to abnormal situations.

Isolation valves are installed in those lines that penetrate the primary containment and must be isolated during a loss-of-coolant accident so that the radiation dose limits are not exceeded during an accident condition. Actuation of these valves is initiated by the protective instrumentation which serves the condition for which isolation is required (this instrumentation is shown in Table 3.2.1). Such instrumentation must be available whenever primary containment integrity is required. The objective is to isolate the primary containment so that the guidelines of 10 CFR 100 are not exceeded during an accident.

The instrumentation which initiates primary system isolation is connected in a dual bus arrangement. Thus the discussion given in the basis for Specification 3.1 is applicable here.

The low reactor level instrumentation is set to trip at > 8 inches on the level instrument (top of active fuel is defined to be 360 inches above vessel zero) and after allowing for the full power pressure drop across the steam dryer the low-level trip is at 504 inches above vessel zero, or 144 inches above the top of active fuel. Retrofit 8x8 fuel has an active fuel length 1.24 inches longer than earlier fuel designs. However, present trip setpoints were used in the LOCA analyses (NEDO-24146A, April 1979). This trip initiates closure of Group 2 and 3 primary containment isolation valves but does not trip the recirculation pumps (reference SAR Section 7.7.2). For a trip setting of 504 inches above vessel zero (144 inches above top of active fuel) and a 60-second valve closure time, the valves will be closed before perforation of the cladding occurs even for the maximum break; the setting is therefore adequate.

The low low reactor level instrumentation is set to trip when reactor water level is ≥ 444 inches above vessel zero (with top of active fuel defined as 360 inches above vessel zero, -59 inches is 84 inches above the top of active fuel). This trip initiates closure of Group 1 primary containment isolation valves (reference SAR Section 7.7.2.2) and also activates the ECC subsystems, starts the emergency diesel generator, and trips the recirculation pumps. This trip setting level was chosen to be low enough to prevent spurious operation but high enough to initiate ECCS operation and primary system isolation so that no melting of the fuel cladding will occur and so that postaccident cooling can be accomplished and the guidelines of 10 CFR 100 will not be exceeded. For the complete circumferential break of a 28-inch recirculation line and with the trip setting given above, ECCS initiation and primary isolation are initiated and in time to meet the above criteria. The instrumentation also covers the full spectrum of breaks and meets the above criteria.

The high-drywell pressure instrumentation is a backup to the water level instrumentation and, in addition to initiating ECCS, it causes isolation of Group 2 isolation valves. For the breaks discussed above, this instrumentation will initiate ECCS operation at about the same time as the low low water level instrumentation; thus the results given above are applicable here also. Group 2 isolation valves include the drywell vent, purge and sump isolation valves. High-drywell pressure activates only these valves because high drywell pressure could occur as the result of non-safety-related causes such as not purging the drywell air during start-up. Total system isolation is not desirable for these conditions, and only the valves in Group 2 are required to close. The low low water level instrumentation initiates protection for the full spectrum of loss-of-coolant accidents and causes a trip of Group 1 primary system isolation valves.

QUAD-CITIES
DPR-30

TABLE 3.2-2

INSTRUMENTATION THAT INITIATES OR CONTROLS THE CORE AND CONTAINMENT COOLING SYSTEMS

Minimum Number of
Operable or Tripped
Instrument
Channels^[1]

	Trip Function	Trip Level Setting	Remarks
4	Reactor low low water level	≥ 84 inches above top of active fuel*	<ol style="list-style-type: none"> 1. In conjunction with low-reactor pressure initiates core spray and LPCI. 2. In conjunction with high-drywell pressure 120-second time delay and low-pressure core cooling interlock initiates auto blowdown. 3. Initiates HPCI and RCIC. 4. Initiates starting of diesel generators.
4[4]	High-drywell pressure ^[2] , [3]	≤ 2.5 psig	<ol style="list-style-type: none"> 1. Initiates core spray, LPCI, HPCI, and SBGTS. 2. In conjunction with low low water level, 120-second time delay, and low-pressure core cooling interlock initiates auto blowdown. 3. Initiates starting of diesel generators. 4. Initiates isolation of control room ventilation.
2	Reactor low pressure	300 psig \leq 350 psig	<ol style="list-style-type: none"> 1. Permissive for opening core spray and LPCI admission valves. 2. In conjunction with low low reactor water level initiates core spray and LPCI.
	Containment spray interlock		Prevents inadvertent operation of containment spray during accident conditions.
2[3] 4[3]	2/3 core height containment high pressure	$\geq 2/3$ core height 0.5 psig \leq 1.5 psig	
2	Timer auto blowdown	≤ 120 seconds	In conjunction with low low reactor water level, high-drywell pressure, and low-pressure core cooling interlock initiates auto blow-down.
4	Low-pressure core cooling pump discharge pressure	100 psig \leq 150 psig	Defers APR actuation pending confirmation of low-pressure core cooling system operation.
2/BUS[5]	Undervoltage on emergency buses	3045 \pm 5% volts	<ol style="list-style-type: none"> 1. Initiates starting of diesel generators. 2. Permissive for starting ECCS pumps. 3. Removes nonessential loads from buses. 4. Bypasses degraded voltage timer.

* Top of active fuel is defined at 360" above vessel zero for all water levels used in the LOCA analysis.