Ducuesne Light Company Beaver Velley Power Station PO Box 4 Shippingport, PA 15077-0004

JOHN D. SIEBER Vice President - Nurlear Group

(412) 643-5255

June 30, 1988

U. S. Nuclear Regulatory Commission

Attn: Document Control Desk

Washington, DC 20555

Reference: Beaver Valley Power Station, Unit No. 1 and No. 2

BV-1 Docket No. 50-334, License No. DPR-66 BV-2 Docket No. 50-412, License No. NPF-73

IE Bulletin 88-03

Gentlemen:

We have reviewed IE Bulletin 88-03, "Inadequate Latch Engagement in HFA Type Latching Relays Manufactured by General Electric Company" for applicability to Beaver Valley Units 1 and 2.

As a result of our review, no HFA relays were identified as being installed or planned for installation in safety-related systems at our facility. The bulletin requests a response within 120 days from plants who do not have HFA type latching relays subject to this bulletin. Accordingly, our actions with respect to the bulletin are complete.

The manpower expenditures for this bulletin was approximately 120 manhours total for the review and report preparation.

If you have any questions concerning this response, please contact my office.

Very truly yours,

J. D. Sieber Vice President Nuclear Group

cc: Mr. J. Beall, Sr. Resident Inspector

Mr. W. T. Russell, NRC Region I Administrator

Mr. P. Tam, Project Manager

TEIL

8807130163 880630 PDR ADOCK 05000334 Q PDC COMMONWEALTH OF PENNSYLVANIA)

SS:
COUNTY OF BEAVER

On this before me, Mula M hattor, a Notary Public in and for said Commonwealth and County, personally appeared J. D. Sieber, who being duly sworn, deposed, and said that (1) he is Vice President of Duquesne Light, (2) he is duly authorized to execute and file the foregoing Submittal on behalf of said Company, and (3) the statements set forth in the Submittal are true and correct to the best of his knowledge, information and belief.

SMILLA M. FACTORY, HOLLARS MINER

SMERIA U. FAVIORY, BOURRY PT. DURC SHIPPING PORT BORD, REAVER COUNTY AT COMMISSION EXPIRES OCT. 13, 1909