



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DETROIT EDISON COMPANY

WOLVERINE POWER SUPPLY COOPERATIVE, INCORPORATED

DOCKET NO. 50-341

FERMI-2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 16
License No. NPF-43


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Detroit Edison Company (the licensee) dated February 4, 1986, as supplemented June 7, 1986, and July 13, 1987, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-43 is hereby amended to read as follows:

Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 16, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. DECo shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Martin J. Virgilio, Director
Project Directorate III-1
Division of Reactor Projects - III, IV, V
& Special Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: March 21, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 16

FACILITY OPERATING LICENSE NO. NPF-43

DOCKET NO. 50-341

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains a vertical line indicating the area of change. The corresponding overleaf page is also provided to maintain document completeness.

REMOVE

3/4 6-31

INSERT

3/4 6-31

TABLE 3.6.3-1 (Continued)

PRIMARY CONTAINMENT ISOLATION VALVES

<u>VALVE FUNCTION AND NUMBER</u>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>
B. <u>Remote-Manual Isolation Valves</u> ^(e) (Continued)	
19. <u>Primary Containment Monitoring System Torus Suction Isolation Valves</u>	NA
Division I: T50-F407A	
Division II: T50-F407B	
20. <u>Drywell Atmosphere Sample Isolation Valves</u>	NA
Division I: T50-F401A	
T50-F402A	
T50-F403A	
T50-F404A	
T50-F405A	
Division II: T50-F401B	
T50-F402B	
T50-F403B	
T50-F404B	
T50-F405B	
21. <u>Drywell to Suppression Chamber Vacuum Breakers N₂ Supply Isolation Valves</u>	NA
T48-F416	
T48-F417	
T48-F418	
T48-F419	
T48-F420	
T48-F421	
T48-F422	
T48-F423	
T48-F424	
T48-F425	
T48-F426	
T48-F427	

TABLE 3.6.3-1 (Continued)
PRIMARY CONTAINMENT ISOLATION VALVES

<u>VALVE FUNCTION AND NUMBER</u>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>
B. <u>Remote-Manual Isolation Valves</u> ^(e) (Continued)	
22. <u>Drywell Pressure Instrumentation Isolation Valves</u>	NA
Division I: T50-F420A	
Division II: T50-F420B	
23. <u>Suppression Pool Level Instrumentation Isolation Valves</u>	NA
Division I: E41-F401 ^(b)	
T50-F412A ^(b)	
E41-F400	
Division II: E41-F403 ^(b)	
T50-F412B ^(t)	
E41-F402	
24. <u>EECW Supply to Drywell Equipment Isolation Valves</u>	NA
Division I: P44-F607A	
Division II: P44-F606B	
25. <u>EECW Return from Drywell Equipment Isolation Valves</u>	NA
Division I: P44-F606A	
P44-F616	
Division II: P44-F607B	
P44-F615	