



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

March 17, 1988

Docket Nos. 50-445
and 50-446

APPLICANT: Texas Utilities Electric Company (TU Electric)
FACILITY: Comanche Peak Steam Electric Station (CPSES),
Units 1 and 2
SUBJECT: SUMMARY OF MEETING ON FEBRUARY 5, 1988 -
DEVELOPMENT AND ATTENUATION OF JETS
FROM HIGH-ENERGY LINE BREAKS

On February 5, 1988 NRC staff met with representatives of TU Electric, lead applicant for the CPSES, in NRC's Rockville, MD offices to discuss NRC comments on the Ebasco Services, Incorporated (Ebasco) jet attenuation calculation, CPE-SI-CA-0000-645. The meeting notice (with NRC's comments as enclosure) and a list of attendees are provided as Enclosures 1 and 2, respectively, to this summary.

During the NRC inspection of Ebasco's Systems Interaction Program for CPSES, the team reviewed Ebasco calculation CPE-SI-CA-0000-645 Revision 0 for jet attenuation from high-energy line breaks. NRC Inspection Report 50-445/87-37; 50-446/87-28 dated February 8, 1988 raised several technical issues concerning misinterpretations of terms and limitations in the theory being used to calculate jet attenuation. For example, Ebasco uses a method which is applicable to gaseous jets and can be used for steam and water jets if the quality beyond the asymptotic plane is greater than 90%. However, Ebasco uses this method without any restriction on the quality of the jet fluid.

During the meeting, TU Electric committed to provide NRC with justification for the attenuation factors employed in the analysis of single-phase steam jets and two-phase flashing water jets. By letter dated February 18, 1988 (TXX-88227), TU Electric informed NRC that they are performing analyses to demonstrate that the attenuation factors being utilized for CPSES are conservative (Enclosure 3). The results of these analyses were expected to be available during the week of February 22, 1988 for NRC review. TU Electric subsequently revised this time frame to late March 1988. The staff has scheduled a follow-up meeting for March 21, 1988 to discuss the results of these analyses with TU Electric representatives.

Melinda Malloy, Project Manager
Comanche Peak Project Division
Office of Special Projects

Enclosures:

1. Meeting Notice
2. List of Attendees
3. TXX-88227 dtd 2/18/88

cc: See next page

8803250217 880317
PDR ADOCK 05000445
A PDR

March 17, 1988

Summary of 2/5/88 meeting

- 2 -

DISTRIBUTION

Docket File

NRC PDR
Local PDR
OSP Reading
CPPD Reading
SEdnetter/JAxelrad
CGrimes
PMcKee
JLyons
RWarnick
JHWilson
CJamerson
GZech
BLiaw
BZalcman
MMalloy
SHou
LMarsh
JRichardson
LShao
AThadani
GWeidenhamer
MVagins
RBosnak
GARlotto
WLanning
OGC-OWFN
FMiraglia
EJordan
JPartlow
ACRS(10)

MMalloy
CPPD:OSP
MMalloy:em
03/17/88

[Signature]
CPPD:OSP
DNotkin
03/17/88

AD:CPPD:OSP
JHWilson
03/17/88

W. G. Council
Texas Utilities Electric Company

CC:
Jack R. Newman, Esq.
Newman & Holtzinger, P.C.
Suite 10.7
1615 L Street, N.W.
Washington, D.C. 20036

Robert A. Wooldridge, Esq.
Worsham, Forsythe, Sampels &
Wooldridge
2001 Bryan Tower, Suite 2500
Dallas, Texas 75201

Mr. Homer C. Schmidt
Director of Nuclear Services
Texas Utilities Electric Company
Skyway Tower
400 North Olive Street, L.B. 81
Dallas, Texas 75201

Mr. Robert E. Ballard, Jr.
Director of Projects
Gibbs and Hill, Inc.
11 Penn Plaza
New York, New York 10001

Mr. R. S. Howard
Westinghouse Electric Corporation
P. O. Box 355
Pittsburgh, Pennsylvania 15230

Renea Hicks, Esq.
Assistant Attorney General
Environmental Protection Division
P. O. Box 12548, Capitol Station
Austin, Texas 78711

Mrs. Juanita Ellis, President
Citizens Association for Sound Energy
1426 South Polk
Dallas, Texas 75224

Ms. Nancy H. Williams
CYGNA Energy Services
2121 N. California Blvd., Suite 390
Walnut Creek, CA 94596

Comanche Peak Steam Electric Station
Units 1 and 2

Asst. Director for Inspec. Programs
Comanche Peak Project Division
U.S. Nuclear Regulatory Commission
P. O. Box 1029
Granbury, Texas 76048

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Lanny A. Sinkin
Christic Institute
1324 North Capitol Street
Washington, D.C. 20002

Ms. Billie Pirner Garde, Esq.
Government Accountability Project
Midwest Office
104 East Wisconsin Avenue
Appleton, Wisconsin 54911

David R. Pigott, Esq.
Orrick, Herrington & Sutcliffe
600 Montgomery Street
San Francisco, California 94111

Anthony Z. Roisman, Esq.
Suite 600
1401 New York Avenue, NW
Washington, D.C. 20005

Robert Jablon
Bonnie S. Blair
Spiegel & McDiarmid
1350 New York Avenue, NW
Washington, D.C. 20005-4798

George A. Parker, Chairman
Public Utility Committee
Senior Citizens Alliance Of
Tarrant County, Inc.
6048 Wonder Drive
Fort Worth, Texas 76133

W. G. Council
Texas Utilities Electric Company

- 2 - Comanche Peak Electric Station
Units 1 and 2

cc:

Joseph F. Fulbright
Fulbright & Jaworski
1301 McKinney Street
Houston, Texas 77010

Roger D. Walker
Manager, Nuclear Licensing
Texas Utilities Electric Company
Skyway Tower
400 North Olive Street, L.B. 81
Dallas, Texas 75201

Mr. Jack Redding
c/o Bethesda Licensing
Texas Utilities Electric Company
3 Metro Center, Suite 610
Bethesda, Maryland 20814

William A. Burchette, Esq.
Counsel for Tex-La Electric Cooperative
of Texas
Heron, Burchette, Ruckert & Rothwell
Suite 700
1025 Thomas Jefferson Street, NW
Washington, D.C. 20007

GDS ASSOCIATES, INC.
Suite 720
1850 Parkway Place
Marietta, Georgia 30067-8237

Administrative Judge Peter Bloch
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Elizabeth B. Johnson
Administrative Judge
Oak Ridge National Laboratory
P. O. Box X, Building 3500
Oak Ridge, Tennessee 37830

Dr. Kenneth A. McCollom
1107 West Knapp
Stillwater, Oklahoma 74075

Dr. Walter H. Jordan
881 West Outer Drive
Oak Ridge, TN 37830



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

January 27, 1988

Docket Nos. 50-445
and 50-446

Reissued on Feb. 2, 1988 with
NRC comments on jet atten-
uation calculation
(CPE-SI-CA-0000-645) to be
addressed during the meeting

MEMORANDUM FOR: Christopher I. Grimes, Director
Comanche Peak Project Division
Office of Special Projects

THRU: James H. Wilson, Assistant Director
for Projects
Comanche Peak Project Division
Office of Special Projects

FROM: Melinda Malloy, Project Manager
Comanche Peak Project Division
Office of Special Projects

SUBJECT: FORTHCOMING MEETING WITH TU ELECTRIC

Date & Time: Friday, February 5, 1988
1:00 pm

Location: One White Flint North
11555 Rockville Pike
Room 16-B-11
Rockville, MD 20852

Purpose: For Applicant to discuss development and
attenuation of jets from high-energy line breaks

Participants*: NRC Applicant
D. Norkin D. West
J. Lyons R. Walker, et al.
P. T. Kuo
J. Wilson
M. Malloy

Enclosure: NRC comments
on calculation

Melinda Malloy
Melinda Malloy, Project Manager
Comanche Peak Project Division
Office of Special Projects

*Meetings between NRC technical staff and applicants for licenses are open for interested members of the public, petitioners, intervenors, or other parties to attend as observers pursuant to "Open Meetings and Statement of NRC Staff Policy," 43 Federal Register 28058, 6/28/78.

CONTACTS: Melinda Malloy or James H. Wilson
(301)492-0738 (301)492-3306

cc: See next page

280211781
4pp

COMMENTS ON CALCULATION CPE-SI-CA-0000-645

The procedure for evaluating the attenuation of jets resulting from high energy line ruptures given in the subject document has been reviewed. Our comments are as follows:

1. The document under review claims (Pg. 2) that Ref. 1 does not address the attenuation of the jet. We believe that Reference 1 does address the attenuation of the jet; although it does not appear as an explicit coefficient. Any attempt to develop an additional attenuation coefficient is inappropriate.
2. The procedure uses a method recommended by Reference 1 based on jet axial velocity, pressure and temperature profiles developed in Reference 2 instead of using Eq. D-2 and D-3 as prescribed in Reference 1. However, this method is applicable to gaseous jets and can be used for steam water mixture jets, if the quality beyond the asymptotic plane is greater than 90%. The subject document, however, uses this approach without any restriction on the quality of the jet fluid. Actually, the lower quality mixture behaves very differently from perfect gas, and because of the relatively higher density of the two phase fluid, the jet will attenuate at a significantly slower rate compared to the gaseous jets. This suggests that the method used in the document is not conservative for low-quality jets. In most cases of flashing water jets (both for primary and secondary coolant systems), the quality of the jet fluid is significantly lower than 90%. The assumption that water substantially separates out before the asymptotic plane resulting in a high quality steam beyond that plane cannot be justified.
3. The postulation (on page 13) that the force that the jet can impart to a target is proportional to $p + \rho V^2/2$ is not correct. The impingement force should be proportional to $(P - p)$.

Where P is the local stagnation pressure and p is the local static pressure and they are related by the following expression:

$$P = p \left\{ 1 + \frac{\gamma - 1}{2} M^2 \right\}^{\frac{\gamma}{\gamma - 1}}$$

Where M is the local Mach number.

It is to be noted that beyond the asymptotic plane, local static pressure (p) remains constant and is equal to the pressure surrounding the jet.

4. In a free jet the total momentum of the jet beyond asymptotic plane remains constant along the axis of the jet. As the jet entrains more and more of the ambient fluid, its velocity and temperature profiles become flatter. But if the target is large enough to intercept the entire jet, the impingement force does not drop even though the stagnation pressure at the jet axis has decayed substantially.

The document under review interprets Figure D.7 in Reference 1 as a plot of variation of local static pressure with distance. It is actually a plot of $(P - p)/p_e$ vs. distance, where p_e is the exit plane pressure of the jet. This figure is the same as Figure 5 of Reference 2. It is to be noted that $(P - p)$ is measured at the jet centerline. The incorrect use of this figure in the document under review has led to the conclusion that there is an additional attenuation factor. It is suggested that Ref. 2 be consulted in case further clarification is needed.

The work done by the jet fluid on the surrounding and the exchange of molecular kinetic energy do not result in any reduction of momentum of the entire jet including the entrained fluid, and any attenuation effect resulting from the work done by the jet and energy exchange cannot be justified.

5. Figure 6 of Reference 2 represents the decay of temperature difference ratio $(\Delta T_m / \Delta T_e)$. The subject document uses this figure inappropriately as temperature ratio (T^*) on Page 11. The error due to this might be significant for the range of temperature of interest.
6. The document determines the attenuation factor " α " in somewhat arbitrary fashion. First, it claims that this factor should follow the decay of P^* , and then, since the decay of P^* is excessive, it considers the decay of V^* as the acceptable attenuation. Since this factor has been applied to the impingement force on a target using Reference 1, the credit due to the attenuation of jet has been double-counted.

REFERENCES:

1. "Design Basis for Protection of Light Water Nuclear Power Plants Against Effects of Postulated Pipe Rupture," ANSI/ANS 58.2-1980.
2. Anderson, A. R. and Johns, F. R., "Characteristics of Free Supersonic Jets Exhausting into Quiescent Air," Jet Propulsion, January 1955.

ENCLOSURE 2

NRC/TU Electric Meeting on Development
and Attenuation of Jets
February 5, 1988

ATTENDEES

<u>Name</u>	<u>Affiliation</u>
D. Norkin	OSP/CPPD
J. H. Wilson	OSP/CPPD
J. E. Lyons	OSP/CPPD
D. A. West	TU Electric
R. G. eo	Ebasco
V. Inragarajan	Ebasco
R. D. Walker	TU Electric
R. Dacko	TU Electric
D. Lowrie	TU Electric
K. K. Niyogi	NRC consultant (United Engineers & Constructors)
G. H. Weidenhamer	RES/DE
S. Traiforos	NRC Consultant
G. Taday	NRC Consultant (United Engineers & Constructors)
R. C. Iotti	Ebasco
J. Moore	OGC
S. Hou	NRR



Log # TXX-88227
 File # 10010
 903.6
 Ref # 10CFR50.30(a)

February 18, 1988

William G. Counsil
 Executive Vice President

U. S. Nuclear Regulatory Commission
 ATTN: Document Control Desk
 Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
 DOCKETS NOS. 50-445 AND 50-446
 JET IMPINGEMENT ANALYSES

Gentlemen:

During the February 5, 1988 meeting with the NRC concerning CPSES jet impingement analyses, TU Electric committed to provide the NRC with justification for the attenuation factors employed in the analysis of single phase steam jets and two phase flashing water jets.

TU Electric is performing analyses to demonstrate that the attenuation factors presently being utilized at CPSES are conservative. These analyses are being performed as follows:

1. For single phase jets (i.e., jets with a quality greater than ninety percent) the attenuation factors contained in CPSES calculation CPE-SI-CA-0000-645 will be demonstrated to be conservative with respect to attenuation factors derived using the methodology presented in American National Standard ANSI/ANS 58.2, "Design Basis for Protection of Light Water Nuclear Power Plants Against Effects of Pipe Rupture".
2. For two phase flashing water jets, an analysis of CPSES specific lines will be performed to demonstrate that the attenuation factors contained in CPSES calculation CPE-SI-CA-0000-645 are conservative with respect to attenuation factors derived using the methodology presented in NUREG/CR-2913, "Two Phase Jet Loads".

Preliminary results of these analyses will be available during the week of February 22, for your review.


8802230165 880218
 PDR ADCK 05000445
 A PDR

Boo!
 1/10

TXX-88227
February 18, 1983
Page 2 of 2

We are confident that above analyses will demonstrate that the attenuation factors used at CPSES for single phase and two phase jets are justified.

Very truly yours,

A handwritten signature in cursive script, appearing to read "W. G. Council".

W. G. Council

BSD/amb

c - Mr. R. D. Martin, Region IV
Resident Inspectors, CPSES (3)