

UNITED STATES NUCLEAR REGULATORY COMMISSION  
DETROIT EDISON COMPANY  
WOLVERINE POWER SUPPLY COOPERATIVE, INCORPORATED  
DOCKET NO. 50-341  
NOTICE OF ISSUANCE OF AMENDMENT TO  
FACILITY OPERATING LICENSE

The United States Nuclear Regulatory Commission (the Commission) has issued Amendment No. 21 to Facility Operating License No. NPF-43, issued to the Detroit Edison Company and Wolverine Power Supply Cooperative, Inc. (the licensees), which revised the Technical Specifications (TSs) for operation of Fermi-2 located in Monroe County, Michigan. The amendment is effective as of the date of issuance.

This amendment revises the Fermi-2 Technical Specifications to delete the Non-regenerative Heat Exchanger Outlet Temperature-High signal from the listing of the Reactor Water Cleanup system isolation signals.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings, as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment.

Notice of Consideration of Issuance of Amendment to Facility Operating License and Opportunity for Hearing in connection with this action was published in the FEDERAL REGISTER on May 11, 1988 (53 FR 16801). No request for hearing or petition to intervene was filed following this notice.

Also in connection with this action, the Commission prepared an

Environmental Assessment and Finding of No Significant Impact which was published in the FEDERAL REGISTER on July 5 , 1988, at 53 FR 25219 .

For further details with respect to this action, see (1) the application for amendment dated March 10, 1988, as supplemented April 21, 1988, (2) Amendment No. 21 to License No. NPF-43, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C. 20555, and at the Monroe County Library System, 3700 South Custer Road, Monroe, Michigan 48161. A copy of items (2) and (3) may be obtained upon request addressed to the U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Director, Division of Reactor Projects - III, IV, V, and Special Projects.

Dated at Rockville, Maryland, this 6th day of July.

FOR THE NUCLEAR REGULATORY COMMISSION

*Theodore R. Quay*

Theodore R. Quay, Project Manager  
Project Directorate III-1  
Division of Reactor Projects - III,  
IV, V & Special Projects