




COLLEGE OF ENGINEERING
THE UNIVERSITY OF TEXAS AT AUSTIN

Department of Mechanical Engineering • Nuclear Engineering Program • Austin, Texas 78712 • (512) 471-5136

April 22, 1988



Mr. L.J. Callan, Director
Division of Reactor Projects
Nuclear Regulatory Commission
611 Ryan Plaza, Suite 1000
Arlington, Texas 76011

Re: Docket 50-192

Dear Mr. Callan:

The enclosed report is provided for the inspection notice of violation dated March 24, 1988.

An attachment of draft documents that supported the immediate response of the licensee to the referenced items is also included.

Please note that the licensee is experiencing the very unusual situation of construction, operation and dismantling activities at various stages of planning, implementation and completion. Curtailment of present routine operation activities are planned for April 29, 1988 with cessation of all operation by May 29, 1988. The licensee continues to incorporate numerous improvements in the docket 50-602 facility that are identified or recognized docket 50-192 deficiencies.

Sincerely,

Thomas L. Bauer

Thomas L. Bauer
Assistant Director
Nuclear Engineering
Teaching Laboratory

TLB:dlw
Enclosures (Items 1,2,3 &4)

cc: D. Klein
H. Marcus

8807180231 880422
PDR ADOCK 05000192
Q PNU

IC-88-588

11
1801

Letter of Reply to
Notice of ViolationUniv. of Texas
TRIGA Mark IDocket 50-192
Operating License 50-192

1. Reason for violation items A and B

The violations identified by the inspection report Mar 24, 1988 were the indirect result of the development of multiple Technical Specification documents during the period January 3, 1980 to November 9, 1984. The original document was in effect February 10, 1980 at the time of the license renewal request (docket 50-192). The current document was in effect July 29, 1983 at the issuance of the license renewal. Development of another document began in the subsequent months for the license application (docket 50-602) dated November 9, 1984. The latter two documents contained several changes to the administrative commitments from the original document. Unfortunately, the latter two documents also contain minor differences caused by different guidance material during the development process. The first document was developed from another licensee's document while the latter used the guidance of the ANS standards more directly, as well as the example of other licensee's documents. This series of sequential Tech. Specs. developments thus led to less than adequate (timely) attention to the details of the applicable document and perhaps confusion on the part of the staff responsible both for development and implementation of the documents. A contributing factor was the lack of a one-to-one correspondence of the applicable Tech. Specs. with procedures written from previous Tech. Specs.

The delay of actions by the licensee during the 41.5 month effective time for the original to current Tech. Spec. document development for docket 50-192 allowed the subsequent development of Tech. Specs. for docket 50-602 to interfere with the licensee's proper attention. It should be emphasized that the corrective action most important to these violations is the avoidance of a multiple commitment to license documents. This is clearly a one-of-kind situation that is expected to exist only during the existence of the University's commitment to two docket activities. The licensee will also be actively changing the Tech. Specs. during the next 6 months to represent the shutdown condition of the Facility. No facility critical operation is planned after May 29, 1988.

2. Corrective steps and results

Item A

An immediate check of the review dates on all procedures and a list was made of all modifications, of any type. A list was made of all changes and is to be submitted to the reactor committee for review at the next scheduled meeting. Changes were classified as typographical (5), clarification (3), and substantive (8). All substantive changes were conservative changes or corrections to procedure supplements and not the procedure itself.

Item B.1

An immediate review by staff of section 6.5 items was made to determine which items were explicitly addressed by procedures, which items were implicitly addressed by manufacturer documentation and which items were not addressed by either.

An alarm response procedure has been written and will be submitted for review by the reactor committee. A routine maintenance procedure has been drafted to identify applicable subject equipment. Action on this procedure is expected to be deferred indefinitely since pending facility shutdown will probably negate the idea of "routine maintenance". No major routine maintenance items were identified that impact safe operation. Transient rod inspections and instrumentation and control system calibrations are already applicable procedures.

Item B.2

The positive period method used by the license is a variation of a method specified in an approved experiment. A specific procedure is being prepared to be applied at the docket 50-602 facility. This procedure will be reviewed and applied, if necessary, at the docket 50-192 facility. Facility activities are expected to shutdown the docket 50-192 operation before the calibration procedure would be applicable. An amendment to the Tech. Specs. is planned that would remove this specification and others that directly relate to reactor operation.

3. Corrective steps to avoid future violation

Item A

A procedural control has already been drafted for use with the docket 50-602 activities, its use on the 50-192 activities will be examined. The procedures after committee review will be redated with revised dates to reflect the current status. A procedure drafted to address the issue of procedure controls has been reviewed, and a modified form will be submitted to the committee for review. A version of this procedure with a slight modification will be implemented for the remainder of the anticipated license period for the docket 50-192 activities.

Item B

No corrective action is proposed to prevent reoccurrence of this violation since a review and implementation of the appropriate procedures will resolve the deficiency. However, a method will be examined to better coordinate correspondence between the Tech. Specs. requirement with the applicable procedure. This coordination is already being applied to docket 50-602 activities.

4. Date for full compliance

Item A

Compliance of the items of part A are scheduled for a reactor committee meeting on April 29, 1988.

Item B

Compliance of the items of part B are scheduled to be completed within a period determined by the "routine" requirement and the procedure applicability. This time period was chosen so that the Tech. Specs. can be amended to reflect the shutdown condition of the reactor core prior to the implementation of fuel shipment and facility dismantlement. The last

scheduled day for operation of the R-92 facility at full power is May 29, 1988.

Item B.1

Compliance with item B.1. will be effective the date of the April 29, 1988 meeting.

Item B.2

Compliance with item B.2. is scheduled for the next applicable calibration or the change of Tech. Specs. to represent a shutdown facility condition. This period will be less than 6 months (probably 90 days) after the next scheduled reactor committee meeting.

Typographical Corrections To Technical
Specification Required Procedures

1. Procedure: Procedure For Determination Of Reactivity Insertion Rates, Shutdown Margin, And Excess Reactivity

Section: 3, Line 1

Original: Measurement of shutdown margin *(<.2% $\Delta K/K/sec$):

Revised: Measurement of shutdown margin *(>.2% $\Delta K/K$):

2. Procedure: Procedure For Fuel Movement

Section: 6, Step e, Line 2

Original: ... number shallbe plotted ...

Revised: ... number shall be plotted ...

3. Procedure: Appendix - Fuel Measurements

Section: 3, Line 1

Original: ... to maximum bridge balance

Revised: ... to maximum; bridge balance

Section: 8, Line 1

Original: ... to five position

Revised: ... to fine position

4. Procedure: Procedure For Semi-Annual Measurement Of Rod Drop Times

Section: 6, Step b, Line 1

Original: ... terminal 16 to

Revised: ... terminal 5 to

5. Procedure: Console Calibration Check

Section: VII, Part C, Instruction 6, subpart a

Original: 0.00001 molar KCl

Revised: 0.0001 molar KCl

Solutions used contain 7.465 mg/l KCl=0.0001 M KCl

Section: IX, Part B, Line 2

Original: ... using XA4TP

Revised: ... using XA4TP1

Section: IX, Part B, Tests 2 and 5

Original: 2. 4.175 + 0.003 _____ V DC

5. 7.083 + 0.018 _____ V DC

Revised: 2. 4.715 + 0.03 _____ V DC

5. 7.018 + 0.018 _____ V DC

Clarifications Added to Technical
Specification Required Procedures

1. Procedure: Procedure For Semi-Annual Measurement Of Rod Drop Times

Section: 5, Step 2

Original: ... terminal #16.

Revised: ... terminal #17.

Section: 5, Step b

Original: ... terminal #4.

Revised: ... terminal #5.

Section: APPENDIX, Channel A

Original: Probe to terminal 16

Revised: Probe to terminal 17

Section: APPENDIX, Channel 13

Original: Probe to terminal 4

Revised: Probe to terminal 5

Justification: Actual Test Points Not changed, only numerical reference to point changed to reflect clarification of label assignments discovered during detailed circuit tracing activities.

Section: APPENDIX: Third set of instructions

Original: Set trig RESET SINGLE

Perform drop

Revised: Set trig RESET SINGLE

Set view CHANNEL A

Perform drop

Section: Appendix

Original: none, add note

Revised: Note - Float Oscilloscope Power

- Ground Oscilloscope to Rod Drive Chassis

2. Procedure: Console Calibration Check

Section: I, part C

Original: Unchanged, add note below

Revised: Note: Log compensation voltage jack - J2C, Adjustment

Pot.-R3

Linear compensation voltage jack-J2D, Adjustment Pot.-R4

Section: II, Part D

Original: unchanged, add note below

Revised: Suggested Equipment - Keithley Current Source (grounded)

Keithley Micro-Micro Ammeter (float

ground)

Test Junction Box

Section: III, Parts A thru D; V, Parts A thru D; VI, Parts A thru G;

VIII, Parts A and D

Original: Entire sections as written

Revised: Insert the following statement at the beginning of each section - Completion of this section not required - Use discontinued or function duplicated during system upgrade.

Section: VII, Part B, Instruction 3, line 1

Original: ... control R508 with ...

Revised: ... control R23 with ...

Section: VII, Part B, Instruction 4, line 1

Original: ... control R506 with ...

Revised: ... control R21 with ...

Section: VIII, Part B, Instruction 1, Subpart c

Original: As written

Revised: Add - Note: TC Element #5981 only has two functioning thermocouples

Section: VIII, Part B, Instruction 2 thru 12

Original: As written

Revised: Delete - Instructions 2 thru 12 in entirety

Add 2. Using DC voltage supply, such as Keithley Millivolt Potentiometer, adjust voltage supply for signal representing 500°C from a chromel-alumel Thermocouple accounting for cold junction compensation in pyrometer

Example: $V_{\text{required}} = V(500^{\circ}\text{C}) - V(\text{ref})$

$19.8\text{mv} = 20.64\text{ mv} - 0.84\text{ mv}$

with reference junction temp of 21°C

3. Disconnect thermocouples from terminals 6, 7, 8, & 9 of TBI, verify pyrometers indicate full scale scrambled mode.

4. Connect voltage source to terminals for each meter,
 $V = \underline{\hspace{2cm}} \text{ mV}$

Meter	Terminal	Polarity
Right	6	+
	7	-
Left	8	+
	9	-

5. Read Pyrometers Left $\underline{\hspace{2cm}}^{\circ}\text{C}$, Right $\underline{\hspace{2cm}}^{\circ}\text{C}$

6. Reconnect thermocouples and compare fuel temperatures to reactor tank water temperature
Water $\underline{\hspace{2cm}}^{\circ}\text{C}$, Left $\underline{\hspace{2cm}}^{\circ}\text{C}$, Right $\underline{\hspace{2cm}}^{\circ}\text{C}$

7. Verify fuel temperature trip level set at $\leq 450^{\circ}\text{C}$
Left trip $\underline{\hspace{2cm}}^{\circ}\text{C}$, Right trip $\underline{\hspace{2cm}}^{\circ}\text{C}$

Section: IX, Part A, Instruction 6

Original: ... meter deflection. $\underline{\hspace{2cm}} \times 10^{-3}$ amps

Revised: ... meter deflection (125%). $\underline{\hspace{2cm}} 10^{-3}$ amps

Suggested equipment: Harrison Meter Calibrator (float ground)
Beckman Voltmeter
Test Junction Box

Section: IV, Part D, Instruction 2,3, and 4

Original: 2. ... A7TP2/S7 ...
3. ... A8TP3/S8 ...
4. ... A4TP3/S8 ...
Revised: 2. ... XA7TP2/S7 ...
3. ... XA8TP3/S8 ...
4. ... XA4TP3/S8 ...

Section: IX, Part D, Instruction 5

Original: 5 ... A4TP3/S8
Revised: 5 ... XA4TP3/S8

Add - Note: Source trip voltage level may be verified as
>2cps by the following process:
Pull source, connect pulse counter to J5. Count
for 10 min. True CPS = measured CPS $\div$ 1200. If
XA4TP3 voltage with the source out is less than
1.5V and the true count rate calculated is
greater than 2 cps, the source trip is at a
level > 2cps.

3. Procedure: Procedure for weekly calibration of area radiation
monitors

Section: Step 2, Line 2

Original: ... Adjust each reading to <500 volts as necessary
Revised: ... Adjust each reading to the measured plateau as necessary

Section: Step 4, Line 1

Original: ... in the Instrument Calibration ... obtained in #2 above
Revised: ... in the Weekly Instrument Calibration ... obtained in
step 3

Section: Step 5, Line 3

Original: Log this in the Instrument Calibration Log.
Revised: Log the alarm level in the Weekly Instrument Calibration Log

4. Procedure: Control rod inspection procedure

Section: Step 9, Line 2

Original: ... by prompt drops.
Revised: ... by prompt drops or positive period.

Minor Substantive Changes to Technical
Specification Required Procedures

1. Procedure: Procedure For Fuel Inspection And Measurement

Section: 4, Line 1, Step b

Original: Two persons ...; b. One person

Revised: Three persons ...; b. Two persons

Justification: Change to more conservative condition

2. Procedure: Console Calibration Check

Section: VII, Part A, Instruction 4, lines 3, 4

Original: ... HI range = 0.00005 $\mu\text{c/cc}$, 1 mr/hr; the LO range = 0.005 $\mu\text{c/cc}$, 10 mr/hr.

Revised: ... HI range = 0.00125 $\mu\text{c/cc}$, 2.5 mr/hr; the LO range = 0.0125 $\mu\text{c/cc}$, 25 mr/hr.

Justification: Reevaluation due to detector aging and shift of high voltage plateau

3. Procedure: Procedure for weekly calibration of area radiation monitors

Section: Step 1, Line 1

Original: ... the 1 $\mu\text{c}/2.5 \mu\text{c}$ radium ... test stand from the CAM drawer.

Revised: ... the 10 $\mu\text{c}/0.8 \mu\text{c}$ radium ... test stand.

Justification: Use of larger test source results is more accurate point source approximation since source to detector distance for given count rate is increased.

Section: Step 3, Line 1

Original: ... each of the first four ... with the 8.5 μc

Revised: ... each of the four ... with the 10 μc

Justification: Same as for Step 1, Line 1

Section: Step 5, Line 1

Original: ... of the five G/M ...

Revised: ... of the four G/M ...

Justification: Reflects actual number of detectors available as stated in Step 3.

4. Procedure: Emergency Plan

Section: Sl. Emergency Call List, Emergency Contacts #1 and #2

Original: 1. T.L. Bauer Reactor Supervisor 471-5136 345-5044

2. M.G. Krause Senior Reactor Operator 471-5136 259-1355

Revised: 1. T.L. Bauer Reactor Supervisor 471-5787 345-5044

2. M.G. Krause Senior Reactor Operator 471-5787 259-1355

Justification: Reassignment of secondary facility phone number to primary facility phone number, original primary phone number retained by facility director at reassigned office.

Section: Sl. Emergency Call List, Emergency Contacts #5 & #6
Original: 5. D.H. Eppes Nuclear Technical Specialist 471-5136
448-4681

6. D.G. Decker Safety Engineer 471-3511 305-5914
Revised: 5. D.G. Decker Safety Engineer 471-3511 345-5914
Justification: Reflect change in personnel

5. Procedure: Power Calibration Procedure, least-squares Linear Fit

Section: 2, numerator of m term

Original: $\sum X_i Y_i - \sum X_i \sum Y_i$

Revised: $\sum X_i Y_i - \sum X_i (\sum Y_i) / n$

Justification: Correction of error in least squares curve fit equation

6. Procedure: Semi-annual Tests of Minimum Interlocks and Safety
Circuits

Section: Step 10, line 2

Original: zero adjustment.

Revised: zero adjustment. Alternate method: Adjust % PWR zero
control to give indicated reading at 10%.

7. ~ Procedures with no date in index

8. ~CAM PROCEDURE - new solid state model

Alarm Response Procedure

INSTRUCTIONS:

1. Identify alarm.
2. Check system status.
3. Verify action level.
4. Take action specified.

EVENT:

ALARM - Area Monitor (Any 1 of 4)

CHECK - Identify radiation source and level with available equipment
Take necessary steps to limit radiation exposure

ACTION LEVEL - Measured Dose > 100 mR/hr, unknown source

ACTION - Shutdown Reactor, Evacuate Reactor Room

ALARM - Continuous Air Monitor

CHECK - Identify potential radiation source

ACTION LEVEL - Count rate > 2000 CPM, unknown source

ACTION - Evaluate CAM performance, monitor system closely

ACTION LEVEL - Count rate > 5000 CPM, unknown source

ACTION - Shutdown Reactor, Evacuate Reactor Room

ALARM - Pool Water Activity

CHECK - Verify meter zero, Lo sensitivity mode, and/or switch purification
suction from skimmer to direct

ACTION LEVEL - Water Activity > 0.0125 $\mu\text{Ci}/\text{cm}^3$

ACTION - Monitor CAM and other systems for abnormal radiation
levels

ALARM - Pool Temperature

CHECK - Observe installed instrumentation or measure sample with
thermometer; do not place mercury thermometer directly in pool

ACTION LEVEL - Water Temperature > 48°C (120°F)

ACTION - Initiate Pool Cooling or Shutdown Reactor

ALARM - Pool Level

CHECK - Visually observe pool level

ACTION LEVEL - Water Level < 4.5 m (15') above top grid plate

ACTION - Initiate Pool Fill or Shutdown Reactor

ALARM - Heat Exchanger Differential Pressure

CHECK - Observe setpoint and function of differential pressure sensor,
check for abnormal pressure indications in flow lines.

ACTION LEVEL - $\Delta P < 7 \text{ kPa}$ (1 Psi)

ACTION - Adjust System Pressure or Shutdown Heat Exchanger

Apply Item 7 to present R-92 license:

Procedure Title: NETL Procedure Outline and Control line 8
Revision Date: ~~Draft~~ 4/88 line 9
Revised
 Personnel: administrative, supervisory operator, line 10
 senior operator, reactor operator,
 research, faculty, assistant,
 technician, or student.
 Components: equipment, instruments, or materials, line 15
 safety devices, special tools,
 measurement instruments,
 calibration standards.
 Supplements: methods to perform calculations, line 20
 specific manuals, basic data tables,
 data sheets, forms, logs.
 Prerequisites: other procedures or tasks, line 25
 special physical conditions.

Instructions: line 30

1. Identify procedure by descriptive title, date of original or latest revision, and the procedure page number, (ADM - 1).
2. Determine responsible person for the procedure. Classification of personnel required to perform the procedure is to be specified.
3. Assemble applicable components for the procedure. Documentation of components required to complete the procedure is to be provided.
4. Locate the information related to the procedure. Sources of information applicable to the procedure should be compiled.
5. Verify the proper prerequisites for the procedure. Assurance of proper conditions for the procedure should be determined.
6. Follow the procedure instruction steps. Deviations from the procedures should not alter the substance or intent of the procedure.
7. Document temporary or permanent changes to a procedure. Notes on procedures are for guidance only. A change log documents changes.
 - a. Temporary changes or minor changes require approval of a senior operator. Record procedure page, effective date, initial, and change in the procedure change log.
 - b. Permanent changes or major changes require review by the reactor committee. Revise and reissue the procedure by reprint with the changes and the revision date.

Record of Procedure Changes

[illegible]