



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

CONSUMERS POWER COMPANY

PALISADES PLANT

DOCKET NO. 50-255

AMENDMENT TO PROVISIONAL OPERATING LICENSE

Amendment No. 113  
License No. DPR-20

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Consumers Power Company (the licensee) dated September 11, 1987, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public; and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 3.B. of Provisional Operating License No. DPR-20 is hereby amended to read as follows:


Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 113, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

8804060104 880325  
PDR ADOCK 05000255  
P PDR

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

  
Martin J. Virgilio, Director  
Project Directorate III-1  
Division of Reactor Projects - III, IV, V  
& Special Projects

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: March 25, 1988

ATTACHMENT TO LICENSE AMENDMENT NO.113  
PROVISIONAL OPERATING LICENSE NO. DPR-20  
DOCKET NO. 50-255

Revise Appendix A Technical Specifications by removing the page identified below and inserting the enclosed page. The revised page is identified by the captioned amendment number and contains marginal lines indicating the area of change.

REMOVE

4-14

INSERT

4-14

TABLE 4.2.1  
Minimum Frequencies for Sampling Tests

	<u>Test</u>	<u>Frequency</u>	<u>FSAR Section Reference</u>
1. Reactor Coolant Samples	Gross Activity Determination	3 Times/7 days with a maximum of 72 hours between samples (T avg greater than 500°F).	None
	Gross Gamma by Fission Product Monitor	Continuous when T avg is greater than 500°F(1).	None
	Isotopic analysis for dose equivalent I-131 concentration	1/14 days during power operation	None
	Radio chemical for E determination	1/6 months (2)	None
	Isotopic analysis for iodine, including I-131, 133, 135	a) Once/4 hours, whenever dose equivalent I-131 exceeds 1.0 $\mu$ CI/gram, and b) One sample between 2 and 6 hours following a thermal power change exceeding 15% of rated thermal power within a one hour period.	
	Chemistry (C1 and O2)	3 times/7 days with a maximum of 72 hours between samples (T avg greater than 210°F).	
	Chemistry (F1)	Once/30 days and following modifications or repair to the primary coolant system involving welding.	
2. Reactor Coolant Boron	Boron Concentration	Twice/Week	None
3. SIRW Tank Water Sample	Boron Concentration	Monthly	None
4. Concentrated Boric Acid Tanks	Boron Concentration	Monthly	None
5. SI Tanks	Boron Concentration	Monthly	6.1.2