

June 20, 1988

Docket No. 50-267

Mr. R. O. Williams, Jr.
Vice President, Nuclear Operations
Public Service Company of Colorado
Post Office Box 840
Denver, Colorado 80201-0840

Dear Mr. Williams:

SUBJECT: FORT ST. VRAIN NUCLEAR GENERATING STATION, AMENDMENT NO. 60
TO FACILITY OPERATING LICENSE NO. DPR-34 (TAC NO. 47416)

The Commission has issued the enclosed Amendment No. 60 to Facility Operating License No. DPR-34 for the Fort St. Vrain Nuclear Generating Station. This amendment consists of changes to the Technical Specifications (TS) in response to your application dated February 8, 1988.

The amendment revises certain setpoints for the Plant Protective System to allow for instrumentation errors. The proposed changes have been reviewed by our contractor, Idaho National Engineering Laboratory (INEL).

A copy of the Safety Evaluation and Notice of Issuance are also enclosed. The Notice of Issuance will be published in the Federal Register.

The staff and INEL have also identified a series of future actions which Public Service Company of Colorado should pursue. These actions are necessary to fully reflect instrumentation errors in the setpoints contained in the TS. We request that you provide us with your current schedule to submit the identified items for staff review. This schedule should be provided within 45 days of the date of this letter. The information requested in this letter affects fewer than 10 respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

/s/
Kenneth L. Heitner, Project Manager
Project Directorate - IV
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 60 to DPR-34
2. Safety Evaluation
3. Technical Evaluation Report
4. Notice of Issuance

cc w/enclosures:

See next page

DISTRIBUTION:

✓ Docket File
Local PDR
PNoonan (3)
JCalvo
EJordan

JPartlow
Wanda Jones
ACRS (10)
ARM/LFMB
S. Newberry

NRC PDR
PD4 Reading
KHeitner
OGC-Rockville
Plant File

TBarnhart (4)
EButcher
GPA/PA
DHagan

PD4/LA
PNoonan
05/23/88

PD4/PM
KHeitner:sr
05/24/88

SIC
SNewberry
05/26/88

OGC-Rockville
R. Buchanan
05/29/88

PD4/D
JCalvo
05/29/88
06/20/88

DF01
11

8807200189 880620
PDR ADOCK 05000267
PDC

June 20, 1988

Docket No. 50-267

Mr. R. O. Williams, Jr.
Vice President, Nuclear Operations
Public Service Company of Colorado
Post Office Box 840
Denver, Colorado 80201-0840

Dear Mr. Williams:

SUBJECT: FORT ST. VRAIN NUCLEAR GENERATING STATION, AMENDMENT NO. 60
TO FACILITY OPERATING LICENSE NO. DPR-34 (TAC NO. 47416)

The Commission has issued the enclosed Amendment No. 60 to Facility Operating License No. DPR-34 for the Fort St. Vrain Nuclear Generating Station. This amendment consists of changes to the Technical Specifications (TS) in response to your application dated February 8, 1988.

The amendment revises certain setpoints for the Plant Protective System to allow for instrumentation errors. The proposed changes have been reviewed by our contractor, Idaho National Engineering Laboratory (INEL).

A copy of the Safety Evaluation and Notice of Issuance are also enclosed. The Notice of Issuance will be published in the Federal Register.

The staff and INEL have also identified a series of future actions which Public Service Company of Colorado should pursue. These actions are necessary to fully reflect instrumentation errors in the setpoints contained in the TS. We request that you provide us with your current schedule to submit the identified items for staff review. This schedule should be provided within 45 days of the date of this letter. The information requested in this letter affects fewer than 10 respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

/s/
Kenneth L. Heitner, Project Manager
Project Directorate - IV
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 60 to DPR-34
2. Safety Evaluation
3. Technical Evaluation Report
4. Notice of Issuance

cc w/enclosures:

See next page

DISTRIBUTION:

Docket File

Local PDR

PNoonan (3)

JCalvo

EJordan

JPartlow

Wanda Jones

ACRS (10)

ARM/LFMB

S. Newberry

NRC PDR

PD4 Reading

KHeitner

OGC-Rockville

Plant File

TBarnhart (4)

EButcher

GPA/PA

DHagan

PD4/LA
PNoonan
05/23/88

PD4/PM
KHeitner:sr
05/24/88

SIC
SNewberry
06/06/88

OGC-Rockville
R. Bachmann
06/09/88

PD4/D
JCalvo
05/18/88
06/20/88



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555
June 20, 1988

Docket No. 50-267

Mr. R. O. Williams, Jr.
Vice President, Nuclear Operations
Public Service Company of Colorado
Post Office Box 840
Denver, Colorado 80201-0840

Dear Mr. Williams:

SUBJECT: FORT ST. VRAIN NUCLEAR GENERATING STATION, AMENDMENT NO. 60
TO FACILITY OPERATING LICENSE NO. DPR-34 (TAC NO. 47416)

The Commission has issued the enclosed Amendment No. 60 to Facility Operating License No. DPR-34 for the Fort St. Vrain Nuclear Generating Station. This amendment consists of changes to the Technical Specifications (TS) in response to your application dated February 8, 1988.

The amendment revises certain setpoints for the Plant Protective System to allow for instrumentation errors. The proposed changes have been reviewed by our contractor, Idaho National Engineering Laboratory (INEL).

A copy of the Safety Evaluation and Notice of Issuance are also enclosed. The Notice of Issuance will be published in the Federal Register.

The staff and INEL have also identified a series of future actions which Public Service Company of Colorado should pursue. These actions are necessary to fully reflect instrumentation errors in the setpoints contained in the TS. We request that you provide us with your current schedule to submit the identified items for staff review. This schedule should be provided within 45 days of the date of this letter. The information requested in this letter affects fewer than 10 respondents; therefore, CMB clearance is not required under P.L. 96-511.

Sincerely,

A handwritten signature in cursive script that reads "Kenneth L. Heitner".

Kenneth L. Heitner, Project Manager
Project Directorate - IV
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 60 to DPR-34
2. Safety Evaluation
3. Technical Evaluation Report
4. Notice of Issuance

cc w/enclosures:
See next page

Mr. R. O. Williams, Jr.
Public Service Company of Colorado

Fort St. Vrain

cc:

Mr. D. W. Warembourg, Manager
Nuclear Engineering Division
Public Service Company
of Colorado
P. O. Box 840
Denver, Colorado 80201-0840

Albert J. Hazle, Director
Radiation Control Division
Department of Health
4210 East 11th Avenue
Denver, Colorado 80220

Mr. David Alberstein, 14/159A
GA Technologies, Inc.
Post Office Box 85608
San Diego, California 92138

Mr. R. O. Williams, Jr., Acting Manager
Nuclear Production Division
Public Service Company of Colorado
16805 Weld County Road 19-1/2
Platteville, Colorado 80651

Mr. H. L. Brey, Manager
Nuclear Licensing and Fuel Division
Public Service Company of Colorado
P. O. Box 840
Denver, Colorado 80201-0840

Mr. P. F. Tomlinson, Manager
Quality Assurance Division
Public Service Company of Colorado
16805 Weld County Road 19-1/2
Platteville, Colorado 80651

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 640
Platteville, Colorado 80651

Mr. R. F. Walker
Public Service Company of Colorado
Post Office Box 840
Denver, Colorado 80201-0840

Kelley, Stansfield & O'Donnell
Public Service Company Building
Room 900
550 15th Street
Denver, Colorado 80202

Commitment Control Program
Coordinator
Public Service Company of Colorado
2420 W. 26th Ave. Suite 100-D
Denver, Colorado 80211

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Chairman, Board of County Commissioners
of Weld County, Colorado
Greeley, Colorado 80631

Regional Representative
Radiation Programs
Environmental Protection Agency
1 Denver Place
999 18th Street, Suite 1300
Denver, Colorado 80202-2413