

Docket/License: 50-245/DPR-21

JUL 01 1988

Northeast Nuclear Energy Company  
ATTN: Mr. Edward J. Mrocza  
Senior Vice President - Nuclear  
Engineering and Operations Group  
P.O. Box 270  
Hartford, Connecticut 06101-0270

Gentlemen:

Subject: Millstone 1 Inspection 50-245/88-07 (4/26/88 to 6/6/88)

This forwards the report for the above subject resident inspection of Millstone 1. The inspection results have been discussed with Mr. J. Stetz of your staff.

We identified a concern involving adherence to ACP-QA-4.03B, "Material Equipment Parts List." The ACP requires verification within sixty days and prior to an evaluation's incorporation into the MEPL. It nonetheless appears that the diesel generator speed switch was classified as a non-QA part in October of 1986 and this evaluation was not verified until May 1988. We have classified this matter as unresolved pending further review. The associated safety and performance significance is increased, in our view, by the NNECO verifying engineer's response statement (Report Detail 8.2) that there were no procedural requirements relating to the time interval between a MEPL determination and its verification.

Your cooperation with us is appreciated.

Sincerely,

Original Signed by:

Lee H. Bettenhausen, Chief  
Projects Branch No. 1  
Division of Reactor Projects

Enclosure: NRC Region I Inspection Report 50-245/88-07

cc w/encl:

W. D. Romberg, Vice President, Nuclear Operations  
R. M. Kacich, Manager, Generation Facilities Licensing  
D. O. Nordquist, Director of Quality Services  
S. E. Scafe, Station Superintendent  
Public Document Room (PDR)  
Local Public Document Room (LPDR)  
Nuclear Safety Information Center (NSIC)  
NRC Senior Resident Inspector  
State of Connecticut

OFFICIAL RECORD COPY

IR MILL1 88-07 - 0001.0.0  
11/29/80

8807200217 880701  
PDR ADOCK 05000245  
Q PDC

IEO111

Northeast Nuclear Energy Co.

2

01 JUL 1988

bcc w/encl:

Region I Docket Room (with concurrences)

Management Assistant, DRMA (w/o enclosures)

DRP Section Chief

M. Boyle, LPM, NRR

R. Bores, DRSS

R. Keimig, DRSS

Chief, Vendor Inspection Branch, NRR (See Detail 6.0)

*RS*  
RI:DRP  
RAYMOND  
5/29/88  
711

*M*  
RI:DRP  
MCCABE  
711

*MAS*  
RI:DRP  
BETTENHAUSEN  
7/1/88

OFFICIAL RECORD COPY

IR MILL1 88-07 - 0001.1.0  
11/29/80