



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

CAROLINA POWER & LIGHT COMPANY, et al.

DOCKET NO. 50-324

BRUNSWICK STEAM ELECTRIC PLANT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 146  
License No. DPR-62

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Carolina Power & Light Company (the licensee), dated September 29, 1987, as supplemented November 24, 1987, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications, as indicated in the attachment to this license amendment; and paragraph 2.C.(2) of Facility Operating License No. DPR-62 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. , are hereby incorporated in the license. Carolina Power & Light Company shall operate the facility in accordance with the Technical Specifications.

- 3. This license amendment is effective as of the date of its issuance and shall be implemented within 60 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

*Burt Buckley for*

Elinor G. Adensam, Director  
Project Directorate II-1  
Division of Reactor Projects I/II

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance:

LA: PD21:DRPR *[Signature]* PE: PD21:DRPR PH: PD21:DRPR OGC-B *[Signature]* D: PD21:DRPR  
 Anderson *[Signature]* GRequa *[Signature]* ESylvester/ *[Signature]* SH Lewis *[Signature]* EAdensam  
 3/21/88 3/21/88 3/22/88 3/25/88 4/1/88  
*Subject to resolution of matters raised in note of 3/25/88. BCB for*

ATTACHMENT TO LICENSE AMENDMENT NO. 146

FACILITY OPERATING LICENSE NO. DPR-62

DOCKET NO. 50-324

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages. The revised areas are indicated by marginal lines.

<u>Remove Pages</u>	<u>Insert Pages</u>
3/4 3-11	3/4 3-11
3/4 3-11a	3/4 3-11a
3/4 3-13	3/4 3-13
3/4 3-17	3/4 3-17
3/4 3-18	3/4 3-18
3/4 3-19	3/4 3-19
3/4 3-22	3/4 3-22
3/4 3-22a	3/4 3-22a
3/4 3-23	3/4 3-23
3/4 3-25	3/4 3-25
3/4 3-25a	3/4 3-25a
3/4 3-27	3/4 3-27

TABLE 3.3.2-1

ISOLATION ACTUATION INSTRUMENTATION

<u>TRIP FUNCTION AND INSTRUMENT NUMBER</u>	<u>VALVE GROUPS OPERATED BY SIGNAL(a)</u>	<u>MINIMUM NUMBER OPERABLE CHANNELS PER TRIP SYSTEM(b)(c)</u>	<u>APPLICABLE OPERATIONAL CONDITION</u>	<u>ACTION</u>
<b>1. PRIMARY CONTAINMENT ISOLATION</b>				
<b>a. Reactor Vessel Water Level -</b>				
1. Low, Level 1 (B21-LT-N017A-1,B-1,C-1,D-1) (B21-LTM-N017A-1,B-1,C-1,D-1)	2, 6, 7, 8	2	1, 2, 3	20
2. Low, Level 2 (B21-LT-N024A-1,B-1, and B21-LT-N025A-1,B-1)  (B21-LTM-N024A-1-1,B-1-1 and B21-LTM-N025A-1-1,B-1-1)	3	2	1, 2, 3	20
3. Low, Level 3 (B21-LT-N024A-1,B-1 and B21-LT-N025A-1,B-1)  (B21-LTS-N024A-1-2,B-1-2 and B21-LTS-N025A-1-2,B-1-2)	1	2	1, 2, 3	20
<b>b. Drywell Pressure - High</b>				
(C72-PT-N002A,B,C,D) (C72-PTM-N002A-1,B-1,C-1,D-1)	2, 6, 7	2	1, 2, 3	20
<b>c. Main Steam Line</b>				
1. Radiation - High (d) (D12-RM-K603A,B,C,D)	1	2	1, 2, 3 <sup>(h)</sup>	21
2. Pressure - Low (B21-PT-N015A,B,C,D) (B21-PTM-N015A-1,B-1,C-1,D-1)	1	2	1	22

3/4 3-11

Amendment No. 145, 142, 145, 146, 147, 148, 149, 150, 151, 152, 153, 154, 155

TABLE 3.3.2-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION

<u>TRIP FUNCTION AND INSTRUMENT NUMBER</u>	<u>VALVE GROUPS OPERATED BY SIGNAL(a)</u>	<u>MINIMUM NUMBER OPERABLE CHANNELS PER TRIP SYSTEM(b)(c)</u>	<u>APPLICABLE OPERATIONAL CONDITION</u>	<u>ACTION</u>
3. Flow - High (B21-PDT-N006A,B,C,D; B21-PDT-N007A,B,C,D; B21-PDT-N008A,B,C,D; B21-PDT-N009A,B,C,D)  (B21-PDTM-N006A-1,B-1,C-1,D-1; B21-PDTM-N007A-1,B-1,C-1,D-1; B21-PDTM-N008A-1,B-1,C-1,D-1; B21-PDTM-N009A-1,B-1,C-1,D-1)	1	2/line	1	22

TABLE 3.3.2-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION

<u>TRIP FUNCTION AND INSTRUMENT NUMBER</u>	<u>VALVE GROUPS OPERATED BY SIGNAL(a)</u>	<u>MINIMUM NUMBER OPERABLE CHANNELS PER TRIP SYSTEM(b)(c)</u>	<u>APPLICABLE OPERATIONAL CONDITION</u>	<u>ACTION</u>
<b>2. <u>SECONDARY CONTAINMENT ISOLATION</u></b>				
a. Reactor Building Exhaust Radiation - High (D12-RM-N010A,B)	6	1	1, 2, 3, 5, and*	23
b. Drywell Pressure - High (C72-PT-N002A,B,C,D) (C72-PTM-N002A-1,B-1,C-1,D-1)	2, 6, 7	2	1, 2, 3	23
c. Reactor Vessel Water Level - Low, Level 2 (B21-LT-N024A-1,B-1 and B21-LT-N025A-1,B-1)  (B21-LTM-NC24A-1-1,B-1-1 and B21-LTM-NC25A-1-1,B-1-1)	3	2	1, 2, 3	23
<b>3. <u>REACTOR WATER CLEANUP SYSTEM ISOLATION</u></b>				
a. Δ Flow - High (C31-dFS-N603-1A,1B)	3	1	1, 2, 3	24
b. Area Temperature - High (C31-TS-N600A,B,C,D,E,F)	3	2	1, 2, 3	24
c. Area Ventilation Δ Temp. - High (C31-TS-N602A,B,C,D,E,F)	3	2	1, 2, 3	24
d. SLCS Initiation (C41A-S1)	3 (f)	NA	1, 2, 3	24
e. Reactor Vessel Water Level - Low, Level 2 (B21-LT-N024A-1,B-1 and B21-LT-N025A-1,B-1)  (B21-LTM-NC24A-1-1,B-1-1 and B21-LTM-NC25A-1-1,B-1-1)	3	2	1, 2, 3	24

TABLE 3.3.2-2

ISOLATION ACTUATION INSTRUMENTATION SETPOINTS

<u>TRIP FUNCTION AND INSTRUMENT NUMBER</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
<b>1. PRIMARY CONTAINMENT ISOLATION</b>		
<b>a. Reactor Vessel Water Level -</b>		
1. Low, Level 1 (B21-LTM-N017A-1,B-1,C-1,D-1)	$\geq + 162.5$ inches <sup>(a)</sup>	$\geq + 162.5$ inches <sup>(a)</sup>
2. Low, Level 2 (B21-LTM-N024A-1-1,B-1-1 and B21-LTM-N025A-1-1,B-1-1)	$\geq + 112$ inches <sup>(a)</sup>	$\geq + 112$ inches <sup>(a)</sup>
3. Low, Level 3 (B21-LTS-N024A-1-2,B-1-2 and B21-LTS-N025A-1-2,B-1-2)	$\geq + 2.5$ inches <sup>(a)</sup>	$\geq + 2.5$ inches <sup>(a)</sup>
<b>b. Drywell Pressure - High</b> (C72-PTM-N002A-1,B-1,C-1,D-1)	$\leq 2$ psig	$\leq 2$ psig
<b>c. Main Steam Line</b>		
1. Radiation - High (D12-RM-K603A,B,C,D)	$\leq 3 \times$ full power background <sup>(b)</sup>	$\leq 3.5 \times$ full power <sup>(b)</sup> background
2. Pressure - Low (B21-PTM-N015A-1,B-1,C-1,D-1)	$\geq 825$ psig	$\geq 825$ psig
3. Flow - High (B21-PDTM-N006A-1,B-1,C-1,D-1; B21-PDTM-N007A-1,B-1,C-1,D-1; B21-PDTM-N008A-1,B-1,C-1,D-1; B21-PDTM-N009A-1,B-1,C-1,D-1)	$\leq 140\%$ of rated flow	$\leq 140\%$ of rated flow
4. Flow - High (B21-PDTS-N006A-2; B21-PDTS-N007B-2; B21-PDTS-N008C-2; B21-PDTS-N009D-2)	$\leq 40\%$ of rated flow	$\leq 40\%$ of rated flow

TABLE 3.3.2-2 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SETPOINTS

<u>TRIP FUNCTION AND INSTRUMENT NUMBER</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
<u>PRIMARY CONTAINMENT ISOLATION (Continued)</u>		
d. Main Steam Line Tunnel Temperature - High (B21-TS-N010A, B, C, D; B21-TS-N011A, B, C, D; B21-TS-N012A, B, C, D; B21-TS-N013A, B, C, D)	$\leq 200^{\circ}\text{F}$	$\leq 200^{\circ}\text{F}$
e. Condenser Vacuum - Low (B21-PTM-N056A-1, B-1, C-1, D-1)	$\geq 7$ inches Hg vacuum	$\geq 7$ inches Hg vacuum
f. Turbine Building Area Temp - High (B21-TS-3225A, B, C, D; B21-TS-3226A, B, C, D; B21-TS-3227A, B, C, D; B21-TS-3228A, B, C, D; B21-TS-3229A, B, C, D; B21-TS-3230A, B, C, D; B21-TS-3231A, B, C, D; B21-TS-3232A, B, C, D)	$\leq 200^{\circ}\text{F}$	$\leq 200^{\circ}\text{F}$
<u>2. SECONDARY CONTAINMENT ISOLATION</u>		
a. Reactor Building Exhaust Radiation - High (D12-RM-N010A, B)	$\leq 11$ mr/hr	$\leq 11$ mr/hr
b. Drywell Pressure - High (C72-PTM-N002A-1, B-1, C-1, D-1)	$\leq 2$ psig	$\leq 2$ psig
c. Reactor Vessel Water Level - Low, Level 2 (B21-LTM-N024A-1-1, B-1-1 and B21-LTM-N025A-1-1, B-1-1)	$\geq + 112$ inches <sup>(a)</sup>	$\geq + 112$ inches <sup>(a)</sup>



TABLE 3.3.2-2 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SETPOINTS

<u>TRIP FUNCTION AND INSTRUMENT NUMBER</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
<u>3. REACTOR WATER CLEANUP SYSTEM ISOLATION</u>		
a. $\Delta$ Flow - High (G31-dFS-N603-1A,1B)	$\leq$ 53 gal/min	$\leq$ 53 gal/min
b. Area Temperature - High (G31-TS-N600A,B,C,D,E,F)	$\leq$ 150°F	$\leq$ 150°F
c. Area Ventilation Temperature $\Delta$ Temp - High (G31-TS-N602A,B,C,D,E,F)	$\leq$ 50°F	$\leq$ 50°F
d. SLCS Initiation (C41A-S1)	NA	NA
e. Reactor Vessel Water Level - Low, Level 2 (B21-LTM-N024A-1-1,B-1-1 and B21-LTM-N025A-1-1,B-1-1)	$\geq$ + 112 inches <sup>(a)</sup>	$\geq$ + 112 inches <sup>(a)</sup>
<u>4. CORE STANDBY COOLING SYSTEMS ISOLATION</u>		
a. High Pressure Coolant Injection System Isolation		
1. HPCI Steam Line Flow - High (E41-PDTS-N004-2; E41-PDTS-N005-2)	$\leq$ 300% of rated flow	$\leq$ 300% of rated flow
2. HPCI Steam Line High Flow Time Delay Relay (E41-TDR-K33; E41-TDR-K43)	$3 \leq t \leq 7$ seconds	$3 \leq t \leq 12$ seconds
3. HPCI Steam Supply Pressure - Low (E41-PSL-N001A,B,C,D)	$\geq$ 100 psig	$\geq$ 100 psig

TABLE 3.3.2-3

ISOLATION SYSTEM INSTRUMENTATION RESPONSE TIME

<u>TRIP FUNCTION AND INSTRUMENT NUMBER</u>	<u>RESPONSE TIME (Seconds)†</u>
<u>1. PRIMARY CONTAINMENT ISOLATION</u>	
a. Reactor Vessel Water Level -	
1. Low, Level 1 (B21-LT-NO17A-1,B-1,C-1,D-1) (B21-LTM-NO17A-1,B-1,C-1,D-1)	≤13
2. Low, Level 2 (B21-LT-NO24A-1,B-1 and B21-LT-NO25A-1,B-1)  (B21-LTM-NO24A-1-1,B-1-1 and B21-LTM-NO25A-1-1,B-1-1)	≤1.0*
3. Low, Level 3 (B21-LT-NO24A-1,B-1 and B21-LT-NO25A-1,B-1)  (B21-LTS-NO24A-1-2,B-1-2 and B21-LTS-NO25A-1-2,B-1-2)	≤1.0*
b. Drywell Pressure - High (C72-PT-NO02A,B,C,D) (C72-PTM-NO02A-1,B-1,C-1,D-1)	≤13
c. Main Steam Line	≤1.0*
1. Radiation - High <sup>(b)</sup> (D12-RM-K603A,B,C,D)	
2. Pressure - Low (B21-PT-NO15A,B,C,D) (B21-PTM-NO15A-1,B-1,C-1,D-1)	≤13
3. Flow - High (B21-PDT-NO06A,B,C,D; B21-PDT-NO07A,B,C,D; B21-PDT-NO08A,B,C,D; B21-PDT-NO09A,B,C,D) --  (B21-PDTM-NO06A-1,B-1,C-1,D-1; B21-PDTM-NO07A-1,B-1,C-1,D-1; B21-PDTM-NO08A-1,B-1,C-1,D-1; B21-PDTM-NO09A-1,B-1,C-1,D-1)	≤0.5*
4. Flow - High (B21-PDTS-NO06A-2; B21-PDTS-NO07B-2; B21-PDTS-NO08C-2; B21-PDTS-NO09D-2)	≤0.5*

TABLE 3.3.2-3 (Continued)

ISOLATION SYSTEM INSTRUMENTATION RESPONSE TIME

<u>TRIP FUNCTION AND INSTRUMENT NUMBER</u>	<u>RESPONSE TIME (Seconds)†</u>
d. Main Steam Line Tunnel Temperature - High (B21-TS-NO10A,B,C,D; B21-TS-NO11A,B,C,D; B21-TS-NO12A,B,C,D; B21-TS-NO13A,B,C,D)	<u>&lt;13</u>
e. Condenser Vacuum - Low (B21-PT-NO56A,B,C,D) (B21-PTM-NO56A-1,B-1,C-1,D-1)	<u>&lt;13</u>

TABLE 3.3.2-3 (Continued)

ISOLATION SYSTEM INSTRUMENTATION RESPONSE TIME

<u>TRIP FUNCTION AND INSTRUMENT NUMBER</u>	<u>RESPONSE TIME (Seconds)#</u>
<u>PRIMARY CONTAINMENT ISOLATION (Continued)</u>	
f. Turbine Building Area Temperature - High (B21-TS-3225A,B,C,D; B21-TS-3226A,B,C,D; B21-TS-3227A,B,C,D; B21-TS-3228A,B,C,D; B21-TS-3229A,B,C,D; B21-TS-3230A,B,C,D; B21-TS-3231A,B,C,D; B21-TS-3232A,B,C,D)	NA
 <u>2. SECONDARY CONTAINMENT ISOLATION</u>	
a. Reactor Building Exhaust Radiation - High <sup>(b)</sup> (D12-RM-N010A,B)	≤13
b. Drywell Pressure - High (C72-PT-N002A,B,C,D) (C72-P M-N002A-1,B-1,C-1,D-1)	≤13
c. Reactor Vessel Water Level - Low, Level 2 (B21-LT-N024A-1,B-1 and B21-LT-N025A-1,B-1)  (B21-LTM-N024A-1-1,B-1-1 and B21-LTM-N025A-1-1,B-1-1)	≤1.0*
 <u>3. REACTOR WATER CLEANUP SYSTEM ISOLATION</u>	
a. Δ Flow - High (G31-dFS-N603-1A,1B)	≤13
b. Area Temperature - High (G31-TS-N600A,B,C,D,E,F)	≤13
c. Area Ventilation Temperature Δ T - High (G31-TS-N602A,B,C,D,E,F)	≤13
d. SLCS Initiation (C41A-S1)	NA
e. Reactor Vessel Water Level - Low, Level 2 (B21-LT-N024A-1,B-1 and B21-LT-N025A-1,B-1)  (B21-LTM-N024A-1-1,B-1-1 and B21-LTM-N025A-1-1,B-1-1)	≤1.0*

TABLE 4.3.2-1

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION AND INSTRUMENT NUMBER</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS IN WHICH SURVEILLANCE REQUIRED</u>
<b>1. PRIMARY CONTAINMENT ISOLATION</b>				
<b>a. Reactor Vessel Water Level -</b>				
1. Low, Level 1 (B21-LT-NO17A-1,B-1,C-1,D-1)	NA <sup>(a)</sup>	NA	R <sup>(b)</sup>	1, 2, 3
(B21-LTM-NO17A-1,B-1,C-1,D-1)	D	SA	SA	1, 2, 3
2. Low, Level 2 (B21-LT-NO24A-1,B-1 and B21-LT-NO25A-1,B-1)	NA <sup>(a)</sup>	NA	R <sup>(b)</sup>	1, 2, 3
(B21-LTM-NO24A-1,B-1 and B21-LTM-NO25A-1,B-1)	D	SA	SA	1, 2, 3
<b>b. Drywell Pressure - High</b>				
(C72-PT-NO02A,B,C,D)	NA <sup>(a)</sup>	NA	R <sup>(b)</sup>	1, 2, 3
(C72-PTM-NO02A-1,B-1,C-1,D-1)	D	SA	SA	1, 2, 3
<b>c. Main Steam Line</b>				
1. Radiation - High (D12-RM-K603A,B,C,D)	D	W	R <sup>(d)</sup>	1, 2, 3
2. Pressure - Low (B21-PT-NO15A,B,C,D)	NA <sup>(a)</sup>	NA	R <sup>(b)</sup>	1
(B21-PTM-NO15A-1,B-1,C-1,D-1)	D	SA	SA	1
3. Flow - High (B21-PDT-NO06A,B,C,D; B21-PDT-NO07A,B,C,D; B21-PDT-NO08A,B,C,D; B21-PDT-NO09A,B,C,D)	NA <sup>(a)</sup>	NA	R <sup>(b)</sup>	1
(B21-PDTM-NO06A-1,B-1,C-1,D-1; B21-PDTM-NO07A-1,B-1,C-1,D-1; B21-PDTM-NO08A-1,B-1,C-1,D-1; B21-PDTM-NO09A-1,B-1,C-1,D-1)	D	SA	SA	1

TABLE 4.3.2-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION AND INSTRUMENT NUMBER</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS IN WHICH SURVEILLANCE REQUIRED</u>
3. Flow - High (B21-PDT-N006A,B,C,D; B21-PDT-N007A,B,C,D; B21-PDT-N008A,B,C,D; B21-PDT-N009A,B,C,D)	NA <sup>(a)</sup>	NA	R <sup>(b)</sup>	1
(B21-PDTM-N006A-1,B-1,C-1,D-1; B21-PDTM-N007A-1,B-1,C-1,D-1; B21-PDTM-N008A-1,B-1,C-1,D-1; B21-PDTM-N009A-1,B-1,C-1,D-1)	D	M	M	1

TABLE 4.3.2-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION AND INSTRUMENT NUMBER</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS IN WHICH SURVEILLANCE REQUIRED</u>
<b>2. <u>SECONDARY CONTAINMENT ISOLATION</u></b>				
a. Reactor Building Exhaust Radiation - High (D12-RM-N010A,B)	D	M	R	1,2,3,5, and *
b. Drywell Pressure - High (C72-PT-N002A,B,C,D) (C72-PTM-N002A-1,B-1,C-1,D-1)	NA <sup>(a)</sup> D	NA M	R <sup>(b)</sup> M	1, 2, 3 1, 2, 3
c. Reactor Vessel Water Level - Low, Level 2 (B21-LT-N024A-1,B-1 and B21-LT-N025A-1,B-1) (B21-LTM-N024A-1-1,B-1-1 and B21-LTM-N025A-1-1,B-1-1)	NA <sup>(a)</sup> D	NA M	R <sup>(b)</sup> M	1, 2, 3 1, 2, 3
<b>3. <u>REACTOR WATER CLEANUP SYSTEM ISOLATION</u></b>				
a. Δ Flow - High (G31-dFS-N603-1A,1B)	D	M	R	1, 2, 3
b. Area Temperature - High (G31-TS-N600A,B,C,D,E,F)	NA	M	R	1, 2, 3
c. Area Ventilation Δ Temp - High (G31-TS-N602A,B,C,D,E,F)	NA	M	R	1, 2, 3
d. SLCS Initiation (C41A-S1)	NA	R	NA	1, 2, 3
e. Reactor Vessel Water Level - Low, Level 2 (E21-LT-N024A-1,B-1 and B21-LT-N025A-1,B-1) (B21-LTM-N024A-1-1,B-1-1 and B21-LTM-N025A-1-1,B-1-1)	NA <sup>(a)</sup> D	NA M	R <sup>(b)</sup> M	1, 2, 3 1, 2, 3