

# THE CLEVELAND ELECTRIC ILLUMINATING COMPANY P.O. BOX 97 . PERRY, OHIO 44081 . TELEPHONE (216) 259-3737 . ADDRESS-10 CENTER ROAD

Serving The Best Location in the Nation PERRY NUCLEAR POWER PLANT

Al Kaplan

VICE PRESIDENT NUCLEAR GROUP July 12, 1988 PY-CEI/NRR-0855 L

U.S. Nuclear Regulatory Commission Document Control Desk Washington, D. C. 20555

> Perry Nuclear Power Plant Docket No. 50-440 Emergency Technical Specification Change Request, Drywell Average Air Temperature

Gentlemen:

The Cleveland Electric Illuminating Company (CEI) hereby requests amendment of Facility Operating License NPF-58 for the Perry Nuclear Power Plant, Unit 1. In accordance with the requirement of 10 CFR 170.21 a check in the amount of \$150.00 is being transmitted by separate cover. In accordance with the requirements of 10 CFR 50.91(b)(1), a copy of this request for amendment has been sent to the State of Ohio as indicated below.

This amendment requests revision of Technical Specification Section 3.6.2.6 concerning Drywell Average Air Temperature Limits on an emergency basis. Attachment 1 provides the Summary, Significant Hazards and Environmental Impact Considerations. Attachment 2 is a copy of the marked up Technical Specification pages.

Any questions with respect to this request should be directed to R.A. Stratman, Manager, Operations at the following phone numbers; plant, 216-259-3737 extension 5173, home 216-257-6226.

Very truly yours,

Frank R Steed for

Al Kaplan Vice President Nuclear Group

AK:cab

Attachments

cc: K. Connaughton T. Colburn J. Harris (State of Ohio)

Attachment 1 PY-CEI/NRR-0855 L Page 1 of 6

## Summary

× · · ·

The existing Perry Technical Specification (3/4.6.2.6) requires that the drywell average air temperature not exceed 135°F. The proposed change would increase this drywell average air temperature limit to 145°F. This would allow for increased operational flexibility and would ensure continuous operation of Perry during the summer months.

CEI has completed the safety evaluation of the proposed increase of the drywell average air temperature from 135°F to 145°F. The results indicated that this initial drywell temperature increase has insignificant effects upon the peak drywell and containment pressures and temperatures used in the design. There is also no safety implication for a 10°F temperature increase with regard to important safety parameters, plant safety design and performance. Since initial drywell temperature effects are not significant on these safety parameters, the primary consideration for this change is the possible effect on long term equipment thermal aging. CEI programs assure that the qualified life of all equipment/components would not be exceeded. The results of the safety evaluations are detailed below.

A. Effect of Higher Initial Drywell Temperature on Drywell and Containment Responses

## 1. Peak Drywell and Containment Temperatures

Increasing the drywell average air temperature to 145°F would not challenge the design temperature of 330°F for the drywell during the period following a Loss-Of-Coolant Accident (LOCA). As identified in USAR Section 6.2.1.1.3.3.5.1, a small break LOCA (SBLCCA) would impose the most severe temperature conditions on the drywell structures and the safety equipment in the drywell, for the longest time period. The thermodynamic process associated with blowdown of primary system fluid is one of constant enthalpy. If the primary system rupture is so located that the blowdown flow consists only of reactor steam, the resultant steam temperature is significantly higher than the temperature associated with a liquid blowdown. This is because the constant enthalpy depressurization of high pressure, sa\*urated steam results in superheated conditions.

In the sarety analysis, the peak drywell temperature is assumed to be the same as the drywell design temperature; see USAR Table 6.2.-1. As noted in USAR Section 6.2.1.1.3.3.5.4, the design temperature for the drywell is determined by finding the combination of primary system pressure and drywell pressure that produces the maximum superheat temperature during a SBLOCA. The maximum drywell temperature occurs when the reactor steam has undergone a constant enthalpy depressurization to approximately 450 psig and the drywell pressure is at its maximum. For design purposes, it is assumed that the drywell is at 15 psig. This combination of pressures produces the maximum possible super-heated steam temperature of 330°F. Due to the theoretical and conservative nature of this calculation, this 330°F is independent of the initial drywell temperature condition.

Attachment 1 PY-CEI/NRR-0855 L Page 2 of 6

Peak containment temperatures are unchanged due to a 10°F drywell temperature increase. Peak containment temperature is controlled by suppression rool temperature. As noted in USAR Sections 6.2.1.1.3.3.5.2. 6.2.1.1.3.3.1.6 and 6.2.2.3.1, suppression pool temperature peaks when the RHR heat exchanger heat removal rate equals the decay heat release rate. The conservative analyses contained in the USAR (LOCA, LOOP, single diesel failure, minimum ECCS, only one RHR heat exchanger, RHR heat exchanger fully fouled, no heat losses other than through the RHR heat exchanger) show that peak suppression pool temperatures occur at about 6 hours post-LOCA, when this equilibrium is reached. The energy addition to the suppression pool from a 10°F drywell air temperature increase is negligible compared to the energy contributed from the LOCA blowdown and decay heat (see USAR Table 6.2-8). Also, the drywell air is carried over to the suppression pool early in the event, well before the RHR heat exchanger capability is challenged.

#### 2. Peak Drywell and Containment Pressures

·· · · ·

As described in USAR Section 6.2.1.1.3.3.5.2, for drywell design purposes, the small break LOCA results in a drywell pressure increase at a rate dependent upon the size of the steam leak. Following a reactor scram and containment isolation, the drywell pressure increase lowers the water level in the annulus until the level begins to clear the vents. At this time, air and water start to enter the suppression pool. The steam is condensed and the air carries over to the containment free space. The air carry-over results in a gradual pressurization of the containment at a rate dependent upon the size of the steam leak. Once all of the drywell air is carried over into the containment, short term containment pressurization ceases and the system reaches an equilibrium condition. The drywell contains only superheated steam and continued blowdown of reactor steam is condensed in the suppression pool.

If the drywell air temperature is raised from 135°F to 145°F, the resulting initial air density is lower. If a DBA-LOCA occurs, the peak drywell pressure would be lower than when the initial drywell temperature is 135°F. In the USAR, as described above, the drywell air is assumed to be swept into the containment during a DBA-LOCA. Thus the calculated peak drywell pressure currently in the USAR is actually independent of the initial drywell air temperature. Hotter initial drywell air also results in a lower air mass within the drywell. The USAR assumed that the initial drywell air is swept into the containment in a DBA-LOCA, and this lower drywell air mass would result in a reduction of the peak containment pressure of 11.31 psig.

Attachment 1 PY-CEI/NRR-0855 L Page 3 of 6

# B. Effect of Higher Initial Drywell Temperature on Structural Design and Analysis

· · · ·

The effects of increasing the average drywell temperature from 135°F to 145°F on Drywell Structural Design was evaluated. Structures including the drywell top slab; reinforced concrete cylinder; vent structure; steel platforms; supports for cable tray, conduit and ducts; biological shield wall; and the drywell liner were evaluated and all were found to be acceptable for the increased temperature. Hot fluid drywell penetrations were also evaluated to assure that the increase in drywell temperature would not cause any penetration to exceed ASME Division 2 allowable temperatures. The evaluations concluded that no penetrations exceeded the code allowables.

# C. Effect of Higher Initial Drywell Temperature on Equipment and Components

Equipment aging and operability assessments were conducted for equipment, components and piping which would be exposed to the higher drywell average air temperature. The results concluded that all the items would remain operable at 145°F and would perform their intended safety function. The only potential impact would be the accelerated aging of some equipment such as seals, solenoid valves and limit switches. This would result in the need to replace these components at an earlier date than presently scheduled by our Equipment Qualification program. CEI will continue to monitor the environmental temperatures through our Environmental Monitoring Program to ensure the timely replacement of these items prior to exceeding their new qualified life.

The EQ assessments conservatively assumed that the items under evaluation would remain at 145°F on a continuous basis year-round. Use of this assumption resulted in the shortest recommended maintenance interval for items inside the drywell being four years, which is substantially greater than one operating cycle. The majority of items remained qualified for the 40 year life of the plant. The items whose recommended maintenance intervals would change based on the 145°F assumption include solenoid coils for valve actuators (5 years to 4 years), an epoxy potting compound used for sealing of junction boxes (40 years to 23 years) and limit switch housing gaskets and o-rings (i2 years to 6 years).

As noted in A. above, the post-LOCA temperatures and pressures in drywell and containment are unchanged or reduced as a result of the initial drywell temperature increase. Therefore the original USAR analyses remain bounding, and the LOCA EQ profiles are still valid.

## D. Effect of Higher Initial Drywell Tempe ature on Pool Swell Loads

Initial drywell temperature is not significant with respect to hydrodynamic loads due to LOCA or SRV actuation. Reviews of loads including pool swell, vent flow, condensation oscillation, chugging and SRV loads, including safety relief valve discharge line reflood height, were performed. The reviews showed either no effect at all or only a negligible effect on any of these phenomena.

Attachment 1 PY-CEI/NRR-0855 L Page 4 of 6

Based on these evaluations, it is concluded that the higher drywell average air temperature will not adversely affect any design/operational considerations. Perry will continue to be in compliance with all General Design Criteria of ?C CFR Part 50, Appendix A.

Last summer (1987) was the first summer in which the Perry Nuclear Power Plant operated in Operational Condition 1. However, the plant was still in the Startup Test Program and did not have extended operation periods, nor extended periods of operating at high power levels during the summer months. In fact the plant was in a major maintenance outage from July 3, 1987 to August 21, 1987. Therefore, no problems with maintaining drywell average air temperatures below 135<sup>o</sup>F were experienced.

Although Perry has not yet experienced any derating of the plant because of drywell average air temperature, the plant is currently in a Technical Specification Action Statement which requires the reduction of average air temperature to 135°F "within 8 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours".

Although previous reviews of drywell heat load calculations with all plant systems operable at full power had identified the potential for difficulties in meeting the current Technical Specification limit, it was felt that special system lineups including the running of additional fans would allow the plant to operate during this current summer period. These contingency measures would result in higher in-plant use of generated power, but would allow for this Technical Specification change request to be processed on a normal time schedule. Recent events indicate that this is not sufficient. Lake temperatures have been rising more rapidly than normal this summer due to the elevated temperatures and lower lake levels during the drought. Higher lake water temperatures lead to decreased efficiency of the drywell air coolers, which act as heat exchangers inside the drywell. On the morning of July 9, 1988 temperatures of the water drawn from the lake increased significantly from 70°F to 75°F within several hours. By Sunday July 10 ct 1825 hours, intake water temperatures had reached 77°F and drywell average air temperature was over 134°F. Plant operators maximized cooling water flow to the drywell air coolers and aligned the drywell fans to the configuration that has resulted in the lowest temperatures. This configuration utilizes four fans rather than the three normally in use. Operators were able to reduce drywell temperatures below 133°F temporarily, but by Monday morning July 11, 1988 the temperature had returned to nearly 134°F. At 1652 on July 12, 1988 drywell average air temperatures could no longer be maintained below 135°F, and the Technical Specification 3.6.2.6 Action Statement was entered, which may require a plant shutdown within 20 hours if drywell temperatures cannot be reduced below 135°F by 0052 on July 13, 1988. This situation will only tend to be aggravated

Attachment 1 PY-CEI/NRR-0855 L Page 5 of 6

as the lake temperature continues to rise in August. Engineering design changes to reroute air supply ducts to the drywell have already been installed in the plant, during plant outages held last year. Also, extensive efforts have been put forth in recent outages to minimize valve packing steam leaks in order to maintain drywell temperature as low as possible. Since the requested change to allow 145°F drywell temperatures does not result in adverse safety consequences, approval of this Technical Specification change on an emergency basis is requested.

### Statement of Emergency Circumstances

. \*

CEI requires this amendment in order to continue full-power operation of Perry Unit 1. As discussed above, it was believed up until today that system operating configurations would allow the plant to continue to operate at least for the time period necessary to process a Technical Specification change request under the normal notice and comment process. Historical lake temperature maximums occur in the month of August. Engineering design changes and maintenance efforts to alleviate the temperature concerns have been actively pursued. All efforts to maintain and reduce temperature through maximizing system flow rates are being pursued, but these actions have not been effective in maintaining the drywell air temperature below the Technical Specification limit of 135°F. Unexpected lake temperature increases over the last several days have accelerated the time frame for the need of this amendment.

The plant is currently in the Action Statement for plant shutdown if the temperature in the drywell cannot be maintained below the 135°F Technical Specification limit. 10CFR50.91(a)(5) allows the Commission to grant an Emergency Technical Specification change under these conditions.

## Significant Hazards Consideration

The standards used to arrive at a determination that a request for amendment requires no significant hazards consideration are included in the Commission's Regulations, 10 CFR 50.92, which states that the operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated, (2) create the possibility of a new or different kind of accident from any accident previously evaluated, or (3) involve a significant reduction in a margin of safety. CEI has reviewed the proposed change with respect to these three factors.

 The proposed change to increase the drywell average air temperature to 145°F does not involve a significant increase in the probability or consequences of an accident previously evaluated. The change does not involve a physical modification to the plant or a change in operating practices. The change does involve a change in the limiting conditions for operation, and has been evaluated against environmental qualification requirements, drywell concrete design requirements, the balance of safety

Attachment 1 PY-CEI/NRR-0855 L Page 6 of 6

related mechanical and electrical equipment in the drywell and the bounding safety analysis accident (LOCA). Operation at the proposed higher temperature would potentially impact some equipment by accelerated aging. This would only result in the need to replace some components at an earlier date. Equipment and component operability, however, would not be affected and the intended safety function performance would not be degraded.

Thus, there is no significant increase in the probability or consequences of an accident previously evaluated.

The proposed change to increase the drywell average air temperature to 2. 145°F does not create the possibility of a new or different kind of accident from any accident previously evaluated. The proposed change will not impact plant performance and will not provide an opportunity for the plant to enter a condition not previously evaluated.

Thus, the change does not create the possibility of a new or different kind of accident from any accident previously evaluated.

The proposed change to increase the drywell average air temperature to 3. 145°F does not involve a significant reduction in a margin of safety. By increasing the drywell average air temperature for normal operations, there is no significant impact on the hydrodynamic loads or the containment response during a LOCA. The analysis indicates that the peak drywell pressure and peak containment pressure actually decrease with the increase in drywell temperature. The margin of safety is maintained with the increase in drywell average air temperature. Our analysis also indicates that the increase in average drywell temperature to 145°F will not cause any drywell structural components to exceed ASME code allowables, and that drywell equipment operability would not be detrimentally affected by the proposed increase in drywell temperature.

Thus, the change does not involve a significant reduction in a margin of safety.

#### Environmental Impact

The Cleveland Electric Illuminating Company (CEI) has reviewed the proposed Technical Specification change against the criteria of 10 CFR 50.22 for environmental considerations. As shown above, the proposed change does not involve a significant hazards consideration, nor increase the types and amounts of effluents that may be released offsite, nor significantly increase individual or cumulative occupational radiation exposures. Based on the foregoing, CEI concludes that the proposed Technical Specification change meets the criteria given in 10 CFR 51.22(c)(9) for a categorical exclusion from the requirement for an Environmental Impact Statement.

5.00