



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

NORTHEAST NUCLEAR ENERGY COMPANY
THE CONNECTICUT LIGHT AND POWER COMPANY
THE WESTERN MASSACHUSETTS ELECTRIC COMPANY
DOCKET NO. 50-336
MILLSTONE NUCLEAR POWER STATION, UNIT NO. 2
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 128
License No. DPR-65

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Northeast Nuclear Energy Company, et al. (the licensee), dated May 26, 1986, as supplemented by letter dated August 11, 1987, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-65 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No.128 , are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John F. Stolz, Director
Project Directorate 7-4
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: March 31, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 128

FACILITY OPERATING LICENSE NO. DPR-65

DOCKET NO. 50-336

Replace the following page of the Appendix A Technical Specifications with the enclosed page. The revised page is identified by amendment number and contains vertical lines indicating the areas of change.

Remove

3/4 9-27

Insert

3/4 9-27

REFUELING OPERATIONS

SPENT FUEL POOL

LIMITING CONDITION FOR OPERATION

3.9.20 Prior to consolidation of spent fuel assemblies, the candidate fuel assemblies must have decayed for at least 5 years.

APPLICABILITY: During all consolidation operations.

ACTION:

With the requirements of the above specification not satisfied, replace candidate assembly with an appropriate substitute or suspend all consolidation activities.

SURVEILLANCE REQUIREMENTS

4.9.20 The decay time of all candidate fuel assemblies for consolidation shall be determined to be greater than or equal to five years within 7 days prior to moving the fuel assembly into the consolidation work station.