Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690 - 0767

July 7, 1988

Mr. Thomas E. Murley, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: Quad Cities Station Unit 2
"Application for Amendment to Facility Operating License DPR-30, Appendix A Technical Specifications"
NRC Docket No. 50-265

Reference (a): Letter from I.M. Johnson to T.E. Murley dated June 20, 1988

Dear Mr. Murley:

Pursuant to 10 CFR 50.90, Commonwealth Edison proposes to amend Appendix A, Technical Specifications to Facility Operating License DPR-30. In Reference (a), Commonwealth Edison informed you of a Detailed Control Room Design Review (DCRDR) Human Factors modification which affected the Quad Cities Station Unit 2 Technical Specifications. As part of the Unit 2 Spring 1988 Refueling Outage, the drywell temperature indicator was relocated. It was indicated in Reference (a), that a Technical Specification correcting the instrument location would be submitted by July 15, 1988. This proposed amendment is being submitted in response to that commitment. Additionally, this amendment includes corrections to panel numbers for instrument readout locations. The changes are listed in Attachment 1 and further described in Attachment 2.

The proposed changes have been reviewed and approved by both On-Site and Off-Site review in accordance with Commonwealth Edison Company procedures. We have reviewed these proposed amendments in accordance with 10 CFR 50.92(c) and determined that no significant hazards consideration exist. This evaluation is documented in Attachment 3.

Commonwealth Edison is notifying the State of Illinois of our application for this amendment by transmitting a copy of this letter and its attachment to the designated State Official.

A001
1/1
w/check $150
#0034629

8807210087 880707
PDR ADOCK 05000265
P PDC

In accordance with 10 CFR 170, a fee remittance in the amount of $150.00 is also enclosed.

Please direct any questions you may have regarding this matter to this office.

Very truly yours,

Irene M. Johnson

I. M. Johnson
Nuclear Licensing Administrator

lm

Attachments 1: Proposed Change to Appendix A Technical Specification for Quad Cities Station Unit 2 Facility Operating License, DPR-30
2: Summary of Changes
3: Evaluation of Significant Hazards Consideration

cc: NRC Resident Inspector - Quad Cities
M. C. Parker - IDNS
T. Ross - NRR

SUBSCRIBED AND SWORN to
before me this 7th day
of July, 1988

Julia A. Mayo
Notary Public

4886K