

APR 04 1988

Docket Nos. 50-277  
50-278

Philadelphia Electric Company  
ATTN: Mr. J. S. Kemper, Sr.  
Vice President - Nuclear  
2301 Market Street  
Philadelphia, Pennsylvania 19101

Gentlemen:

Subject: Combined Inspection Report Nos. 50-277/88-07 and 50-278/88-07

A routine radiation safety inspection was conducted on February 16-19, 1988 at the Peach Bottom Station by Messrs T. Dragoun and W. Thomas of this office. The program areas reviewed included followup of a worker allegation, staff training in radiation protection, calibration and maintenance of radiation detection instrumentation, processing of radiological workers termination reports, and the status of the recirculation pipe replacement project.

One licensee identified violation regarding lack of a procedure for calibration and source checking of portal monitors was observed. Due to the licensee's immediate corrective action and in accordance with 10 CFR 2, Appendix C, this violation will not be cited.

No reply to this letter is required. Your cooperation with us is appreciated.

Sincerely,

Original Signed By:  
Ronald R. Bellamy

Ronald R. Bellamy, Chief  
Facilities Radiological Safety and  
Safeguards Branch  
Division of Radiation Safety  
and Safeguards

Enclosure:

Combined Inspection Report Nos. 50-277/88-07 and 50-278/88-07

"OFFICIAL RECORD COPY"

8804120049 880404  
PDR ADOCK 05000277  
Q DCD

IE 06

APR 04 1988

cc w/encl:

E. C. Kistner, Chairman, Nuclear Review Board  
Dickinson M. Smith, Vice President, Peach Bottom Atomic Power Station  
Jack Urban, General Manager, Fuels Department, Delmarva Power & Light Co.  
John F. Franz, Plant Manager, Peach Bottom Atomic Power Station  
Troy B. Conner, Jr., Esquire (Without Report)  
W. H. Hirst, Director, Joint Generation Projects Department, Atlantic Electric  
Eugene J. Bradley, Esquire, Assistant General Counsel (Without Report)  
Raymond L. Hovis, Esquire (Without Report)  
Thomas Magette, Power Plant Siting, Nuclear Evaluations  
W. M. Alden, Director, Licensing Section  
J. W. Gallagher, Vice President, Nuclear Services  
Doris Poulsen, Secretary of Harford County Council  
Public Document Room (PDR)  
Local Public Document Room (LPDR)  
Nuclear Safety Information Center (NSIC)  
NRC Resident Inspector  
Commonwealth of Pennsylvania

APR 04 1988

bcc w/encl:  
Region I Docket Room (with concurrences)  
Management Assistant, DRMA (w/o encl)  
DRP Section Chief  
Robert J. Bores, DRSS

RI:DRSS *[Signature]*  
for Dragoun/gcb/slj  
3/30/88

RI:DRSS *[Signature]*  
Thomas  
3/30/88

RI:DRSS *[Signature]*  
Shanbaky  
3/31/88

*useellamy*  
RI:DRSS  
Bellamy  
4/4/88