

TABLE 3.3.2-1 (Continued)
ISOLATION ACTUATION INSTRUMENTATION

ACTION

- ACTION 20 - Be in at least HOT SHUTDOWN within 6 hours and in COLD SHUTDOWN within the next 30 hours.
- ACTION 21 - Be in at least STARTUP with the main steam line isolation valves closed within 2 hours or be in at least HOT SHUTDOWN within 6 hours and in COLD SHUTDOWN within the next 30 hours.
- ACTION 22 - Be in at least STARTUP within 2 hours.
- ACTION 23 - Be in at least STARTUP with the Group 1 isolation valves closed within 2 hours or in at least HOT SHUTDOWN within 6 hours.
- ACTION 24 - Establish SECONDARY CONTAINMENT INTEGRITY with the standby gas treatment system operating within one hour.
- ACTION 25 - Isolate the reactor water cleanup system.
- ACTION 26 - Close the affected system isolation valves and declare the affected system inoperable.
- ACTION 27 - Verify power availability to the bus at least once per 12 hours or close the affected system isolation valves and declare the affected system inoperable.
- ACTION 28 - Close the shutdown cooling supply and reactor vessel head spray isolation valves unless reactor steam dome pressure is 145 psig.
- ACTION 29 - Either close the affected isolation valves within 24 hours or be in HOT SHUTDOWN within the next 6 hours and in COLD SHUTDOWN within the next 30 hours.

NOTES

- * Actuates the standby gas treatment system.
- ** When handling irradiated fuel in the secondary containment.
- *** When performing inservice hydrostatic or leak testing with the reactor coolant temperature above 212° F.
- a. See Specification 3.6.3, Table 3.6.3-1 for valves in each valve group.
- b. A channel may be placed in an inoperable status for up to 2 hours for required surveillance without placing the trip system in the tripped condition provided at least one other OPERABLE channel in the same trip system is monitoring that parameter.
- c. With a design providing only one channel per trip system, an inoperable channel need not be placed in the tripped condition where this would cause the Trip Function to occur. In these cases, the inoperable channel shall be restored to OPERABLE status within 2 hours or the ACTION required by Table 3.3.2-1 for that Trip Function shall be taken.
- d. Trips the mechanical vacuum pumps.
- e. A channel is OPERABLE if 2 of 4 instruments in that channel are OPERABLE.
- f. May be bypassed with all turbine stop valves closed.
- g. Closes only RWCU outlet isolation valve 2G31-F004.
- h. Alarm only.
- i. Adjustable up to 60 minutes.
- j. Isolates containment purge and vent valves.
- k. Within 24 hours prior to the planned start of the hydrogen injection test with the reactor power at greater than 20% rated power, the normal full-power radiation background level and associated trip setpoints may be changed based on a calculated value of the radiation level expected during the test. The background radiation level and associated trip setpoints may be adjusted during the test based on either calculations or measurements of actual radiation levels resulting from hydrogen injection. The background radiation level shall be determined and associated trip setpoints shall be set within 24 hours of re-establishing normal radiation levels after completion of hydrogen injection and prior to establishing reactor power levels below 20% rated power.

8804130304 880407
PDR ADDOCK 05000366 PDR
P