



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

THE CLEVELAND ELECTRIC ILLUMINATING COMPANY, ET AL.

DOCKET NO. 50-440

PERRY NUCLEAR POWER PLANT, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 14
License No. NPF-58


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by The Cleveland Electric Illuminating Company, Duquesne Light Company, Ohio Edison Company, Pennsylvania Power Company, and Toledo Edison Company (the licensees) dated July 12, 1988 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-58 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 14 are hereby incorporated into this license. The Cleveland Electric Illuminating Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment was effective on July 12, 1988.

FOR THE NUCLEAR REGULATORY COMMISSION



Gary M. Holahan, Assistant Director
Region III and V Reactors
Division of Reactor Projects - III,
IV, V and Special Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: July 14, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 14

FACILITY OPERATING LICENSE NO. NPF-58

DOCKET NO. 50-440

Replace the following pages of the Appendix "A" Technical Specifications with the attached pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change. Overleaf pages are provided to maintain document completeness.

Remove

3/4 6-21
B 3/4 6-4

Insert

3/4 6-21
B 3/4 6-4

CONTAINMENT SYSTEMS

DRYWELL AVERAGE AIR TEMPERATURE

LIMITING CONDITION FOR OPERATION

3.6.2.6 Drywell average air temperature shall not exceed 145°F.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2 and 3.

ACTION:

With the drywell average air temperature greater than 145°F, reduce the average air temperature to within the limit within 8 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

SURVEILLANCE REQUIREMENTS

4.6.2.6 The drywell average air temperature shall be the arithmetical average* of the temperatures at the following elevations# and shall be determined to be within the limit at least once per 24 hours:

	<u>Elevation</u>	<u>Azimuth</u>
a.	653'-8"	315°, 220°, 135°, 34°
b.	634'-0" - 640'-0"	340°, 308°, 215°, 145°, 30°, 20°
c.	604'-6" - 609'-8"	310°, 308°, 253°, 212°, 150°, 140°, 80°

*At least one reading from each elevation for an arithmetical average.

#The temperature at each elevation shall be the arithmetical average of the temperatures obtained from all available instruments at that elevation.

CONTAINMENT SYSTEMS

3/4.6.3 DEPRESSURIZATION SYSTEMS

SUPPRESSION POOL

LIMITING CONDITION FOR OPERATION

3.6.3.1 The suppression pool shall be OPERABLE with the pool water:

- a. Volume between 115,612 ft³ and 118,548 ft³ equivalent to a level between 18'0" and 18'6", and a
- b. Maximum average temperature of 90°F except that the maximum average temperature may be permitted to increase to:
 1. 105°F during testing which adds heat to the suppression pool.
 2. 110°F with THERMAL POWER less than or equal to 1% of RATED THERMAL POWER.
 3. 120°F with the main steam line isolation valves closed following a scram.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2 and 3.

ACTION:

- a. With the suppression pool water level outside the above limits, restore the water level to within the limits within 1 hour or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- b. With the suppression pool average water temperature greater than 90°F, restore the average temperature to less than or equal to 90°F within 24 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours, except, as permitted above:
 1. With the suppression pool average water temperature greater than 105°F during testing which adds heat to the suppression pool, stop all testing which adds heat to the suppression pool and restore the average temperature to less than 90°F within 24 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
 2. With the suppression pool average water temperature greater than:
 - a) 90°F for more than 24 hours and THERMAL POWER greater than 1% of RATED THERMAL POWER, be in at least HOT SHUTDOWN within 12 hours and in COLD SHUTDOWN within the next 24 hours.
 - b) 110°F, place the reactor mode switch in the Shutdown position and operate at least one residual heat removal loop in the suppression pool cooling mode.

CONTAINMENT SYSTEMS

BASES

DRYWELL AND CONTAINMENT PURGE SYSTEM (Continued)

Leakage integrity tests with a maximum allowable leakage rate for purge supply and exhaust isolation valves will provide early indication of resilient material seal degradation and will allow the opportunity for repair before gross leakage failure develops. The 0.60 L_a leakage limit shall not be exceeded when the leakage rates determined by the leakage integrity tests of these valves are added to the previously determined total for all valves and penetrations subject to Type B and C tests.

3/4.6.1.9 FEEDWATER LEAKAGE CONTROL SYSTEM

The OPERABILITY of the feedwater leakage control system is required to meet the restrictions on overall containment leak rate assumed in the accident analyses.

3/4.6.2 DRYWELL

3/4.6.2.1 DRYWELL INTEGRITY

Drywell integrity ensures that the steam released for the full spectrum of drywell pipe breaks is condensed inside the primary containment either by the suppression pool or by containment spray. By utilizing the suppression pool as a heat sink, energy released to the containment is minimized and the severity of the transient is reduced.

3/4.6.2.2 DRYWELL BYPASS LEAKAGE

The limitation on drywell bypass leakage rate is based on having containment spray OPERABLE. It ensures that the maximum leakage which could bypass the suppression pool during an accident would not result in the containment exceeding its design pressure of 15.0 psig. The integrated drywell leakage value is limited to 10% of the design drywell leakage rate.

The limiting case accident is a very small reactor coolant system break which will not automatically result in a reactor depressurization. The long term differential pressure created between the drywell and containment will result in a significant pressure buildup in the containment due to this bypass leakage.

3/4.6.2.3 DRYWELL AIR LOCK

The limitations on closure for the drywell air lock is required to meet the restrictions on DRYWELL INTEGRITY and the drywell leakage rate given in Specifications 3.6.2.1 and 3.6.2.2. The specification makes allowances for the fact that there may be long periods of time when the air lock will be in a closed and secured position during reactor operation. Only one closed door in the air lock is required to maintain the integrity of the drywell.

The air supply to the drywell air lock and seal system is the service and instrument air system. This system consists of two 100% capacity air compressors per unit and can be cross-connected. This system is redundant and extremely reliable and provides system pressure indication in the control room.

CONTAINMENT SYSTEMS

BASES

3/4.6.2.4 DRYWELL STRUCTURAL INTEGRITY

This limitation ensures that the structural integrity of the drywell will be maintained comparable to the original design specification for the life of the unit. A visual inspection in conjunction with Type A leakage tests is sufficient to demonstrate this capability.

3/4.6.2.5 DRYWELL INTERNAL PRESSURE

The limitations on drywell-to-containment differential pressure ensure that the drywell peak calculated pressure of 21.8 psig does not exceed the design pressure of 30.0 psig and that the containment peak pressure of 11.31 psig does not exceed the design pressure of 15.0 psig during LOCA conditions. The maximum external drywell pressure differential is limited to +0.5 psid, well below the 2.4 psid at which suppression pool water will be forced over the weir wall and into the drywell. The limit of 2.0 psid for initial positive drywell to containment pressure will limit the drywell pressure to 21.8 psig which is less than the design pressure and is consistent with the safety analysis.

3/4.6.2.6 DRYWELL AVERAGE AIR TEMPERATURE

The drywell average temperature is an input parameter to the containment/drywell response analyses as the result of a DBA-LOCA. Furthermore, the drywell average temperature is important in drywell equipment qualification considerations.

3/4.6.3 DEPRESSURIZATION SYSTEMS

The specifications of this section ensure that the drywell and containment pressure will not exceed the design pressure of 30 psig and 15 psig, respectively, during primary system blowdown from full operating pressure.

The suppression pool water volume must absorb the associated decay and structural sensible heat released during a reactor blowdown from 1045 psig. Using conservative parameter inputs, the maximum calculated containment pressure during and following a design basis accident is below the containment design pressure of 15 psig. Similarly the drywell pressure remains below the design pressure of 30 psig. The maximum and minimum water volumes for the suppression pool are 118,548 cubic feet and 115,612 cubic feet, respectively. These values include the water volume of the containment pool, horizontal vents, and weir annulus. Testing in the Mark III Pressure Suppression Test Facility and analysis have assured that the suppression pool temperature will not rise above 185°F for the full range of break sizes.

Should it be necessary to make the suppression pool inoperable, this shall only be done as specified in Specification 3.5.3.

Experimental data indicates that effective steam condensation without excessive load on the containment pool walls will occur with a quencher device and pool temperature below 200°F during relief valve operation. Specifications have been placed on the envelope of reactor operating conditions to assure the bulk pool temperature does not rise above 185°F in compliance with the containment structural design criteria.