

JUL 11 1988

Docket No: 50-193

Rhode Island Atomic Energy Commission
ATTN: Mr. A. Francis DiMeglio, Director
Nuclear Science Center
South Ferry Road
Narragansett, Rhode Island 02882

Gentlemen:

Subject: Inspection Report No. 50-193/88-01

This refers to your letter dated May 19, 1988, in response to our letter dated May 11, 1988.

Thank you for informing us of the corrective and preventive actions documented in your letter. These actions will be examined during a future inspection of your licensed program.

Sincerely,

Original Signed By:
Lee H. Bettenhausen

Lee H. Bettenhausen, Chief
Projects Branch No. 1
Division of Reactor Projects

cc:
Professor George Seidel, Chairman, RIAEC
Dr. Stephen Mecca, Commissioner, RIAEC
John S. Pascalides, Commissioner, RIAEC
Dr. Vincent C. Rose, Commissioner, RIAEC
Dr. Stanley J. Pickart, Physics Department
Public Document Room (PDR) (w/cy of May 19, 1988 Response Letter)
Local Public Document Room (LPDR) (w/cy of May 19, 1988 Response Letter)
Nuclear Safety Information Center (NSIC) (w/cy of May 19, 1988 Response Letter)
State of Rhode Island (w/cy of May 19, 1988 Response Letter)

8807250363 880711
PDR ADOCK 05000193
G PNU

OFFICIAL RECORD COPY

DL50-193/88-01REPLY - 0001.0.0
07/07/88

IEO1/11

JUL 11 1988

bcc w/cy of May 19, 1988 Response Letter:
Region I Docket Room (with concurrences)
Management Assistant, DRMA (w/o encl)
Robert J. Bores, DRSS
E. McCabe, Chief, RPS 3B, DRP
J. Shedlosky, SRI (Millstone 3), DRP
E. Conner, Project Inspector, DRP

RI:DRP
820
Conner/meo
7/7/88

RI:DRP
7/11/88
McCabe
7/11/88

RI:DRP
7/11/88
Bettenhausen
7/11/88

OFFICIAL RECORD COPY

DL50-193/88-01REPLY - 0002.0.0
07/07/88



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Rhode Island Atomic Energy Commission
 NUCLEAR SCIENCE CENTER
 South Ferry Road
 Narragansett, R.I. 02882-1197

May 19, 1988

Lee H. Bettenhausen, Chief
 Projects Branch No. 1
 Division of Reactor Projects
 U. S. Nuclear Regulatory Commission
 475 Allendale Road
 King of Prussia, PA 19406

License R-95
 Docket 50-193

Dear Mr. Bettenhausen:

This letter is transmitted in response to the notice of violation contained in inspection report 50-193/88-01 dated May 11, 1988 concerning the failure to calculate quarterly the fission density of all fuel elements which have burnup. The notice was received on May 17, 1988.

At the beginning of the two periods listed in the notice, predictive calculations were made based on our standard operating schedule to show that no fuel elements would reach the fission density limit during the time period. Unfortunately these predictions were not documented and therefore not available for inspection.

Full compliance with the technical specifications was achieved with the calculations performed February 1988 and calculations performed on April 28, 1988.

To avoid further violations, calculations will be performed at least quarterly as required by the technical specifications.

Very truly yours,

A. Francis DiMeglio

A. Francis DiMeglio
 Director

AFD:cd

cc: Rhode Island Atomic Energy Commission
 Reactor Utilization Committee

8806140011