

3/4.5 EMERGENCY CORE COOLING SYSTEMS

3/4.5.1 ACCUMULATORS

LIMITING CONDITION FOR OPERATION

3.5.1 Each Reactor Coolant System accumulator shall be OPERABLE with:

- a. The isolation valve open and power removed,
- b. A contained borated water volume of between 6061 and 6655 gallons,
- c. A boron concentration of between 1900 and 2100 ppm, and
- d. A nitrogen cover-pressure of between 602 and 643 psig.

APPLICABILITY: MODES 1, 2, and 3*.

ACTION:

- a. With one accumulator inoperable, except as a result of a closed isolation valve, restore the inoperable accumulator to OPERABLE status within 1 hour or be in at least HOT STANDBY within the next 6 hours and ~~in HOT SHUTDOWN~~ within the following 6 hours.
- b. With one accumulator inoperable due to the isolation valve being closed, ^{reduce RCS pressure to less than 1000 psig} either immediately open the isolation valve or be in at least HOT STANDBY within 6 hours and ~~in HOT SHUTDOWN~~ within the following 6 hours.

SURVEILLANCE REQUIREMENTS

4.5.1.1 Each accumulator shall be demonstrated OPERABLE:

- a. At least once per 12 hours by:
 - 1) Verifying, by the absence of alarms, the contained borated water volume and nitrogen cover-pressure in the tanks, and
 - 2) Verifying that each accumulator isolation valve is open.

one accumulator isolation valve may be closed for up to 2 hours in mode 3*, for surveillance testing per 4.0.5 or 4.4.6.2.2.

*pressurizer pressure above 1000 psig.

In order to perform check valve surveillance testing per 4.0.5 or 4.4.6.2.2 above 1000 psig RCS pressure, one accumulator isolation valve may be closed for up to 2 hours in mode 3 only.

REVISION 1

3/4.5 EMERGENCY CORE COOLING SYSTEMS

BASES

3/4.5.1 ACCUMULATORS

The OPERABILITY of each Reactor Coolant System (RCS) accumulator ensures that a sufficient volume of borated water will be immediately forced into the core through each of the cold legs in the event the RCS pressure falls below the pressure of the accumulators. This initial surge of water into the core provides the initial cooling mechanism during large RCS pipe ruptures.

The limits on accumulator volume, boron concentration and pressure ensure that the assumptions used for accumulator injection in the safety analysis are met.

The accumulator power operated isolation valves are considered to be "operating bypasses" in the context of IEEE Std. 279-1971, which requires that bypasses of a protective function be removed automatically whenever permissive conditions are not met. In addition, as these accumulator isolation valves fail to meet single failure criteria, removal of power to the valves is required.

The limits for operation with an accumulator inoperable for any reason except an isolation valve closed minimizes the time exposure of the plant to a LOCA event occurring concurrent with failure of an additional accumulator which may result in unacceptable peak cladding temperatures. If a closed isolation valve cannot be immediately opened, the full capability of one accumulator is not available and prompt action is required to place the reactor in a MODE where this capability is not required. ←

The requirement to verify accumulator isolation valves shut with power removed from the valve operator when the pressurizer is solid ensures the accumulators will not inject water and cause a pressure transient when the Reactor Coolant System is on solid plant pressure control.

3/4.5.2, 3/4.5.3, and 3/4.5.4 ECCS SUBSYSTEMS

The OPERABILITY of two independent ECCS subsystems ensures that sufficient emergency core cooling capability will be available in the event of a LOCA assuming the loss of one subsystem through any single failure consideration. Either subsystem operating in conjunction with the accumulators is capable of supplying sufficient core cooling to limit the peak cladding temperatures within acceptable limits for all postulated break sizes ranging from the double ended break of the largest RCS cold leg pipe downward. In addition, each ECCS subsystem provides long-term core cooling capability in the recirculation mode during the accident recovery period.

With the RCS temperature below 350°F, one OPERABLE ECCS subsystem is acceptable without single failure consideration on the basis of the stable reactivity condition of the reactor and the limited core cooling requirements.