

Georgia Power Company
Post Office Box 282
Waynesboro, Georgia 30830
Telephone 404 554-9961 Extension 3413
404 724-8114 Extension 3413

Reissue: Date omitted.



Georgia Power

the southern electric system

P. D. Rice
Vice President
Vogtle Project

July 19, 1988

United States Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

File: X7BF10
Log: GN-1474

Reference: Vogtle Electric Generating Plant - Unit 2
USNRC Inspection Report 50-425/88-28

The Georgia Power Company wishes to submit the following information concerning the violation identified in the referenced inspection report.

Violation 50-425/88-28-01, "Failure to utilize certified Field Level III Inspectors as committed per ANSI N45.2.6-1978."

The Georgia Power Company (GPC) acknowledges the violation as identified in the USNRC report. GPC Construction utilizes Level III Administrators for the purpose of coordinating and evaluating the orientation, training and certification of inspection personnel. Misinterpretation of ANSI N45.2.6 was the root cause of this violation since the Level III Administrator does not record, implement, plan or evaluate inspection, examination and testing activities.

To prevent further recurrence, Section 1.9.58 of the FSAR shall be amended to include the GPC Level III Administrator and specify his function. Full compliance shall be achieved on or before October 31, 1988.

P. D. Rice

PDR/sem

xc: USNRC - Region II
Suite 2900
101 Marietta Street, N. W.
Atlanta, GA 30323

H. G. Baker, Jr.	D. R. Altman	J. P. Kane
R. P. McDonald	J. A. Bailey	C. W. Hayes
R. H. Pinson	G. Bockhold, Jr.	R. W. McManus
E. D. Groover	G. R. Frederick	Sr. Resident (NRC)
C. T. Moore	J. E. Swartzwelder	D. H. Smith (OPC)
R. A. Thomas	A. B. Gallant	J. E. Joiner
		NORMS

8807280365 880719
PDR ADOCK 05000425
Q PNU

1204
11