



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

July 22, 1988

Docket Nos. 50-369
and 50-370

MEMORANDUM FOR: Sholly Coordinator

FROM: Darl S. Hood, Project Manager
Project Directorate II-3
Division of Reactor Projects-I/II

SUBJECT: REQUEST FOR PUBLICATION IN MONTHLY FR NOTICE - NOTICE OF
ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE AND
FINAL DETERMINATION OF NO SIGNIFICANT HAZARDS CONSIDERATION
AND OPPORTUNITY FOR HEARING (EXIGENT OR EMERGENCY CIRCUMSTANCES)
(TACS 68727/68728)

Duke Power Company, Docket Nos. 50-369 and 50-370, McGuire Nuclear Station,
Units 1 and 2, Mecklenburg County, North Carolina

Date of application for amendments: July 15 and 19, 1988, as supplemented
July 21, 1988

Brief description of amendments: The amendments corrected Technical Specification
4.8.1.1.2.e.6(c) to recognize that four, rather than three, diesel generator
trips are not automatically bypassed during tests simulating a loss-of-offsite
power in conjunction with an engineered safety features actuation test signal.

Date of issuance: July 22, 1988

Effective date: July 15, 1988

Amendment Nos.: 90 and 71

Facility Operating License Nos. NPF-9 and NPF-17: Amendments revised the
Technical Specifications.

Public comments requested as to proposed no significant hazards consideration: No
The Commission's related evaluation is contained in a Safety Evaluation dated
July 22, 1988.

8808010071 880722
FDR ADOCK 05000369
PDC

Attorney for licensee: Mr. Albert Carr, Duke Power Company, 422 South Church Street, Charlotte, North Carolina 28242

Local Public Document Room location: Atkins Library, University of North Carolina, Charlotte (UNCC Station), North Carolina 28223

NRC Project Director: David B. Matthews

Original signed by:

Darl S. Hood, Project Manager
Project Directorate II-3
Division of Reactor Projects-I/II

DISTRIBUTION:

- Docket File
- PDII-3 R/F
- McGuire R/F
- MRood
- DMatthews
- OGC
- DHood

LA:PDII-3
MRood
7/22/88

DJA
PM:PDII-3
DHood:pw
7/22/88

DM
O:PDII-3
DMatthews
7/22/88