



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DEC 31 1981

Docket nos.: 50-315
50-316

MEMORANDUM FOR: Thomas Novak, Assistant Director
for Operating Reactors
Division of Licensing


FROM: William V. Johnston, Assistant Director
for Materials & Qualifications Engineering
Division of Engineering

SUBJECT: FIRE PROTECTION STATUS - D.C. COOK UNITS 1 & 2 (TAC#47036/47037)

Facility: Donald C. Cook Nuclear Plant Unit Nos. 1 & 2
Licensee: Indiana & Michigan Electric Company
Docket Nos: 50-315/316
Responsible Branch: CRB #1
Project Manager: Sydney Miner
Reviewing Branch: Chemical Engineering Branch
Reviewer: R. Anand
Status: Complete

On February 17, 1981, the fire protection rule for operating nuclear power plants, 10 CFR 50.48 and Appendix R to 10 CFR Part 50 became effective. By letter dated March 27, 1981, the licensee stated that D.C. Cook Plant Units 1 and 2 meet the requirements of sections III.G, III.J and III.O of Appendix R to 10 CFR Part 50. Therefore, no technical exemptions were requested nor were any modifications proposed to meet the requirement of III.G-3 which specifies alternative or dedicated shutdown capability if other requirements of III.G are not met. Therefore, DSI/ASB does not have this plant under review.

The CMEB review of the fire protection program is complete.


William V. Johnston, Assistant Director
for Materials & Qualifications Engineering
Division of Engineering

cc: R. Vollmer R. Ferguson
D. Eisenhut S. Varga
R. Tedesco V. Panciera
V. Benaroya S. Minor
T. Wambach T. Sullivan
O. Parr R. Anand

82φ125φ127 XAT

P/11