


U.S. Nuclear Regulatory Commission
3F0897-01
Enclosure 1

ATTACHMENT C

**FLORIDA POWER CORPORATION
CRYSTAL RIVER UNIT 3
DOCKET NUMBER 50-302/LICENSE NUMBER DPR-72**

FPC CALCULATION S94-0011

UNRESOLVED SAFETY ISSUED A-46



**Florida
Power**
CORPORATION

INTEROFFICE CORRESPONDENCE

Nuclear Engineering
OFFICE

C21
MAC

5882
PHONE

SUBJECT: Crystal River Unit No. 3
Quality Document Transmittal - Analysis/Calculations
File: CALC

TO: Records Management - NR2A

The following analysis/calculation package is submitted as the QA Record copy:

DOCNO (FPC DOCUMENT IDENTIFICATION NUMBER) S-94-0011	REV 0	SYSTEM(S) CD, EF DH, CA	TOTAL PAGES TRANSMITTED 126
TITLE SEISMIC VERIFICATION OF TANKS - SQUG METHODOLOGY			

KWDS (IDENTIFY KEYWORDS FOR LATER RETRIEVAL)

TANK, SQUG, SEISMIC

DXREF (REFERENCES OR FILES - LIST PRIMARY FILE FIRST)

SP-B3-033

VEND (VENDOR NAME) G/CI	VENDOR DOCUMENT NUMBER (DXREF) DC-5520-161.0 SE	SUPERSEDED DOCUMENTS (DXREF) NA
TAG		
CDT-1	CAT-5B	
EFT-2		
DHT-1		
CAT-5A		
PART NO.		
COMMENTS (USAGE RESTRICTIONS, PROPRIETARY, ETC.)		

NOTE:

Use Tag number only for valid tag numbers (i.e., RCV-8, SWV-34, DCH-99), otherwise; use Part number field (i.e., CSC1453, CSC1459). If more space is required, write "See Attachment" and list on separate sheet.

DESIGN ENGINEER <i>C. Glenn</i>	DATE 2/11/94	VERIFICATION ENGINEER N/A	DATE	SUPERVISOR, NUCLEAR ENG. <i>Barry</i>	DATE 2/14/94
------------------------------------	------------------------	-------------------------------------	------	--	------------------------

cc: MAR O' (If MAR Related) ☐ Yes ☒ No

MAR/F: ect File

Mgr. Nuci. Config. Mgt.

File (C.S.C.) - FPES - "Original" w/attach

Mgr., S. Nuci. Eng. Serv. w/attach

GLENN PUGH w/ATTACH.


Supervisor, Nuclear Document Control w/Plant Doc. Rev.

Eval. and Analysis 'Calc. Summary

Plant Document Review Required ☐ Yes ☒ No

A/E ☐ Yes ☒ No

(If Yes, Transmit w/attach)



PLANT DOCUMENT REVIEW EVALUATION

DOCUMENT TYPE / NUMBER TO BE EVALUATED

5-94-0011

PART I

INSTRUCTIONS: Calculations, Document Change Notices, and Plant Equipment Equivalency Replacements have the potential to affect plant documents. The Originator of any of these documents is required to determine which, if any, plant organizations should review the subject document for impact. The Originator should use the best judgment to make this determination based on the nature of the changes. If in doubt as to whether or not a plant organization should review a particular document, it is suggested that the subject organization be contacted.

The Originator is to check the appropriate boxes below and attach to the subject package as follows:

Calculations - Insert behind Analysis/Calculation Transmittal
DCNs - Insert behind DCN page 1
PEEREs - Insert behind PEERE page 2
CIDPs - Insert behind CIDP page 1

The above referenced document must be distributed as follows:

- | | |
|---|---|
| <input checked="" type="checkbox"/> No Review Required | <input type="checkbox"/> Supervisor, Operations Engineering & Support |
| <input type="checkbox"/> Senior Radiation Protection Engineer | <input type="checkbox"/> Manager, Nuclear Maintenance |
| <input type="checkbox"/> Manager, Site Nuclear Services | <input type="checkbox"/> Manager, Nuclear Plant Technical Support |
| | <input type="checkbox"/> Other(s): |

ORIGINATOR / DATE

C. Blum

2/11/94

SUPERVISOR / DATE

Don Smith

2/14/94

Upon completion of **Part I**, attach to the subject document, check "Plant Document Review Required" block, as applicable, and give to Nuclear Engineering Clerk for distribution.

CIDPs - Distribute with Attachments

Calcs - Distribute with Transmittal Memo, Summary - PEERE - Distribute with Attachments - DCNs - Distribute with Attachments and Drawings

PART II

INSTRUCTIONS: Upon receipt of the subject document, the assigned Reviewer enters the "Reviewing Department" name below, reviews the subject document for impact on plant procedures, and completes the evaluation below.

REVIEWING DEPARTMENT

PLANT REVIEW IMPACT EVALUATION: The above referenced document has been reviewed and evaluated as follows:

- ☐ No Action Required
- ☐ Action Required: The below listed document(s) is affected and requires revision and/or other actions as indicated (i.e., generate a new procedure, void a procedure, etc.)




DOCUMENTS / ACTIONS

REVIEWER / DATE

SUPERVISOR / DATE

Upon completion, forward evaluation form only to Nuclear Document Control (NR2A)

* If the Supervisor or designee acts as the Originator or Reviewer, the applicable "Originator/Reviewer" block should be NA'd.

	CALCULATION			PAGE 1 OF 114
	PROJECT: FPC- Crystal River Unit 3			IDENTIFIER DC-5520-161.05E
	SUBJECT: Seismic Verification of Tanks			CLASSIFICATION Nuclear Safety
	DISCIPLINE NAME AND NUMBER Structural/Piping 2241 & 2242			W.O. 04-5520-161
REVISION	0	1	2	3
ITEM(S) REVISED	Initial Issue			
ORIGINATOR	 S.J. Serhan			
DATE	01/19/94			
REVIEWER	G.M. Jackson			
DATE	01/19/94			
APPROVAL	 S.J. Serhan			
DATE	01/19/94			
ASSUMPTIONS/PRELIMINARY DATA	None			
PAGES REFERENCE	N/A			
THIS CALCULATION ALSO REQUIRES VERIFICATION PER DCP 2.05 YES NO				
THE REVIEW OF THE CALCULATION INCLUDED EVALUATION AGAINST THE FOLLOWING QUESTIONS:	REMARKS	REMARKS	REMARKS	REMARKS
WERE INPUTS, INCLUDING CODES, STANDARDS, AND REGULATORY REQUIREMENTS, CORRECTLY SELECTED AND APPLIED?	Yes			
ARE ASSUMPTIONS REASONABLE AND ADEQUATELY IDENTIFIED?	Yes			
HAVE APPLICABLE CONSTRUCTION AND OPERATING EXPERIENCES BEEN CONSIDERED?	N/A			
WAS AN APPROPRIATE CALCULATION METHOD USED?	Yes			
IS THE OUTPUT REASONABLE COMPARED TO INPUTS?	Yes			

THIS IS A PERMANENT DESIGN RECORD

DO NOT DESTROY

GAI-525 2-92^{PC}

Engineering Instruction No. 2



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 2	
REV.	0	1	2	3	OF		
MICROFILMED						PAGES 114	
ORIGINATOR		S.J. Serhan				WO.	
DATE		01/18/94					

CONTENTS

	<u>PAGE</u>
CALCULATION COVER SHEET	1
CONTENTS	2
1. OBJECTIVE	3
2. DESIGN INPUT AND REFERENCES	4
3. ASSUMPTIONS	5
4. GENERATION OF 4.0% DAMPED RESPONSE SPECTRA	6
4.1 Ground Spectrum	6
4.2 Auxiliary Building Elevation 119'	20
5. CONDENSATE STORAGE TANK	29
6. DEDICATED EMERGENCY FEEDWATER TANK	54
7. BORATED WATER TANK	78
8. HORIZONTAL BORIC ACID TANK	102
9. CONCLUSIONS	113

ATTACHMENTS

ATTACHMENT A	G/C DESIGN INFORMATION TRANSMITTAL	0-4
ATTACHMENT B	FPC TELECOPY DEDICATED EMERGENCY FEEDWATER TANK	0-2
ATTACHMENT C	DESIGN VERIFICATION RECORD	0-2

Engineering Instruction No. 2



CALCULATION


SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 3	
REV.	0	1	2	3	OF		
MICROFILMED						PAGES 114	
ORIGINATOR		S.J. Serhan				WO.	
DATE		01/18/94					

1. OBJECTIVE

The objective of this calculation is to:

- o generate 4% damped acceleration response spectrum curves for use in the tanks evaluation. The scope of this item includes the following locations:
 - Free-Field Ground
 - Auxiliary Building Elevation 119'
- o perform seismic verification of tanks by using the PSP Section 7 Methodology [Reference 4]. The scope of this item includes the following tanks:
 - Condensate Storage Tank [CDT-1]
 - Dedicated Emergency Feedwater Tank [EFT-2]
 - Borated Water Tank [DHT-1]
 - Horizontal Boric Acid Tank [CAT-5A and CAT-5B]


Engineering Instruction No. 2

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 4
	REV.	0	1	2	3		OF
	MICROFILMED						PAGES 114
	ORIGINATOR S.J. Serhan						WO.
	DATE 01/18/94						

2. DESIGN INPUT AND REFERENCES

- (1) Generic Implementation Procedure (GIP) for Seismic Verification of Nuclear Plant Equipment, Revision 2, SQUG, February 1992.
- (2) G/C Calculation DC-5520-127.0SE, Revision 0, Floor Response Spectrum Generation, CR3, 1992.
- (3) Computer Software: MathCAD, Version 2.5, Mathsoft Inc.
- (4) Florida Power Corporation's Plant Specific Procedures (PSP) for Seismic Verification of Nuclear Plant Equipment, Revision 0.
- (5) Florida Power Corporation "Environmental and Seismic Qualification Program Manual".

Engineering Instruction No. 2

 CALCULATION	SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 5 OF
	REV.	0	1	2	3	PAGES 114	
	MICROFILMED						WO.
	ORIGINATOR		S.J. Serhan				
	DATE		01/18/94				

3. ASSUMPTIONS

All assumptions are noted in the body of the calculation.



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 6	
REV.	0	1	2	3	OF		
MICROFILMED						PAGES 114	
ORIGINATOR		S.J. Serhan				WO.	
DATE		01/18/94					

4. GENERATION OF 4.0% DAMPED RESPONSE SPECTRA

In this section, G/C will develop the 4% damped floor acceleration response curves for the free-field ground and Auxiliary Building Elevation 119' for use in the tanks evaluation.

As done in Reference [2], the Power Method will be used in the generation of the 4% damped OBE acceleration response curves for the free-field ground and the Auxiliary Building Elevation 119'.

The reader is referred to Reference [2] for description of the lumped mass model of the Auxiliary Building, ground response spectra (plot and digitized values), and structural damping values.

To achieve the objective of this calculation, the 4.0% OBE curves are generated and the results shall be multiplied by a factor of 2.0 to develop the corresponding 4.0% SSE curves. Plots and tables of the generated broadened OBE acceleration response spectra are documented in the following subsections.

4.1 Ground Spectrum

The following pages document the generation of the 4.0 damped OBE ground acceleration response spectrum in the horizontal direction by using the Power Method.



CALCULATION

 SUBJECT FPC - Crystal River Unit 3
 Seismic Verification of Tanks

 IDENTIFIER
 DC-5520-161.0SE

PAGE

7
OF

REV.

0

1

2

3

MICROFILMED

PAGES

114

ORIGINATOR S.J. Serhan

WO.

DATE 01/18/94

GENERATION OF 4.0% DAMPED HORIZONTAL GROUND RESPONSE SPECTRUM

Given: 3.0% and 5.0% Damped Ground Response Spectra

Required: 4.0% Damped Ground Response Spectrum

Read in the input data for the 3.0% and 5.0% damped horizontal
 OBE ground response spectra (see page 23 of Reference 2):

$N_3 = 15$ [Number of Data Pairs for the 3.0% Spectrum]

Frequency (Hz)

Acceleration (g)

$$F_{3_0} = 0.25$$

$$A_{3_0} = 0.03$$

$$F_{3_1} = 0.5$$

$$A_{3_1} = 0.05$$

$$F_{3_2} = 1.0$$

$$A_{3_2} = 0.1$$

$$F_{3_3} = 1.22$$

$$A_{3_3} = 0.124$$

$$F_{3_4} = 1.43$$

$$A_{3_4} = 0.123$$

$$F_{3_5} = 1.667$$

$$A_{3_5} = 0.12$$

$$F_{3_6} = 2.0$$

$$A_{3_6} = 0.114$$

$$F_{3_7} = 2.5$$

$$A_{3_7} = 0.109$$

$$F_{3_8} = 3.33$$

$$A_{3_8} = 0.105$$

$$F_{3_9} = 5.0$$

$$A_{3_9} = 0.097$$

$$F_{3_{10}} = 7.14$$

$$A_{3_{10}} = 0.082$$

$$F_{3_{11}} = 10.0$$

$$A_{3_{11}} = 0.068$$

$$F_{3_{12}} = 16.67$$

$$A_{3_{12}} = 0.059$$

$$F_{3_{13}} = 50$$

$$A_{3_{13}} = 0.052$$

$$F_{3_{14}} = 100$$

$$A_{3_{14}} = 0.05$$



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 8	
REV.	0	1	2	3	OF		
MICROFILMED						PAGES 114	
ORIGINATOR		S.J. Serhan				WO.	
DATE		01/18/94					

$N5 = 16$ [Number of Data Pairs for the 5.0% Spectrum]

Frequency (Hz)

Acceleration (g)

$$F5_0 = 0.25$$

$$A5_0 = 0.02$$

$$F5_1 = 0.5$$

$$A5_1 = 0.04$$

$$F5_2 = 1.0$$

$$A5_2 = 0.082$$

$$F5_3 = 1.11$$

$$A5_3 = 0.092$$

$$F5_4 = 1.22$$

$$A5_4 = 0.099$$

$$F5_5 = 1.43$$

$$A5_5 = 0.1$$

$$F5_6 = 1.667$$

$$A5_6 = 0.097$$

$$F5_7 = 2.0$$

$$A5_7 = 0.092$$

$$F5_8 = 2.5$$

$$A5_8 = 0.087$$

$$F5_9 = 3.33$$

$$A5_9 = 0.08$$

$$F5_{10} = 5.0$$

$$A5_{10} = 0.07$$

$$F5_{11} = 7.14$$

$$A5_{11} = 0.061$$

$$F5_{12} = 10.0$$

$$A5_{12} = 0.056$$

$$F5_{13} = 16.67$$

$$A5_{13} = 0.0525$$

$$F5_{14} = 50.0$$

$$A5_{14} = 0.051$$

$$F5_{15} = 100.0$$

$$A5_{15} = 0.05$$

$$I3 = 0..(N3 - 1)$$

$$I5 = 0..(N5 - 1)$$



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 9 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED							WO.
ORIGINATOR S.J. Serhan							
DATE 01/18/94							


Acceleration
(g)

Figure OBE Ground Response Spectra for 3.0% and 5.0% Equipment Damping. Horizontal Direction.



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 10	
REV.	0	1	2	3	OF		
MICROFILMED				PAGES 114			
ORIGINATOR S.J. Serhan				WO.			
DATE 01/18/94							

F3 and F5 do not have the same frequency spacing and, consequently, their frequency and acceleration values do not match one-to-one. Therefore, linear interpolation is performed to obtain acceleration values (A3final and A5final) at 250 selected frequencies (F).

$$J = 1..250$$

$$F_J = 0.2 \cdot J \quad [\text{Selected Frequencies}]$$


$$A3_{final_J} = \text{interp}[F3, A3, F_J]$$

$$A5_{final_J} = \text{interp}[F5, A5, F_J]$$




CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 11 OF 11	
REV.	0	1	2	3	PAGES 114		
MICROFILMED				WO.			
ORIGINATOR S.J. Serhan							
DATE 01/18/94							

Acceleration
(g)
$$\frac{A_{3final J}}{A_{3 I3}}$$


Frequency (Hz)

Figure Comparison of Original 3.0%
Ground Spectrum and Interpolated
3.0% Ground Spectrum.

Acceleration
(g)
$$\frac{A_{5final J}}{A_{5 I5}}$$


Frequency (Hz)

Figure Comparison of Original 3.0%
Ground Spectrum and Interpolated
3.0% Ground Spectrum.



CALCULATION

 SUBJECT FPC - Crystal River Unit 3
 Seismic Verification of Tanks

 IDENTIFIER
 DC-5520-161.0SE

 PAGE 12
 OF

REV. 0 1 2 3

MICROFILMED

ORIGINATOR S.J. Serhan

DATE 01/18/94

PAGES 114

WD.

Using the Power Method described in Calculation DC-5520-127.0SE,
 the 4.0% damped ground spectrum is derived as follows:

$$\beta_1 = 3$$

$$\beta_2 = 5$$

$$\beta_3 = 4$$

$$n = \frac{\ln \left[\frac{\beta_3}{\beta_1} \right]}{\ln \left[\frac{\beta_2}{\beta_1} \right]} \quad n = 0.562$$

$$A4_{final_j} = [A3_{final_j}]^{(1-n)} \cdot [A5_{final_j}]^n$$


 Acceleration
 (g)


Figure OBE Ground Response Spectra for 3.0%, 4.0%, and 5.0%
 equipment damping.
 Horizontal Direction.



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 13	
REV.	0	1	2	3	OF		
MICROFILMED				PAGES 114			
ORIGINATOR S.J. Serhan				WO.			
DATE 01/18/94							

Listing of the 4.0% Damped Horizontal OBE Ground Spectrum

 $J = 1.35$

Frequency (Hz)

Acceleration (g)

 F_j $A4final_j$

0.2
0.4
0.6
0.8
1
1.2
1.4
1.6
1.8
2
2.2
2.4
2.6
2.8
3
3.2
3.4
3.6
3.8
4
4.2
4.4
4.6
4.8
5
5.2
5.4
5.6
5.8
6
6.2
6.4
6.6
6.8
7

0.02
0.036
0.053
0.071
0.089
0.108
0.109
0.107
0.104
0.101
0.099
0.097
0.095
0.094
0.092
0.091
0.09
0.089
0.087
0.086
0.085
0.084
0.083
0.082
0.081
0.08
0.079
0.078
0.076
0.075
0.074
0.073
0.072
0.071
0.07



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 14	
REV.	0	1	2	3	OF		
MICROFILMED				PAGES 114			
ORIGINATOR S.J. Serhan				WO.			
DATE 01/18/94							

Listing of the 4.75% Damped Horizontal OBE Ground Spectrum

J = 36 .. 70

Frequency (Hz)

Acceleration (g)

 F_j $A4final_j$

7.2
7.4
7.6
7.8
8
8.2
8.4
8.6
8.8
9
9.2
9.4
9.6
9.8
10
10.2
10.4
10.6
10.8
11
11.2
11.4
11.6
11.8
12
12.2
12.4
12.6
12.8
13
13.2
13.4
13.6
13.8
14

0.069
0.069
0.068
0.067
0.067
0.066
0.066
0.065
0.065
0.064
0.063
0.063
0.062
0.062
0.061
0.061
0.061
0.06
0.06
0.06
0.06
0.06
0.059
0.059
0.059
0.059
0.059
0.059
0.059
0.058
0.058
0.058
0.058
0.058
0.058

PAGE 15
OF
PAGES 114
WO.

[illegible]



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 16 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR		S.J. Serhan					
DATE		01/18/94					

Listing of the 4.0% Damped Horizontal OBE Ground Spectrum

 $J = 106 \dots 140$

Frequency (Hz)

Acceleration (g)

F_j	$A4final_j$
21.2	0.055
21.4	0.055
21.6	0.055
21.8	0.055
22	0.055
22.2	0.055
22.4	0.055
22.6	0.055
22.8	0.055
23	0.055
23.2	0.055
23.4	0.054
23.6	0.054
23.8	0.054
24	0.054
24.2	0.054
24.4	0.054
24.6	0.054
24.8	0.054
25	0.054
25.2	0.054
25.4	0.054
25.6	0.054
25.8	0.054
26	0.054
26.2	0.054
26.4	0.054
26.6	0.054
26.8	0.054
27	0.054
27.2	0.054
27.4	0.054
27.6	0.054
27.8	0.054
28	0.054



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 17 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR		S.J. Serhan					
DATE		01/18/94					

Listing of the 4.0% Damped Horizontal OBE Ground Spectrum

 $J = 141..175$

Frequency (Hz)


Acceleration (g)

F_J	$A4final_J$
28.2	0.054
28.4	0.054
28.6	0.054
28.8	0.054
29	0.054
29.2	0.054
29.4	0.054
29.6	0.054
29.8	0.054
30	0.054
30.2	0.054
30.4	0.054
30.6	0.054
30.8	0.054
31	0.054
31.2	0.054
31.4	0.054
31.6	0.054
31.8	0.054
32	0.054
32.2	0.053
32.4	0.053
32.6	0.053
32.8	0.053
33	0.053
33.2	0.053
33.4	0.053
33.6	0.053
33.8	0.053
34	0.053
34.2	0.053
34.4	0.053
34.6	0.053
34.8	0.053
35	0.053

WO.

[illegible]

Engineering Instruction No. 2

 CALCULATION	SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER	DC-5520-161.0SE	PAGE	20
	REV.	0	1	2	3		OF	
	MICROFILMED						PAGES	114
	ORIGINATOR		S.J. Serhan				WO.	
	DATE		01/18/94					

4.2 Auxiliary Building Elevation 119'

The following pages document the generation of the 4.0 damped OBE floor acceleration response spectrum for the Auxiliary Building Elevation 119' in the horizontal direction by using the Power Method.



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 21 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR S.J. Serhan							
DATE 01/18/94							

GENERATION OF 4.0% DAMPED HORIZONTAL RESPONSE SPECTRUM
FOR AUXILIARY BUILDING ELEVATION 119'

Given: 0.5% and 1.0% Damped Floor Response Spectra (Reference 5)

Required: 4.0% Damped Floor Response Spectrum

Read in the input data for the 0.5% and 1.0% damped horizontal
OBE floor response spectra:

N = 76 [Number of Data Points]

Frequency (Hz)	0.5% Damped Acceleration (g)	1.0% Damped Acceleration (g)
$F_1 = 0.5$	$A05_1 = 0.04$	$A1_1 = 0.04$
$F_2 = 0.6$	$A05_2 = 0.048$	$A1_2 = 0.048$
$F_3 = 0.7$	$A05_3 = 0.064$	$A1_3 = 0.064$
$F_4 = 0.8$	$A05_4 = 0.088$	$A1_4 = 0.088$
$F_5 = 0.9$	$A05_5 = 0.114$	$A1_5 = 0.114$
$F_6 = 1.0$	$A05_6 = 0.15$	$A1_6 = 0.15$
$F_7 = 1.1$	$A05_7 = 0.175$	$A1_7 = 0.16$
$F_8 = 1.2$	$A05_8 = 0.19$	$A1_8 = 0.184$
$F_9 = 1.3$	$A05_9 = 0.2$	$A1_9 = 0.184$
$F_{10} = 1.4$	$A05_{10} = 0.2$	$A1_{10} = 0.165$
$F_{11} = 1.5$	$A05_{11} = 0.2$	$A1_{11} = 0.16$
$F_{12} = 1.6$	$A05_{12} = 0.2$	$A1_{12} = 0.16$
$F_{13} = 1.7$	$A05_{13} = 0.2$	$A1_{13} = 0.16$
$F_{14} = 1.8$	$A05_{14} = 0.2$	$A1_{14} = 0.155$
$F_{15} = 1.9$	$A05_{15} = 0.2$	$A1_{15} = 0.15$
$F_{16} = 2.0$	$A05_{16} = 0.2$	$A1_{16} = 0.148$
$F_{17} = 2.1$	$A05_{17} = 0.2$	$A1_{17} = 0.145$

Engineering Instruction No. 2



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 22 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED				WO.			
ORIGINATOR S.J. Serhan							
DATE 01/18/94							

Frequency (Hz)	0.5% Damped Acceleration (g)	1.0% Damped Acceleration (g)
$F_{18} = 2.2$	$A05_{18} = 0.2$	$A1_{18} = 0.142$
$F_{19} = 2.3$	$A05_{19} = 0.2$	$A1_{19} = 0.141$
$F_{20} = 2.4$	$A05_{20} = 0.2$	$A1_{20} = 0.14$
$F_{21} = 2.5$	$A05_{21} = 0.2$	$A1_{21} = 0.14$
$F_{22} = 2.6$	$A05_{22} = 0.2$	$A1_{22} = 0.141$
$F_{23} = 2.7$	$A05_{23} = 0.2$	$A1_{23} = 0.143$
$F_{24} = 2.8$	$A05_{24} = 0.2$	$A1_{24} = 0.145$
$F_{25} = 2.9$	$A05_{25} = 0.2$	$A1_{25} = 0.146$
$F_{26} = 3.0$	$A05_{26} = 0.2$	$A1_{26} = 0.148$
$F_{27} = 3.15$	$A05_{27} = 0.2$	$A1_{27} = 0.15$
$F_{28} = 3.3$	$A05_{28} = 0.2$	$A1_{28} = 0.151$
$F_{29} = 3.45$	$A05_{29} = 0.2$	$A1_{29} = 0.151$
$F_{30} = 3.6$	$A05_{30} = 0.2$	$A1_{30} = 0.151$
$F_{31} = 3.8$	$A05_{31} = 0.2$	$A1_{31} = 0.148$
$F_{32} = 4.0$	$A05_{32} = 0.2$	$A1_{32} = 0.145$
$F_{33} = 4.2$	$A05_{33} = 0.2$	$A1_{33} = 0.144$
$F_{34} = 4.4$	$A05_{34} = 0.2$	$A1_{34} = 0.145$
$F_{35} = 4.6$	$A05_{35} = 0.2$	$A1_{35} = 0.148$
$F_{36} = 4.8$	$A05_{36} = 0.2$	$A1_{36} = 0.15$
$F_{37} = 5.0$	$A05_{37} = 0.2$	$A1_{37} = 0.145$
$F_{38} = 5.25$	$A05_{38} = 0.2$	$A1_{38} = 0.141$
$F_{39} = 5.5$	$A05_{39} = 0.2$	$A1_{39} = 0.15$
$F_{40} = 5.75$	$A05_{40} = 0.2$	$A1_{40} = 0.153$

Engineering Instruction No. 2




CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 23 OF	
REV.	0	1	2	3			
MICROFILMED						PAGES 114	
ORIGINATOR		S.J. Serhan				WO.	
DATE		01/18/94					

Frequency (Hz)	0.5% Damped Acceleration (g)	1.0% Damped Acceleration (g)
$F_{41} = 6.0$	$A05_{41} = 0.2$	$A1_{41} = 0.155$
$F_{42} = 6.25$	$A05_{42} = 0.2$	$A1_{42} = 0.16$
$F_{43} = 6.5$	$A05_{43} = 0.2$	$A1_{43} = 0.172$
$F_{44} = 6.75$	$A05_{44} = 0.2$	$A1_{44} = 0.175$
$F_{45} = 7.0$	$A05_{45} = 0.2$	$A1_{45} = 0.19$
$F_{46} = 7.25$	$A05_{46} = 0.2$	$A1_{46} = 0.193$
$F_{47} = 7.5$	$A05_{47} = 0.21$	$A1_{47} = 0.20$
$F_{48} = 7.75$	$A05_{48} = 0.22$	$A1_{48} = 0.21$
$F_{49} = 8.0$	$A05_{49} = 0.23$	$A1_{49} = 0.22$
$F_{50} = 8.5$	$A05_{50} = 0.25$	$A1_{50} = 0.24$
$F_{51} = 9.0$	$A05_{51} = 0.29$	$A1_{51} = 0.28$
$F_{52} = 9.5$	$A05_{52} = 0.32$	$A1_{52} = 0.304$
$F_{53} = 10.0$	$A05_{53} = 0.343$	$A1_{53} = 0.326$
$F_{54} = 10.5$	$A05_{54} = 0.375$	$A1_{54} = 0.356$
$F_{55} = 11.0$	$A05_{55} = 0.405$	$A1_{55} = 0.385$
$F_{56} = 11.5$	$A05_{56} = 0.41$	$A1_{56} = 0.39$
$F_{57} = 12.0$	$A05_{57} = 0.47$	$A1_{57} = 0.415$
$F_{58} = 12.5$	$A05_{58} = 0.54$	$A1_{58} = 0.418$
$F_{59} = 13.0$	$A05_{59} = 0.54$	$A1_{59} = 0.418$
$F_{60} = 13.5$	$A05_{60} = 0.54$	$A1_{60} = 0.415$
$F_{61} = 14.0$	$A05_{61} = 0.54$	$A1_{61} = 0.41$
$F_{62} = 14.5$	$A05_{62} = 0.54$	$A1_{62} = 0.408$
$F_{63} = 15.0$	$A05_{63} = 0.48$	$A1_{63} = 0.38$

Engineering Instruction No. 2

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 24 OF
	REV.	0	1	2	3	PAGES 1/4	
	MICROFILMED						WO.
	ORIGINATOR S.J. Serhan						
	DATE 01/18/94						

Frequency (Hz)	0.5% Damped Acceleration (g)	1.0% Damped Acceleration (g)
$F_{64} = 16.0$	$A05_{64} = 0.34$	$A1_{64} = 0.33$
$F_{65} = 17.0$	$A05_{65} = 0.28$	$A1_{65} = 0.28$
$F_{66} = 18.0$	$A05_{66} = 0.24$	$A1_{66} = 0.24$
$F_{67} = 20.0$	$A05_{67} = 0.16$	$A1_{67} = 0.16$
$F_{68} = 22.0$	$A05_{68} = 0.12$	$A1_{68} = 0.12$
$F_{69} = 25.0$	$A05_{69} = 0.11$	$A1_{69} = 0.08$
$F_{70} = 28.0$	$A05_{70} = 0.14$	$A1_{70} = 0.075$
$F_{71} = 31.0$	$A05_{71} = 0.22$	$A1_{71} = 0.065$
$F_{72} = 34.0$	$A05_{72} = 0.18$	$A1_{72} = 0.06$
$F_{73} = 36.0$	$A05_{73} = 0.12$	$A1_{73} = 0.06$
$F_{74} = 40.0$	$A05_{74} = 0.09$	$A1_{74} = 0.055$
$F_{75} = 45.0$	$A05_{75} = 0.07$	$A1_{75} = 0.05$
$F_{76} = 50.0$	$A05_{76} = 0.06$	$A1_{76} = 0.04$

Ncount = 1..N



CALCULATION

SUBJECT FPC - Crystal River Unit 3
Seismic Verification of Tanks

IDENTIFIER
DC-5520-161.0SE

PAGE 25
OF

REV. 0 1 2 3

MICROFILMED

PAGES 114

ORIGINATOR S.J. Serhan

WO.

DATE 01/18/94

Acceleration
(g)




Figure OBE Response Spectra for 0.5% and 1.0%
Equipment Damping. Auxiliary Building
Elevation 119' for Horizontal Direction.



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 26 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED							WO.
ORIGINATOR S.J. Serhan							
DATE 01/18/94							

Using the Power Method described in Calculation DC-5520-127.0SE,
the 4.0% damped floor spectrum is derived as follows:

$$\beta_1 = 0.5 \quad \beta_2 = 1.0 \quad \beta_3 = 4.0$$

$$n = \frac{\ln \left[\frac{\beta_3}{\beta_1} \right]}{\ln \left[\frac{\beta_2}{\beta_1} \right]} \quad n = 3$$

$$A_{4Ncount} = [A_{05Ncount}]^{(1-n)} \cdot [A_{1Ncount}]^n$$

Acceleration
(g)




Figure OBE Ground Response Spectra for 0.5%, 1.0%, and 4.0%
Damping in the Horizontal Direction.



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 27 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR		S.J. Serhan					
DATE		01/18/94					

Listing of the 4.0% Damped Horizontal OBE Floor Spectrum

$$J = 1.35$$

Frequency (Hz) Acceleration (g)

F_J	$A4_J$
0.5	0.04
0.6	0.048
0.7	0.064
0.8	0.088
0.9	0.114
1	0.15
1.1	0.134
1.2	0.173
1.3	0.156
1.4	0.112
1.5	0.102
1.6	0.102
1.7	0.102
1.8	0.093
1.9	0.084
2	0.081
2.1	0.076
2.2	0.072
2.3	0.07
2.4	0.069
2.5	0.069
2.6	0.07
2.7	0.073
2.8	0.076
2.9	0.078
3	0.081
3.15	0.084
3.3	0.086
3.45	0.086
3.6	0.086
3.8	0.081
4	0.076
4.2	0.075
4.4	0.076
4.6	0.081

Engineering Instruction No. 2



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 28 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR		S.J. Serhan					
DATE		01/18/94					

 $J = 36..76$

Frequency (Hz)


Acceleration (g)

 F_J $A4_J$

4.8	0.084
5	0.076
5.25	0.07
5.5	0.084
5.75	0.09
6	0.093
6.25	0.102
6.5	0.127
6.75	0.134
7	0.171
7.25	0.18
7.5	0.181
7.75	0.191
8	0.201
8.5	0.221
9	0.261
9.5	0.274
10	0.294
10.5	0.321
11	0.348
11.5	0.353
12	0.324
12.5	0.25
13	0.25
13.5	0.245
14	0.236
14.5	0.233
15	0.238
16	0.311
17	0.28
18	0.24
20	0.16
22	0.12
25	0.042
28	0.022
31	0.006
34	0.007
36	0.015
40	0.021
45	0.026
50	0.018


THIS IS A PERMANENT RECORD DO NOT DESTROY

Engineering Instruction No. 2

 CALCULATION	SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER		DC-5520-151.0SE		PAGE		29	
	REV.		0		1		2		3		OF	
	MICROFILMED										PAGES 114	
	ORIGINATOR		S.J. Serhan								WO.	
	DATE		01/18/94									

5. CONDENSATE STORAGE TANK

The following pages document the seismic verification of the Condensate Storage Tank by using the PSP Section 7 Methodology [Reference 4].

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 30 OF
	REV.	0	1	2	3	PAGES 114	
	MICROFILMED						WO.
	ORIGINATOR S.J. Serhan						
	DATE 01/18/94						

FPC- Crystal River Unit 3

USI A-46 Project

Tanks Evaluation

Tank: Condensate Storage Tank [CDT-1]

Originator: Samir J. Serhan 06/25/1993

Reviewer: Gary M. Jackson

Program Name: TANKv1

Dr. Samir J. Serhan
Gilbert/Commonwealth, Inc.
April 5, 1993

SEISMIC VERIFICATION OF VERTICAL TANKS

Scope:

This seismic verification procedure is applicable to tanks with the following characteristics:

- (a) Large cylindrical tanks,
- (b) Axis of symmetry is vertical,
- (c) Flat bottom,
- (d) Anchored to concrete pads or building floor,
- (e) Tank material is carbon steel (ASTM A36 or A283 Grade C), stainless steel (ASTM A240 Type 304), aluminum (various alloys), or better material,
- (f) Anchor bolts are evenly spaced around tank circumference within + or - 5 degrees,
- (g) Anchor bolts are cast-in-place or J-bolts (ASTM A36 or A307, A325),
- (h) Fluid in tank is water or similar material, and
- (i) Dimensions for tank shell, anchorage, and content should fall within the following range of parameters:

[See the following page]


Engineering Instruction No. 2



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 31 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR		S.J. Serhan					
DATE		01/18/94					

Nominal Radius (R):	60" to 420"
Height of Tank Shell (Hp):	120" to 960"
Maximum Height of Fluid (H):	120" to 960"
Minimum Thickness of Tank Shell in the lowest 10% of Hp (ts):	0.1875" to 1.0"
Effective Thickness of Tank Shell [(tav+tmin)/2] (tef):	0.1875" to 1.0"
Diameter of Anchor Bolt (d):	0.5" to 2.0"
Number of anchor bolts (N):	8 or more
Ratio of Thickness of Wall ts to Radius of Tank (ts/R):	0.001 to 0.01
Ratio of Thickness of Wall tef to Radius of Tank (tef/R):	0.001 to 0.01
Ratio of Maximum Height of Fluid to Radius of Tank (H/R):	1.0 to 5.0

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 32
	REV.	0	1	2	3		OF
	MICROFILMED						PAGES 114
	ORIGINATOR S.J. Serhan						WO.
	DATE 01/18/94						

Evaluation Process:

Per the PSP Section 7 [4], the seismic verification for vertical tanks consists of the following 23 steps:

* STEP 1 INPUT DATA to be provided by the user

Tank Shell:

$R = 192$ in [Nominal Radius of Tank]
 $H_p = 420$ in [Height of Tank Shell]
 $t_{min} = 0.25$ in [Minimum Shell Thickness]
 $t_s = 0.25$ in [Minimum Shell Thickness in lowest 10% H_p]
 $n = 5$ [Variation of Shell Thickness Along Height]
 $h_1 = 84$ in $t_1 = 0.25$ in
 $h_2 = 84$ in $t_2 = 0.25$ in
 $h_3 = 84$ in $t_3 = 0.25$ in
 $h_4 = 84$ in $t_4 = 0.25$ in
 $h_5 = 84$ in $t_5 = 0.25$ in



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 33 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR		S.J. Serhan					
DATE		01/18/94					

(Step 1 Continued)

$\sigma_y = 30000$ psi [Yield Stress of Tank Shell Material]
 $h_c = 8.5$ in [Height of Chair]
 $E_s = 29 \cdot 10^6$ psi [Young's Modulus of Tank Shell Material]

Tank Foundation:

$V_s = 1500$ ft/sec [Shear Wave Velocity of Supporting Soil]

Tank Content:

$\rho_f = 0.0361$ lbf/in³ [Weight Density of Fluid in Tank]
 $H = 390$ in [Maximum Height of Fluid]
 $h_f = 30$ in [Freeboard Height]

Tank Anchorage Bolts:

$N = 24$ [Number of Anchor Bolts]
 $d = 1.25$ in [Diameter of Anchor Bolt]
 $h_b = 47$ in [Effective Length of Anchor Bolt]
 $E_b = 30000000$ psi [Young's Modulus of Anchor Bolt]



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 34 OF
REV.	0	1	2	3		
MICROFILMED						PAGES 114
ORIGINATOR S.J. Serhan						WO.
DATE 01/18/94						

STEP 2 Ratios:

$$H_{overR} = \frac{H}{R}$$

$$H_{overR} = 2.031$$

$$t_{overR} = \frac{ts}{R}$$

$$t_{overR} = 0.001$$

$$i = 1..n$$

$$t_{av} = \frac{\sum_i [t_i \cdot h_i]}{H_p}$$

$$t_{av} = 0.25 \quad \text{in}$$

$$t_{ef} = \frac{t_{av} + t_{min}}{2}$$

$$t_{ef} = 0.25 \quad \text{in}$$

$$t_{efoverR} = \frac{t_{ef}}{R}$$

$$t_{efoverR} = 0.001$$

$$A_b = \frac{\pi \cdot d^2}{4}$$

$$A_b = 1.227 \quad \text{in}^2$$

$$t_p = \left[\frac{N \cdot A_b}{2 \cdot \pi \cdot R} \right] \cdot \left[\frac{E_b}{E_s} \right]$$

$$t_p = 0.025 \quad \text{in}$$

$$c_p = \left[\frac{t_p}{t_s} \right] \cdot \left[\frac{h_c}{h_b} \right]$$

$$c_p = 0.018$$

$$W = \pi \cdot R^2 \cdot H \cdot \Gamma \phi$$

$$W = 1.631 \cdot 10^6 \quad \text{lb f}$$



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 35 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						V.O.	
ORIGINATOR		S.J. Serhan					
DATE		01/18/94					

* Note to User:

Before proceeding to Step 2, confirm that the values listed and ratios calculated in Step 1 are within the applicable range of parameters documented in the scope of this seismic verification procedure.

STEP 3 Fluid-Structure Modal Frequency (Impulsive Frequency)

* Note to User:

Using the following parameters, enter Table 7-3 of the PSP Section 7 and obtain Ff in Hz:

$$R = 192 \quad \text{in}$$

$$te_{\text{over}R} = 0.001$$

$$H_{\text{over}R} = 2.031$$

The following answer is provided by the user:

$$Ff = 7.5 \quad \text{Hz} \quad [\text{This frequency is for carbon steel tanks containing water}]$$

For tanks made of stainless steel or aluminum :

$$Ff = Ff \cdot \sqrt{\frac{0.0361}{\Gamma \phi}} \cdot \sqrt{\frac{E_s}{30 \cdot 10^6}}$$

$$Ff = 7.374 \quad \text{Hz}$$

The Condensate Storage Tank is made of carbon steel, therefore

$$Ff = 7.5 \quad \text{Hz}$$



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 36	
REV.	0	1	2	3	OF		
MICROFILMED						PAGES 114	
ORIGINATOR S.J. Serhan						WO.	
DATE 01/18/94							

STEP 4 Spectral Acceleration for Impulsive Frequency

* Note to User:

Using the 4% damped maximum horizontal ground or floor (whichever is applicable) acceleration response spectrum, determine the maximum spectral acceleration S_{af} over the frequency range $0.8 F_f < F < 1.2 F_f$.

For tanks with concrete pads founded on ground with a shear wave velocity less than 3500 ft/sec, the following is suggested in lieu of conducting soil/structure interaction analysis:

If F_f is less than the peak frequency of the maximum horizontal ground acceleration response spectrum, ignore soil/structure interaction effects.

Otherwise, use the peak spectral acceleration for S_{af} .

The following answer is provided by the user:

$S_{af} = 0.137 \quad g$ (From page 14 @ 7.5 Hz,
 $S_{af} = 2 \times 0.0685$)

STEP 5 Base Shear Load

* Note to User:

Using the following parameters, enter Figure 7-3 of the PSP Section 7 and obtain the base shear load coefficient Q_p :

$H_{overR} = 2.031$


$t_{efoverR} = 0.001$

The following answer is provided by the user:

$Q_p = 0.725$

Therefore, the shear load at the base of the tank is equal to:

$$Q = Q_p \cdot W \cdot S_{af} \quad Q = 1.62 \cdot 10^5 \quad \text{lbf}$$

 CALCULATION	SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER	DC-5520-161.0SE	PAGE	37
	REV.	0	1	2	3		OF	
	MICROFILMED						PAGES	114
	ORIGINATOR		S.J. Serhan				WO.	
	DATE		01/18/94					

STEP 6 Base Overturning Moment

* Note to User:

Using the following parameters, enter Figure 7-4 of the PSP Section 7 and obtain the base overturning moment coefficient M_p :

$$\text{HoverR} = 2.031$$

$$\text{tefoverR} = 0.001$$

The following answer is provided by the user:

$$M_p = 0.368$$

Therefore, the overturning moment at the base of the tank is equal to:

$$M = M_p \cdot W \cdot H \cdot S_{af} \quad M = 3.206 \cdot 10^7 \quad \text{in-lbf}$$

STEP 7 Bolt Tensile Load Capacity

* Note to User:

Using Appendix C of the GIP [Reference 1], obtain anchor bolt tensile capacity P_u in lbf.

The following answer is provided by the user:

The Condensate Storage Tank is anchored to its foundation by 24 1.25" ϕ cast-in-place J bolts with 90-degree hooks. The minimum bend radius is 4 ϕ , and the minimum straight extension of the hook is also 4 ϕ . The corresponding values for the Condensate Storage Tank are 0.8 ϕ and 1.8 ϕ , respectively. As a conservative assumption, the length of the hook will not be included in the embedment length. The actual embedment length provided for the anchor bolt is

$$L = 39.25 \quad \text{in}$$

From Table C.4-1 of the GIP, $L_{min} = 68.125 \quad \text{in}$



CALCULATION

 SUBJECT FPC - Crystal River Unit 3
 Seismic Verification of Tanks

 IDENTIFIER
 DC-5520-161.0SE

 PAGE 38
 OF

REV. 0 1 2 3

MICROFILMED

ORIGINATOR S.J. Serhan

DATE 01/18/94

PAGES 114

WO.

(Step 7 Continued)

Sinc $L_{min} > L > \text{or} = 16d$, the reduction factor for embedment is calculated as:

$$R_{embed} = \frac{(L + 8 \cdot d)}{62.5 \cdot d} \quad R_{embed} = 0.63$$

The pullout and shear capacity given in Table C.4-1 of the GIP are based on f'_c of 3500 psi. Therefore, the reduction factor for f'_c of 3000 psi is calculated as:

$$R_{conc} = \sqrt{\frac{3000}{3500}} \quad R_{conc} = 0.926$$

Using Table C.4-1 of the GIP, the pullout capacity and shear capacity of a 1.25" ϕ anchor are:

$$P_{nom} = 41720 \quad \text{lbf}$$

$$V_{nom} = 20860 \quad \text{lbf}$$

Applying reduction factors

$$P_u = P_{nom} \cdot R_{embed} \cdot R_{conc} \quad P_u = 2.435 \cdot 10^4 \quad \text{lbs}$$

The allowable bolt stress is:

$$F_b = \frac{P_u}{A_b} \quad F_b = 1.984 \cdot 10^4 \quad \text{psi}$$



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 39 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR S.J. Serhan							
DATE 01/18/94							

STEP 8 Top Plate of Anchor Bolt Chair

The dimensions f and c represent the length along the vertical stiffeners and thickness of the top plate, respectively. The dimension g represents the distance between the inner surfaces of the vertical stiffener plates.

- * The following dimensions f , c and g are provided by the user:

$$f = \frac{6 - d}{2} \quad f = 2.375 \quad \text{in}$$

$$c = 0.5 \quad \text{in}$$

$$g = 3 \quad \text{in}$$

The maximum bending stress in the top plate is calculated as:


$$\sigma = \frac{(0.375 \cdot g - 0.22 \cdot d) \cdot P_u}{f \cdot c^2}$$

$$\sigma = 3.486 \cdot 10^4 \quad \text{psi} < f_y = 3.6 \cdot 10^4$$

If the above relation is OK, there is no load reduction factor to be applied on the anchor bolt allowable tensile stress F_b . Otherwise, multiply F_b by the following reduction factor:

$$R_{\text{chair}} = \left[\frac{f_y}{\sigma} \right]$$

$$R_{\text{chair}} = 1.033 \quad (\text{Do not use if } > 1.0)$$

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 40 OF
	REV.	0	1	2	3		PAGES 114
	MICROFILMED						WO.
	ORIGINATOR S.J. Serhan						
	DATE 01/18/94						

STEP 9 Tank Shell Stress

- * For the calculation of the tank shell stress, the following dimensions should be provided by the user:

a = 5 in [Width of chair top plate parallel to shell]

e = 3 in [Eccentricity of anchor bolt with respect to shell outside surface]

tb = 0.25 in [Thickness of base plate of tank]

h = 8.75 in [Height of chair]

The maximum bending stress σ in the tank shell is:

$$Z = \frac{1.0}{\left[\frac{0.177 \cdot a \cdot tb}{\sqrt{R \cdot ts}} \cdot \left[\frac{tb}{ts} \right]^2 + 1.0 \right]}$$


$$\sigma = \left[\frac{Pu \cdot e}{ts^2} \right] \cdot \left[\frac{1.32 \cdot Z}{\left[\frac{1.43 \cdot a \cdot h^2}{R \cdot ts} + \left[4 \cdot a \cdot h^2 \right]^{0.333} \right]} + \frac{0.031}{\sqrt{R \cdot ts}} \right]$$

$$\sigma = 7.051 \cdot 10^4 \text{ psi} < \sigma_{\psi} = 3 \cdot 10^4 \text{ psi}$$

If the above relation is OK, there is no load reduction factor to be applied on the anchor bolt allowable tensile stress F_b . Otherwise, multiply F_b by the following reduction factor:

$$R_{\text{shell}} = \left[\frac{\sigma_{\psi}}{\sigma} \right] \quad R_{\text{shell}} = 0.425 \quad (\text{Do not use if } > 1.0)$$

$$F_r = F_b \cdot R_{\text{shell}} \quad F_r = 8.442 \cdot 10^3 \text{ psi}$$

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 41 OF
	REV.	0	1	2	3	PAGES 114	
	MICROFILMED						WO.
	ORIGINATOR S.J. Serhan						
	DATE 01/18/94						

STEP 10 Vertical Stiffener Plates

- * The following dimensions are provided by the user:

$k = 3.75$ in [Average width of chair vertical stiffener plate]

$j = 0.5$ in [Thickness of chair vertical stiffener plate]

- * The user should check that the following four relations are satisfied:

$$\frac{k}{j} = 7.5 < \frac{95}{\sqrt{\frac{f_y}{1000}}} = 15.833$$


$$j = 0.5 > 0.04 \cdot (h - c) = 0.33 \text{ in}$$

$$j = 0.5 > 0.5 \text{ in (marginal, OK)}$$

$$\frac{P_u}{2 \cdot k \cdot j} = 6.493 \cdot 10^3 < 21000 \text{ psi}$$

If one or more of the above relations are not satisfied, consult applicable codes and standards for an appropriate reduction factor or consider the tank as an outlier.

Engineering Instruction No. 2

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 42 OF
	REV.	0	1	2	3	PAGES 14	
	MICROFILMED						WO.
	ORIGINATOR S.J. Serhan						
	DATE 01/18/94						

STEP 11 Chair-to-Tank Shell Weld

The required load per inch for the weld between the chair and tank shell is:

$$W_w = P_u \cdot \sqrt{\left[\frac{1}{a + 2 \cdot h} \right]^2 + \left[\frac{e}{a \cdot h + 0.667 \cdot h^2} \right]^2}$$

- * The user should provide thickness of leg of weld and check that the following relation is satisfied:

$$t_w = 0.25 \quad \text{in}$$

$$W_w = 1.328 \cdot 10^3 < \text{or} = \frac{30600 \cdot t_w}{\sqrt{2}} = 5.409 \cdot 10^3$$

If the above relations are not satisfied, consult applicable codes and standards for an appropriate reduction factor or consider the tank as an outlier.



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 43 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR		S.J. Serhan					
DATE		01/18/94					

STEP 12 Fluid Pressure for Elephant-Foot Buckling

- * Using the following parameters, enter Figure 7-7 of the PSP Section 7 and obtain the fluid pressure coefficient Pep for elephant-foot buckling:

$$Saf = 0.137 \quad g$$

$$HoverR = 2.031$$

The following answer is provided by the user:

$$Pep = 2.2$$

Based on the value of Pep , the fluid pressure at the base of the tank for elephant-foot buckling is:

$$Pe = Pep \cdot T \phi \cdot R$$

$$Pe = 15.249 \quad \text{psi}$$



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 44 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR		S.J. Serhan					
DATE		01/18/94					

STEP 13 Elephant-Foot Buckling Stress Capacity Factor

- * Using the following parameters, enter Figure 7-8 of the PSP Section 7 and obtain the fluid pressure coefficient P_{ep} for elephant-foot buckling:

$$P_e = 15.249$$

$$t_{soverR} = 0.001$$

The following answer is provided by the user for tanks made of Carbon Steel:

$$\sigma_{TE} = 11.8 \quad \text{ksi}$$

$$\sigma_{TE} = \sigma_{TE} \cdot 1000 \quad \sigma_{TE} = 1.18 \cdot 10^4 \quad \text{psi}$$

For tanks made of stainless steel or aluminum, the following procedure applies:

$$S1 = \frac{R}{400 \cdot ts}$$

$$S2 = \frac{S1 + \left[\frac{\sigma_{\psi}}{36000} \right]}{S1 + 1}$$

$$\sigma_{TE} = \frac{0.6 \cdot E_s}{\frac{R}{ts}} \cdot \left[1 - \left[\frac{P_e \cdot R}{\sigma_{\psi} \cdot ts} \right]^2 \right] \cdot \left[1 - \left[\frac{1}{1.12 + S1^{1.5}} \right] \right] \cdot S2$$

$$\sigma_{TE} = 1.332 \cdot 10^4 \quad \text{psi}$$

For the Condensate Storage Tank, $\sigma_{TE} = 1.18 \cdot 10^4 \quad \text{psi}$

Engineering Instruction No. 2



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 45 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WC.	
ORIGINATOR		S.J. Serhan					
DATE		01/18/94					

STEP 14 Fluid Pressure for Diamond-Shape Buckling

- * Using the following parameters, enter Figure 7-9 of the PSP Section 7 and obtain the pressure coefficient P_{ep} for diamond-shape buckling:

$$S_{af} = 0.137 \quad g$$

$$H_{overR} = 2.031$$

The following answer is provided by the user:

$$P_{dp} = 2.1$$

Based on the value of P_{dp} , the fluid pressure at the base of the tank for diamond-shape buckling is:

$$P_d = P_{dp} \cdot \Gamma \cdot \phi \cdot R$$

$$P_d = 14.556 \quad \text{psi}$$



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 46 OF	
REV.	0	1	2	3			
MICROFILMED						PAGES 114	
ORIGINATOR S.J. Serhan						WO.	
DATE 01/18/94							

STEP 15 Diamond-Shape Buckling Stress Capacity Factor

- * Using the following parameters, enter Figure 7-10 of the PSP Section 7 and obtain the stress capacity factor σ_{pd} for diamond-shape buckling:

$$P_d = 14.556 \quad \text{psi}$$

$$t_{\text{sover}R} = 0.001$$

The following answer is provided by the user:

$$\sigma_{\pi\delta} = 12.2 \quad \text{ksi}$$

$$\sigma_{\pi\delta} = \sigma_{\pi\delta} \cdot 1000 \quad \sigma_{\pi\delta} = 1.22 \cdot 10^4 \quad \text{psi}$$

This value of σ_{pd} is for carbon steel. For tanks made of stainless steel or aluminum, the following procedure is applied:

- * Using the following parameter, enter Figure 7-11 of the PSP Section 7, obtain $\delta\Gamma$, and calculate σ_{pd} :

$$\frac{P_d}{E_s} \cdot \left[\frac{R}{t_s} \right]^2 = 0.296 \quad \delta\Gamma = 0.12 \quad [\text{Figure 7-11}]$$

$$\phi = \frac{1}{16} \cdot \left[\frac{R}{t_s} \right] \quad \Gamma = 1 - 0.73 \cdot [1 - \exp(-\phi)]$$

$$\sigma_{\pi\delta} = \left[0.6 \cdot \Gamma + \delta\Gamma \right] \cdot \left[\frac{E_s}{\frac{R}{t_s}} \right] \quad \sigma_{\pi\delta} = 1.357 \cdot 10^4 \quad \text{psi}$$

For Condensate Storage Tank, $\sigma_{\pi\delta} = 1.22 \cdot 10^4 \quad \text{psi}$



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 47 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR		S.J. Serhan					
DATE		01/18/94					

STEP 16 Allowable Buckling Stress

The allowable buckling stress σ_c is calculated as 72% of the lower value of σ_{pe} or σ_{pd} .

$$iii = 0..1$$

$$\sigma_{\pi_0} = \sigma_{\pi e}$$

$$\sigma_{\pi_0} = 1.18 \cdot 10^4 \text{ psi}$$

$$\sigma_{\pi_1} = \sigma_{\pi \delta}$$

$$\sigma_{\pi_1} = 1.22 \cdot 10^4 \text{ psi}$$

$$\sigma_{\chi} = 0.72 \cdot \min(\sigma_{\pi})$$

$$\sigma_{\chi} = 8.496 \cdot 10^3 \text{ psi}$$



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 48 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR S.J. Serhan							
DATE 01/18/94							

STEP 17 Overturning Capacity of Tank

Ductile Failure:

Ductile failure modes are

- Anchor bolt stretching (Step 7)
- Chair top plate bending (Step 8)
- Tank shell bending (Step 9)

Using the following parameters, enter Figure 7-12 of the PSP Section 7, and obtain the base overturning moment coefficient Mcapp:

$$c_p = 0.018$$

$$\frac{\sigma_x}{F_r} \cdot \frac{h_c}{h_b} = 0.182$$

$$M_{capp} = 0.06 \quad [\text{Figure 7-12}]$$

The base overturning moment is:

$$M_{capDUCT} = M_{capp} \cdot (2 \cdot F_r) \cdot [R^2 \cdot t_s] \cdot \left[\frac{h_b}{h_c} \right]$$

$$M_{capDUCT} = 5.163 \cdot 10^7 \quad \text{in-lbf}$$

Engineering Instruction No. 2



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER		DC-5520-161.0SE		PAGE		49	
REV.		0		1		2		3		OF	
MICROFILMED										PAGES 114	
ORIGINATOR		S.J. Serhan								WO.	
DATE		01/18/94									

STEP 17 Continued

Brittle Failure:

Brittle failure modes are

Concrete cone failure (Step 7)

Chair stiffener plate shear or buckling failure (Step 10)

Chair-to-tank wall weld shear failure (Step 11)

Using the following parameters, enter Table 7-4 of the PSP Section 7, and obtain the base overturning moment coefficient M_{capp} :

$$c_p = 0.018$$

$$M_{capp} = 0.04094 \quad [\text{Table 7-4}]$$

The base overturning moment is:

[User Note: Use the smaller value of F_b or F_R from Steps 7, 8, 9, 10, or 11]

$$M_{capBRIT} = M_{capp} \cdot (2 \cdot F_R) \cdot [R^2 \cdot t_s] \cdot \left[\frac{hb}{hc} \right]$$

$$M_{capBRIT} = 3.523 \cdot 10^7 \quad \text{in-lbf}$$

Engineering Instruction No. 2



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 50 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR		S.J. Serhan					
DATE		01/18/94					

STEP 18 Capacit vs. Demand for Base Overturning Moment

- * If the expected failure mode is ductile, the user should select the McapDUCT for use as Mcap. However, if the expected failure mode is brittle, the user should select the lower of McapDUCT and McapBRIT for use as Mcap.

For the Condensate Storage Tank, the expected failure mode is brittle (not enough embedment length). Therefore,

$$M_{cap} = M_{capBRIT}$$

$$M_{cap} = 3.523 \cdot 10^7 \text{ in-lbf}$$

The base overturning moment demand is determined from Step 6 and it is equal to:

$$M = 3.206 \cdot 10^7 \text{ in-lbf}$$

- * The user should check that the following relation is satisfied:

$$M_{cap} = 3.523 \cdot 10^7 > \text{or} = M = 3.206 \cdot 10^7$$

[OK, marginal]

If the above relation is not satisfied, consider the tank as an outlier.

Engineering Instruction No. 2



CALCULATION

SUBJECT		PC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 51 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR		S.J. Serhan					
DATE		01/18/94					

STEP 19 Base Shear Load Capacity

The base shear load capacity is determined as:

$$Q_{cap} = 0.55 \cdot (1 - 0.218 \cdot S_{af}) \cdot W$$


$$Q_{cap} = 8.7 \cdot 10^5 \quad \text{lb} \cdot \text{f}$$

STEP 20 Capacity vs. Demand for Base Shear

- * The user should check that the following relation is satisfied:

$$Q_{cap} = 8.7 \cdot 10^5 \quad > \text{ or } = \quad Q = 1.62 \cdot 10^5 \quad \text{OK}$$

If the above relation is not satisfied, consider the tank as an outlier.

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 52
	REV.	0	1	2	3		OF
	MICROFILMED						PAGES 114
	ORIGINATOR S.J. Serhan						WO.
	DATE 01/18/94						

STEP 21 Slosh Height

$G = 386.4$ in/sec/sec [Acceleration of Gravity]

The sloshing mode frequency is:

$$F_s = \frac{1}{2 \cdot \pi} \cdot \sqrt{\frac{1.84 \cdot G}{R} \cdot \tanh \left[\frac{1.84 \cdot H}{R} \right]}$$

$$F_s = 0.306 \text{ Hz}$$

* Note to User:

Using the 1/2% damped maximum horizontal ground or floor (whichever is applicable) acceleration response spectrum, determine the spectral acceleration S_{as} at frequency = F_s .

$$S_{as} = 0.13 \text{ g (OBE Acc. from Fig. 24 of Reference 5 @ 0.31 Hz times 2)}$$

The slosh height is:

$$h_s = 0.837 \cdot R \cdot S_{as} \quad h_s = 20.892 \text{ in}$$


STEP 22 Freeboard Clearance vs. Slosh Height

* The user should check that the following relation is satisfied:

$$h_f = 30 > \text{or} = h_s = 20.892 \text{ [OK]}$$

If the above relation is not satisfied, consider the tank as an outlier.

Engineering Instruction No. 2

 CALCULATION	SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 53
	REV.	0	1	2	3	OF	
	MICROFILMED					PAGES 114	
	ORIGINATOR		S.J. Serhan				WO.
	DATE		01/18/94				

CONCLUSION: Tank under evaluation is acceptable per PSP Section 7 seismic verification procedure.

Engineering Instruction No. 2




CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 54 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR		S.J. Serhan					
DATE		01/18/94					

6. DEDICATED EMERGENCY FEEDWATER TANK

The following pages document the seismic verification of the Dedicated Emergency Feedwater Tank by using the PSP Section 7 Methodology [Reference 4].

Engineering Instruction No. 2

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 55 OF
	REV.	0	1	2	3		
	MICROFILMED						PAGES 14
	ORIGINATOR S.J. Serhan						WO.
	DATE 01/18/94						

FPC- Crystal River Unit 3

USI A-46 Project

Tanks Evaluation

Tank: Dedicated Emergency Feedwater Tank [EFT-2]

Originator: Samir J. Serhan 10/08/1993

Reviewer: Gary M. Jackson

Program Name: TANKv3

Dr. Samir J. Serhan
 Gilbert/Commonwealth, Inc.
 April 5, 1993

SEISMIC VERIFICATION OF VERTICAL TANKS


Scope:

This seismic verification procedure is applicable to tanks with the following characteristics:

- (a) Large cylindrical tanks,
- (b) Axis of symmetry is vertical,
- (c) Flat bottom,
- (d) Anchored to concrete pads or building floor,
- (e) Tank material is carbon steel (ASTM A36 or A283 Grade C), stainless steel (ASTM A240 Type 304), aluminum (various alloys), or better material,
- (f) Anchor bolts are evenly spaced around tank circumference within + or - 5 degrees,
- (g) Anchor bolts are cast-in-place or J-bolts (ASTM A36 or A307, A325),
- (h) Fluid in tank is water or similar material, and
- (i) Dimensions for tank shell, anchorage, and content should fall within the following range of parameters:


[See the following page]

Engineering Instruction No. 2

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 56 OF
	REV	0	1	2	3	PAGES 114	
	MICROFILMED						WO.
	ORIGINATOR S.J. Serhan						
DATE 01/18/94							

Nominal Radius (R):	60" to 420"
Height of Tank Shell (Hp):	120" to 960"
Maximum Height of Fluid (H):	120" to 960"
Minimum Thickness of Tank Shell in the lowest 10% of Hp (ts):	0.1875" to 1.0"
Effective Thickness of Tank Shell [(tav+tmin)/2] (tef):	0.1875" to 1.0"
Diameter of Anchor Bolt (d):	0.5" to 2.0"
Number of anchor bolts (N):	8 or more
Ratio of Thickness of Wall ts to Radius of Tank (ts/R):	0.001 to 0.01
Ratio of Thickness of Wall tef to Radius of Tank (tef/R):	0.001 to 0.01
Ratio of Maximum Height of Fluid to Radius of Tank (H/R):	1.0 to 5.0

Engineering Instruction No. 2

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 57 OF
	REV.	0	1	2	3	PAGES 114	
	MICROFILMED						WO.
	ORIGINATOR S.J. Serhan						
	DATE 01/18/94						

Evaluation Process:


Per the PSP Section 7 [4], the seismic verification for vertical tanks consists of the following 23 steps:

* STEP 1 INPUT DATA to be provided by the user

Tank Shell:

$R = 167.81$ in [Nominal Radius of Tank]
 $H_p = 480$ in [Height of Tank Shell]
 $t_{min} = 0.1875$ in [Minimum Shell Thickness]
 $t_s = 0.375$ in [Minimum Shell Thickness in lowest 10% H_p]
 $n = 5$ [Variation of Shell Thickness Along Height]
 $h_1 = 96$ in $t_1 = 0.375$ in
 $h_2 = 96$ in $t_2 = 0.3125$ in
 $h_3 = 96$ in $t_3 = 0.25$ in
 $h_4 = 96$ in $t_4 = 0.1875$ in
 $h_5 = 96$ in $t_5 = 0.1875$ in

Engineering Instruction No. 2

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 58 OF
	REV.	0	1	2	3		PAGES 114
	MICROFILMED						WO.
	ORIGINATOR S.J. Serhan						
DATE 01/18/94							

(Step 1 Continued)

 $\sigma_y = 30000$ psi [Yield Stress of Tank Shell Material] $h_c = 8.0$ in [Height of Chair] $E_s = 29 \cdot 10^6$ psi [Young's Modulus of Tank Shell Material]

Tank Foundation:

 $V_s = 1500$ ft/sec [Shear Wave Velocity of Supporting Soil]

Tank Content:

 $\rho_f = 0.0361$ lbf/in³ [Weight Density of Fluid in Tank] $H = 465$ in [Maximum Height of Fluid] $h_f = 15$ in [Freeboard Height]

Tank Anchorage Bolts:

 $N = 36$ [Number of Anchor Bolts] $d = 1.375$ in [Diameter of Anchor Bolt]

[Diameter of anchor bolt is reduced from 1.5" to 1.375" to obtain the allowable capacities from GIP Table C.3-1]

 $h_b = 46$ in [Effective Length of Anchor Bolt] $E_b = 30000000$ psi [Young's Modulus of Anchor Bolt]

Engineering Instruction No. 2



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 59 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED							WO.
ORIGINATOR S.J. Serhan							
DATE 01/18/94							

STEP 2 Ratios:

$$\text{HoverR} = \frac{H}{R}$$

$$\text{HoverR} = 2.771$$

$$\text{tsoverR} = \frac{ts}{R}$$

$$\text{tsoverR} = 0.002$$

$$i = 1..n$$

$$\text{tav} = \frac{\sum_i [t_i \cdot h_i]}{H_p}$$

$$\text{tav} = 0.263 \quad \text{in}$$

$$\text{tef} = \frac{\text{tav} + \text{tmin}}{2}$$

$$\text{tef} = 0.225 \quad \text{in}$$

$$\text{tefoverR} = \frac{\text{tef}}{R}$$

$$\text{tefoverR} = 0.001$$

$$A_b = \frac{\pi \cdot d^2}{4}$$

$$A_b = 1.485 \quad \text{in}^2$$

$$t_p = \left[\frac{N \cdot A_b}{2 \cdot \pi \cdot R} \right] \cdot \left[\frac{E_b}{E_s} \right]$$

$$t_p = 0.052 \quad \text{in}$$

$$c_p = \left[\frac{t_p}{t_s} \right] \cdot \left[\frac{h_c}{h_b} \right]$$

$$c_p = 0.024$$

$$W = \pi \cdot R^2 \cdot H \cdot \Gamma \phi$$

$$W = 1.485 \cdot 10^6 \quad \text{lbf}$$

Engineering Instruction No. 2



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 60 OF
REV.	0	1	2	3	PAGES 114	
MICROFILMED						WO.
ORIGINATOR S.J. Serhan						
DATE 01/18/94						

* Note to User:

Before proceeding to Step 2, confirm that the values listed and ratios calculated in Step 1 are within the applicable range of parameters documented in the scope of this seismic verification procedure.

Answer: Yes [Diameter of anchor bolt is reduced to 1.375" to obtain allowable capacities from Table C.3-1 of the PSP] ^{SJS} _{GIF 1-18-94}

STEP 3 Fluid-Structure Modal Frequency (Impulsive Frequency)

* Note to User:

Using the following parameters, enter Table 7-3 of the PSP Section 7 and obtain Ff in Hz:

$$R = 167.81 \text{ in}$$

$$tefoverR = 0.001$$

$$HoverR = 2.771$$

The following answer is provided by the user:


$$Ff = 5.74 \text{ Hz} \quad [\text{This frequency is for carbon steel tanks containing water}]$$

For tanks made of stainless steel or aluminum :

$$Ff = Ff \cdot \sqrt{\frac{0.0361}{\Gamma \phi}} \cdot \sqrt{\frac{Es}{30 \cdot 10^6}} \quad Ff = 5.644 \text{ Hz}$$

The Emergency Feedwater Tank is made of carbon steel, therefore

$$Ff = 5.74 \text{ Hz}$$

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 61 OF
	REV.	0	1	2	3		PAGES 114
	MICROFILMED						
	ORIGINATOR S.J. Serhan						WO.
	DATE 01/18/94						

STEP 4 Spectral Acceleration for Impulsive Frequency

* Note to User:

Using the 4% damped maximum horizontal ground or floor (whichever is applicable) acceleration response spectrum, determine the maximum spectral acceleration S_{af} over the frequency range $0.8 F_f < F < 1.2 F_f$.

For tanks with concrete pads founded on ground with a shear wave velocity less than 3500 ft/sec, the following is suggested in lieu of conducting soil/structure interaction analysis:

If F_f is less than the peak frequency of the maximum horizontal ground acceleration response spectrum, ignore soil/structure interaction effects.

Otherwise, use the peak spectral acceleration for S_{af} .

The following answer is provided by the user:

$S_{af} = 0.699 \quad g \quad (\text{Figure EFW07 of Reference 5})$

STEP 5 Base Shear Load

* Note to User:

Using the following parameters, enter Figure 7-3 of the PSP Section 7 and obtain the base shear load coefficient Q_p :

$H_{overR} = 2.771$

$t_{eoverR} = 0.001$


The following answer is provided by the user:

$Q_p = 0.735$

Therefore, the shear load at the base of the tank is equal to:

$Q = Q_p \cdot W \cdot S_{af} \quad Q = 7.63 \cdot 10^5 \quad \text{lb}_f$

Engineering Instruction No. 2

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 62 OF
	REV.	0	1	2	3		PAGES 114
	MICROFILMED						WO.
	ORIGINATOR S.J. Serhan						
DATE 01/18/94							

STEP 6 Base Overturning Moment

* Note to User:

Using the following parameters, enter Figure 7-4 of the PSP Section 7 and obtain the base overturning moment coefficient M_p :

$$\text{HoverR} = 2.771$$

$$\text{tefoverR} = 0.001$$

The following answer is provided by the user:

$$M_p = 0.393$$

Therefore, the overturning moment at the base of the tank is equal to:

$$M = M_p \cdot W \cdot H \cdot \text{Saf} \quad M = 1.897 \cdot 10^8 \quad \text{in-lbf}$$

STEP 7 Bolt Tensile Load Capacity

* Note to User:

Using Appendix C of the GIP [Reference 1], obtain anchor bolt tensile capacity P_u in lbf.


The following answer is provided by the user:

The EFT-2 Tank is anchored to its foundation by 36 1.375" ϕ cast-in-place bolts with end plate. The actual embedment length provided for the anchor bolt is

$$L = 39.0 \quad \text{in}$$

From Table C.3-1 of the GIP, $L_{\min} = 13.75 \quad \text{in}$

Engineering Instruction No. 2

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 63 OF
	REV.	0	1	2	3		PAGES 114
	MICROFILMED						
	ORIGINATOR S.J. Serhan						WO.
	DATE 01/18/94						

(Step 7 Continued)

Sinc $L_{min} < L$, the reduction factor for embedment is calculated as:

$$R_{embed} = 1.0$$

The pullout and shear capacity given in Table C.3-1 of the GIP [Reference 1] are based on f'_c of 3500 psi. Therefore, the reduction factor for f'_c of 3000 psi is calculated as:

$$R_{conc} = \sqrt{\frac{3000}{3500}} \quad R_{conc} = 0.926$$

Using Table C.3-1 of the GIP [Reference 1], the pullout capacity and shear capacity of a 1.375" $\#4$ anchor are:

$$P_{nom} = 50400 \quad \text{lbf}$$

$$V_{nom} = 25250 \quad \text{lbf}$$

Applying reduction factors

$$P_u = P_{nom} \cdot R_{embed} \cdot R_{conc} \quad P_u = 4.666 \cdot 10^4 \quad \text{lbs}$$

The allowable bolt stress is:

$$F_b = \frac{P_u}{A_b} \quad F_b = 3.142 \cdot 10^4 \quad \text{psi}$$

Engineering Instruction No. 2



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 64 OF	
RFV	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR S.J. Serhan							
DATE 01/18/94							

STEP 8 Top Plate of Anchor Bolt Chair

The dimensions f and c represent the length along the vertical stiffeners and thickness of the top plate, respectively. The dimension g represents the distance between the inner surfaces of the vertical stiffener plates.

- * The following dimensions f , c and g are provided by the user:

$$f = \frac{8 - d}{2} \quad f = 3.313 \quad \text{in}$$

$$c = 1.0 \quad \text{in}$$

$$g = 3.25 \quad \text{in}$$

The maximum bending stress in the top plate is calculated as:

$$\sigma = \frac{(0.375 \cdot g - 0.22 \cdot d) \cdot P_u}{f \cdot c^2}$$

$$\sigma = 1.291 \cdot 10^4 \quad \text{psi} < f_y = 3.6 \cdot 10^4$$

If the above relation is OK, there is no load reduction factor to be applied on the anchor bolt allowable tensile stress F_b . Otherwise, multiply F_b by the following reduction factor:

$$R_{\text{chair}} = \left[\frac{f_y}{\sigma} \right]$$

$$R_{\text{chair}} = 2.789 \quad (\text{Do not use if } > 1.0)$$

- * Answer by User:

$$R_{\text{chair}} = 1.0$$

$$\sigma = \sigma \cdot R_{\text{chair}} \quad \sigma = 1.291 \cdot 10^4 \quad \text{psi}$$

Engineering Instruction No. 2



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 65 OF	
REV.	0	1	2	3			
MICROFILMED						PAGES 14	
ORIGINATOR		S.J. Serhan				WO.	
DATE		01/18/94					

STEP 9 Tank Shell Stress

- * For the calculation of the tank shell stress, the following dimensions should be provided by the user:

$a = 8$ in [Width of chair top plate parallel to shell]

$e = 5.0$ in [Eccentricity of anchor bolt with respect to shell outside surface]

$t_b = 0.25$ in [Thickness of base plate of tank]

$h = 8$ in [Height of chair]

The maximum bending stress σ in the tank shell is:

$$Z = \frac{1.0}{\left[\frac{0.177 \cdot a \cdot t_b}{\sqrt{R \cdot t_s}} \cdot \left[\frac{t_b}{t_s} \right]^2 + 1.0 \right]}$$

$$\sigma = \left[\frac{P_u \cdot e}{t_s^2} \right] \cdot \left[\frac{1.32 \cdot Z}{\left[\frac{1.43 \cdot a \cdot h^2}{R \cdot t_s} \right] + \left[4 \cdot a \cdot h^2 \right]^{0.333}} + \frac{0.031}{\sqrt{R \cdot t_s}} \right]$$

$$\sigma = 9.485 \cdot 10^4 \text{ psi} < \sigma_{\psi} = 3 \cdot 10^4 \text{ psi}$$


If the above relation is OK, there is no load reduction factor to be applied on the anchor bolt allowable tensile stress F_b . Otherwise, multiply F_b by the following reduction factor:

$$R_{\text{shell}} = \left[\frac{\sigma_{\psi}}{\sigma} \right] \quad R_{\text{shell}} = 0.316 \quad (\text{Do not use if } > 1.0)$$

- * Answer by User:

$$F_r = F_b \cdot R_{\text{shell}} \quad F_r = 9.939 \cdot 10^3 \text{ psi}$$

Engineering Instruction No. 2

	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 66 OF
	REV.	0	1	2	3		PAGES 114
	MICROFILMED						WO.
	ORIGINATOR S.J. Serhan						
	DATE 01/18/94						

STEP 10 Vertical Stiffener Plates

- * The following dimensions are provided by the user:

$k = 5.0$ in [Average width of chair vertical stiffener plate]

$j = 0.5$ in [Thickness of chair vertical stiffener plate]

- * The user should check that the following four relations are satisfied:

$$\frac{k}{j} = 10 < \frac{95}{\sqrt{\frac{f_y}{1000}}} = 15.833$$

$$j = 0.5 > 0.04 \cdot (h - c) = 0.28 \text{ in}$$

$$j = 0.5 > 0.5 \text{ in (marginal, OK)}$$

$$\frac{P_u}{2 \cdot k \cdot j} = 9.332 \cdot 10^3 < 21000 \text{ psi}$$

If one or more of the above relations are not satisfied, consult applicable codes and standards for an appropriate reduction factor or consider the tank as an outlier.

Engineering Instruction No. 2



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 67 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR		S.J. Serhan					
DATE		01/18/94					

STEP 11 Chair-to-Tank Shell Weld

The required load per inch for the weld between the chair and tank shell is:

$$W_w = P_u \cdot \sqrt{\left[\frac{1}{a + 2 \cdot h} \right]^2 + \left[\frac{e}{a \cdot h + 0.667 \cdot h^2} \right]^2}$$


- * The user should provide thickness of leg of weld and check that the following relation is satisfied:

$$t_w = 0.25 \quad \text{in}$$

$$W_w = 2.926 \cdot 10^3 \quad < \text{ or } = \quad \frac{30600 \cdot t_w}{\sqrt{2}} = 5.409 \cdot 10^3$$

If the above relations are not satisfied, consult applicable codes and standards for an appropriate reduction factor or consider the tank as an outlier.

Engineering Instruction No. 2

 CALCULATION	SUBJECT			FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER	DC-5520-161.0SE		PAGE	68
	REV.	0	1	2	3	OF				
	MICROFILMED					PAGES 114				
	ORIGINATOR S.J. Serhan					WO.				
	DATE 01/18/94									

STEP 12 Fluid Pressure for Elephant-Foot Buckling

- * Using the following parameters, enter Figure 7-7 of the PSP Section 7 and obtain the fluid pressure coefficient Pep for elephant-foot buckling:

$$Saf = 0.699 \quad g$$

$$HoverR = 2.771$$

The following answer is provided by the user:

$$Pep = 3.95$$

Based on the value of Pep , the fluid pressure at the base of the tank for elephant-foot buckling is:

$$Pe = Pep \cdot \phi \cdot R$$

$$Pe = 23.929 \quad \text{psi}$$



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 69 OF
REV.	0	1	2	3	PAGES 114	
MICROFILMED						WO.
ORIGINATOR S.J. Serhan						
DATE 01/18/94						

STEP 13 Elephant-Foot Buckling Stress Capacity Factor

- * Using the following parameters, enter Figure 7-8 of the PSP Section 7 and obtain the fluid pressure coefficient P_{ep} for elephant-foot buckling:

$$P_e = 23.929$$

$$t_{\text{soverR}} = 0.002$$

The following answer is provided by the user:

$$\sigma_{TE} = 19.0 \quad \text{ksi}$$

$$\sigma_{TE} = \sigma_{TE} \cdot 1000 \quad \sigma_{TE} = 1.9 \cdot 10^4 \quad \text{psi}$$

For tanks made of stainless steel or aluminum,


$$S1 = \frac{R}{400 \cdot t_s}$$

$$S2 = \frac{S1 + \left[\frac{\sigma_{\psi}}{36000} \right]}{S1 + 1}$$

$$\sigma_{TE} = \frac{0.6 \cdot E_s}{\frac{R}{t_s}} \cdot \left[1 - \left[\frac{P_e \cdot R}{\sigma_{\psi} \cdot t_s} \right]^2 \right] \cdot \left[1 - \left[\frac{1}{1.12 + S1^{1.5}} \right] \right] \cdot S2$$

$$\sigma_{TE} = 1.769 \cdot 10^4 \quad \text{psi}$$

For Emergency Feedwater Tank, $\sigma_{TE} = 1.9 \cdot 10^4 \quad \text{psi}$

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 70 OF
	REV.	0	1	2	3	PAGES 114	
	MICROFILMED						
	ORIGINATOR S.J. Serhan						
DATE 01/18/94							WO.

STEP 14 Fluid Pressure for Diamond-Shape Buckling

- * Using the following parameters, enter Figure 7-9 of the PSP Section 7 and obtain the pressure coefficient P_{dp} for diamond-shape buckling:

$$Saf = 0.699 \text{ g}$$

$$HoverR = 2.771$$


The following answer is provided by the user:

$$P_{dp} = 3.1$$

Based on the value of P_{dp} , the fluid pressure at the base of the tank for diamond-shape buckling is:

$$P_d = P_{dp} \cdot \rho \cdot R$$

$$P_d = 18.78 \text{ psi}$$

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 71 OF
	REV.	0	1	2	3		PAGES 14
	MICROFILMED						WO.
	ORIGINATOR S.J. Serhan						
	DATE 01/18/94						

STEP 15 Diamond-Shape Buckling Stress Capacity Factor

- * Using the following parameters, enter Figure 7-10 of the PSP Section 7 and obtain the stress capacity factor ϕ_d for diamond-shape buckling:

$$P_d = 18.78 \quad \text{psi}$$

$$t_{\text{overR}} = 0.002$$

The following answer is provided by the user:

$$\sigma_{\phi d} = 23.0 \quad \text{ksi}$$

$$\sigma_{\phi d} = \sigma_{\phi d} \cdot 1000 \quad \sigma_{\phi d} = 23 \cdot 10^4 \quad \text{psi}$$

This value of ϕ_d is for carbon steel. For tanks made of stainless steel or aluminum, the following procedure is applied:

- * Using the following parameter, enter Figure 7-11 of the GIP Section 7, obtain $\delta\Gamma$, and calculate ϕ_d :


$$\frac{P_d}{E_s} \cdot \left[\frac{R}{ts} \right]^2 = 0.13 \quad \delta\Gamma = 0.09 \quad [\text{Figure 7-11}]$$

$$\phi = \frac{1}{16} \cdot \sqrt{\left[\frac{R}{ts} \right]} \quad \Gamma = 1 - 0.73 \cdot [1 - \exp(-\phi)]$$

$$\sigma_{\phi d} = \left[0.6 \cdot \Gamma + \delta\Gamma \right] \cdot \left[\frac{E_s}{R} \right] \quad \sigma_{\phi d} = 239 \cdot 10^4 \quad \text{psi}$$

$$\text{For Emergency Feedwater Tank, } \sigma_{\phi d} = 23 \cdot 10^4 \quad \text{psi}$$

Engineering Instruction No. 2

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 72
	REV.	0	1	2	3		OF
	MICROFILMED						PAGES 114
	ORIGINATOR S.J. Serhan						WO.
DATE 01/18/94							

STEP 16 Allowable Buckling Stress

The allowable buckling stress σ_c is calculated as 72% of the lower value of σ_{pe} or σ_{pd} .


$$iii = 0..1$$

$$\sigma_{\pi_0} = \sigma_{\pi e} \quad \sigma_{\pi_0} = 1.9 \cdot 10^4 \quad \text{psi}$$

$$\sigma_{\pi_1} = \sigma_{\pi d} \quad \sigma_{\pi_1} = 2.3 \cdot 10^4 \quad \text{psi}$$

$$\sigma_{\chi} = 0.72 \cdot \min(\sigma_{\pi})$$

$$\sigma_{\chi} = 1.368 \cdot 10^4 \quad \text{psi}$$

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 73 OF
	REV.	0	1	2	3		PAGES 114
	MICROFILMED						WO.
	ORIGINATOR S.J. Serhan						
DATE 01/18/94							

STEP 17 Overturning Capacity of Tank

Ductile Failure:

Ductile failure modes are

Anchor bolt stretching (Step 7)

Chair top plate bending (Step 8)

Tank shell bending (Step 9)

Using the following parameters, enter Figure 7-12 of the PSP Section 7, and obtain the base overturning moment coefficient M_{capp} :

$$c_p = 0.024$$

$$\frac{\sigma_x}{F_r} \cdot \frac{h_c}{h_b} = 0.239$$

$$M_{capp} = 0.07 \quad [\text{Figure 7-12}]$$

The base overturning moment is:

$$M_{capDUCT} = M_{capp} \cdot (2 \cdot F_r) \cdot \left[R^2 \cdot t_s \right] \cdot \left[\frac{h_b}{h_c} \right]$$

$$M_{capDUCT} = 8.449 \cdot 10^7 \quad \text{in-lbf}$$

Engineering Instruction No. 2



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 74 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR		S.J. Serhan					
DATE		01/18/94					

STEP 17 Continued

Brittle Failure:

Brittle failure modes are

Concrete cone failure (Step 7)

Chair stiffener plate shear or buckling failure (Step 10)

Chair-to-tank wall weld shear failure (Step 11)

Using the following parameters, enter Table 7-4 of the PSP Section 7, and obtain the base overturning moment coefficient Mcapp:


$$c_p = 0.024$$

$$M_{capp} = 0.056 \quad [\text{Table 7-4}]$$

The base overturning moment is:

$$M_{capBRIT} = M_{capp} \cdot (2 \cdot Fr) \cdot R^2 \cdot t_s \cdot \left[\frac{hb}{hc} \right]$$

$$M_{capBRIT} = 6.759 \cdot 10^7 \quad \text{in-lbf}$$

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 75
	REV.	0	1	2	3		OF
	MICROFILMED						PAGES 114
	ORIGINATOR S.J. Serhan						WO.
	DATE 01/18/94						

STEP 18 Capacit vs. Demand for Base Overturning Moment

- * If the expected failure mode is ductile, the user should select the McapDUCT for use as Mcap. However, if the expected failure mode is brittle, the user should select the lower of McapDUCT and McapBRIT for use as Mcap.

For the Emergency Feedwater Tank, the expected failure mode is ductile (Step 9). Therefore,

$$M_{cap} = M_{capDUCT}$$

$$M_{cap} = 8.449 \cdot 10^7 \text{ in-lbf}$$

VERIFIER COMMENT:

WALL BENDING → STEP 9 OK

The base overturning moment demand is determined from Step 6 and it is equal to:

$$M = 1.897 \cdot 10^8 \text{ in-lbf}$$

- * The user should check that the following relation is satisfied:

$$M_{cap} = 8.449 \cdot 10^7 > \text{or} = M = 1.897 \cdot 10^8 \text{ [NG]}$$

Engineering Instruction No. 2



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 76 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR		S.J. Serhan					
DATE		01/18/94					

STEP 19 Base Shear Load Capacity

The base shear load capacity is determined as:


$$Q_{cap} = 0.55 \cdot (1 - 0.218 \cdot S_{af}) \cdot W$$

$$Q_{cap} = 6.923 \cdot 10^5 \quad \text{lbf}$$

STEP 20 Capacity vs. Demand for Base Shear

* The user should check that the following relation is satisfied:

$$Q_{cap} = 6.923 \cdot 10^5 \quad > \text{ or } = \quad Q = 7.63 \cdot 10^5 \quad [\text{NG}]$$

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 77
	REV.	0	1	2	3		OF
	MICROFILMED						PAGES 114
	ORIGINATOR S.J. Serhan						WO.
DATE 01/18/94							

STEP 21 Slosh Height

G = 386.4 in/sec/sec [Acceleration of Gravity]

The sloshing mode frequency is:

$$F_s = \frac{1}{2\pi} \sqrt{\frac{1.84 \cdot G}{R} \cdot \tanh\left[\frac{1.84 \cdot H}{R}\right]} \quad F_s = 0.328 \quad \text{Hz}$$

* Note to User:

Using the 1/2% damped maximum horizontal ground or floor (whichever is applicable) acceleration response spectrum, determine the spectral acceleration S_{as} at frequency = F_s .

$S_{as} = 0.1 \quad g$ (estimated from Figure EFW07 of Reference 5)

The slosh height is:

$$h_s = 0.837 \cdot R \cdot S_{as} \quad h_s = 14.046 \quad \text{in}$$


STEP 22 Freeboard Clearance vs. Slosh Height

* The user should check that the following relation is satisfied:

$$h_f = 15 \quad > \text{ or } = \quad h_s = 14.046 \quad \text{OK}$$

CONCLUSION: Tank under evaluation is an outlier per PSP Section 7 seismic verification procedure due to base shear and overturning moment.

Engineering Instruction No. 2

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 78 OF
	REV.	0	1	2	3		PAGES 114
	MICROFILMED						WO.
	ORIGINATOR S.J. Serhan						
	DATE 01/18/94						

7. **BORATED WATER TANK**

The following pages document the seismic verification of the Borated Water Tank by using the PSP Section 7 Methodology [Reference 4].



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 79 OF 114	
REV.	0	1	2	3	PAGES 114		
MICROFILMED				WO.			
ORIGINATOR S.J. Serhan							
DATE 01/18/94							

FPC- Crystal River Unit 3

USI A-46 Project

Tanks Evaluation

Tank: Borated Water Tank [DHT]

Originator: Samir J. Serhan 10/08/1993

Reviewer: Gary M. Jackson

Program Name: TANKv2

Dr. Samir J. Serhan
 Gilbert/Commonwealth, Inc.
 April 5, 1993

SEISMIC VERIFICATION OF VERTICAL TANKS

Scope:

This seismic verification procedure is applicable to tanks with the following characteristics:

- (a) Large cylindrical tanks,
- (b) Axis of symmetry is vertical,
- (c) Flat bottom,
- (d) Anchored to concrete pads or building floor,
- (e) Tank material is carbon steel (ASTM A36 or A283 Grade C), stainless steel (ASTM A240 Type 304), aluminum (various alloys), or better material,
- (f) Anchor bolts are evenly spaced around tank circumference within + or - 5 degrees,
- (g) Anchor bolts are cast-in-place or J-bolts (ASTM A36 or A307, A325),
- (h) Fluid in tank is water or similar material, and
- (i) Dimensions for tank shell, anchorage, and content should fall within the following range of parameters:

[See the following page]

Engineering Instruction No. 2



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 80 OF	
REV.	0	1	2	3	PAGES 14		
MICROFILMED						WO.	
ORIGINATOR S.J. Serhan							
DATE 01/18/94							

Nominal Radius (R):	60" to 420"
Height of Tank Shell (Hp):	120" to 960"
Maximum Height of Fluid (H):	120" to 960"
Minimum Thickness of Tank Shell in the lowest 10% of Hp (ts):	0.1875" to 1.0"
Effective Thickness of Tank Shell [(tav+tmin)/2] (tef):	0.1875" to 1.0"
Diameter of Anchor Bolt (d):	0.5" to 2.0"
Number of anchor bolts (N):	8 or more
Ratio of Thickness of Wall ts to Radius of Tank (ts/R):	0.001 to 0.01
Ratio of Thickness of Wall tef to Radius of Tank (tef/R):	0.001 to 0.01
Ratio of Maximum Height of Fluid to Radius of Tank (H/R):	1.0 to 5.0

Engineering Instruction No. 2



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 81 OF 114	
REV.	0	1	2	3	PAGES 114		
MICROFILMED				WO.			
ORIGINATOR S.J. Serhan							
DATE 01/18/94							

Evaluation Process:

Per the PSP Section 7 [4], the seismic verification for vertical tanks consists of the following 23 steps:

* STEP 1 INPUT DATA to be provided by the user

Tank Shell:

$R = 240.21$ in [Nominal Radius of Tank]
 $H_p = 564$ in [Height of Tank Shell]
 $t_{min} = 0.25$ in [Minimum Shell Thickness]
 $t_s = 0.421$ in [Minimum Shell Thickness in lowest 10% H_p]
 $n = 5$ [Variation of Shell Thickness Along Height]
 $h_1 = 94$ in $t_1 = 0.421$ in
 $h_2 = 94$ in $t_2 = 0.3683$ in
 $h_3 = 94$ in $t_3 = 0.3158$ in
 $h_4 = 94$ in $t_4 = 0.2634$ in
 $h_5 = 188$ in $t_5 = 0.25$ in



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 82 CF
REV.	0	1	2	3	PAGES 114	
MICROFILMED						WO.
ORIGINATOR S.J. Serhan						
DATE 01/18/94						

(Step 1 Continued)

$\sigma_y = 30000$ psi [Yield Stress of Tank Shell Material]
 $h_c = 27.75$ in [Height of Chair]
 $E_s = 29 \cdot 10^6$ psi [Young's Modulus of Tank Shell Material]

Tank Foundation:

$V_s = 5000$ ft/sec [Shear Wave Velocity of Supporting Soil]
 [Tank is supported on concrete floor, Auxiliary Bldg. Elev. 119']

Tank Content:

$\Gamma_f = 0.0361$ lbf/in³ [Weight Density of Fluid in Tank]
 $H = 573.6$ in [Maximum Height of Fluid]
 $h_f = 0$ in [Freeboard Height]

Tank Anchorage Bolts:

$N = 32$ [Number of Anchor Bolts]
 $d = 1.375$ in [Diameter of Anchor Bolt]
 [Diameter of anchor bolt is reduced from 2.5" to 1.375" to satisfy the applicable range of parameters and to obtain the allowable capacities from GIP Table C.4-1]
 $h_b = 120.75$ in [Effective Length of Anchor Bolt]
 $E_b = 30000000$ psi [Young's Modulus of Anchor Bolt]

SEE VERIFIER
COMMENT - 2

* THIS IS CONSERVATIVE.

Engineering Instruction No. 2



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 83 OF	
REV.	0	1	2	3			
MICROFILMED							
ORIGINATOR S.J. Serhan							
DATE 01/18/94							
				PAGES 114			
				WO.			

STEP 2 Ratios:

$$\text{HoverR} = \frac{H}{R}$$

$$\text{HoverR} = 2.388$$

$$\text{tsoverR} = \frac{ts}{R}$$

$$\text{tsoverR} = 0.002$$

$$i = 1 \dots n$$

$$\text{tav} = \frac{\sum_i [t_i \cdot h_i]}{H_p}$$

$$\text{tav} = 0.311 \quad \text{in}$$

$$\text{tef} = \frac{\text{tav} + t_{\min}}{2}$$

$$\text{tef} = 0.281 \quad \text{in}$$

$$\text{tefoverR} = \frac{\text{tef}}{R}$$

$$\text{tefoverR} = 0.001$$

$$A_b = \frac{\pi \cdot d^2}{4}$$

$$A_b = 1.485 \quad \text{in}^2$$

$$t_p = \left[\frac{N \cdot A_b}{2 \cdot \pi \cdot R} \right] \cdot \left[\frac{E_b}{E_s} \right]$$

$$t_p = 0.033 \quad \text{in}$$

$$c_p = \left[\frac{t_p}{ts} \right] \cdot \left[\frac{hc}{hb} \right]$$

$$c_p = 0.018$$

$$W = \pi \cdot R^2 \cdot H \cdot \Gamma \phi$$

$$W = 3.754 \cdot 10^6 \quad \text{lb} \cdot \text{ft}$$

Engineering Instruction No. 2



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 84	
REV.	0	1	2	3	OF		
MICROFILMED						PAGES 114	
ORIGINATOR S.J. Serhan						WO.	
DATE 01/18/94							

* Note to User:

Before proceeding to Step 2, confirm that the values listed and ratios calculated in Step 1 are within the applicable range of parameters documented in the scope of this seismic verification procedure.

Answer: Yes [Diameter of anchor bolt is reduced to 1.375" to satisfy the applicable range of parameters and to obtain allowable capacities from Table C.4-1]

STEP 3 Fluid-Structure Modal Frequency (Impulsive Frequency)

* Note to User:

Using the following parameters, enter Table 7-3 of the PSP Section 7 and obtain Ff in Hz:

$$R = 240.21 \text{ in}$$

$$tefoverR = 0.001$$

$$HoverR = 2.388$$

The following answer is provided by the user:

$$Ff = 4.8 \text{ Hz} \quad [\text{This frequency is for carbon steel tanks containing water}]$$

For tanks made of stainless steel or aluminum :

$$Ff = Ff \cdot \sqrt{\frac{0.0361}{\Gamma \phi}} \cdot \sqrt{\frac{Es}{30 \cdot 10^6}} \quad Ff = 4.719 \text{ Hz}$$

The Borated Water Tank is made of stainless steel, therefore

$$Ff = 4.719 \text{ Hz}$$



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 85 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR		S.J. Serhan					
DATE		01/18/94					

STEP 4 Spectral Acceleration for Impulsive Frequency

* Note to User:

Using the 4% damped maximum horizontal ground or floor (whichever is applicable) acceleration response spectrum, determine the maximum spectral acceleration S_{af} over the frequency range $0.8 F_f < F < 1.2 F_f$.

For tanks with concrete pads founded on ground with a shear wave velocity less than 3500 ft/sec, the following is suggested in lieu of conducting soil/structure interaction analysis:

If F_f is less than the peak frequency of the maximum horizontal ground acceleration response spectrum, ignore soil/structure interaction effects.

Otherwise, use the peak spectral acceleration for S_{af} .

The following answer is provided by the user:

$S_{af} = 0.18 \quad g \quad (\text{page 28: } 2 \times 0.09)$

STEP 5 Base Shear Load

* Note to User:

Using the following parameters, enter Figure 7-3 of the PSP Section 7 and obtain the base shear load coefficient Q_p :

$H_{overR} = 2388$


$t_{eoverR} = 0.001$

The following answer is provided by the user:

$Q_p = 0.733$

Therefore, the shear load at the base of the tank is equal to:

$Q = Q_p \cdot W \cdot S_{af} \quad Q = 4.953 \cdot 10^5 \quad \text{lb}$

 CALCULATION	SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER	DC-5520-161.0SE	PAGE	86
	REV.	0	1	2	3		OF	
	MICROFILMED						PAGES	114
	ORIGINATOR						WO.	
	DATE							

STEP 6 Base Overturning Moment

* Note to User:

Using the following parameters, enter Figure 7-4 of the PSP Section 7 and obtain the base overturning moment coefficient M_p :

$$\text{HoverR} = 2.388$$

$$\text{tefoverR} = 0.001$$

The following answer is provided by the user:

$$M_p = 0.382$$

Therefore, the overturning moment at the base of the tank is equal to:

$$M = M_p \cdot W \cdot H \cdot \text{Saf} \quad M = 1.48 \cdot 10^8 \quad \text{in-lbf}$$

STEP 7 Bolt Tensile Load Capacity

* Note to User:

Using Appendix C of the GIP, obtain anchor bolt tensile capacity P_u in lbf.

The following answer is provided by the user:

The Borated Water Tank is anchored to its foundation by 32 2.0" \pm cast-in-place J bolts with 90-degree hooks. The minimum bend radius is 4 \times , and the minimum straight extension of the hook is also 4 \times . The corresponding values for the Borated Water Tank are 0.5 \times and 3 \times , respectively. As a conservative assumption, the length of the hook will not be included in the embedment length. The actual embedment length provided for the anchor bolt is

$$L = 92.75 \quad \text{in}$$

From Table C.4-1 of the GIP, $L_{\min} = 75.0 \quad \text{in}$



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 87 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR		S.J. Serhan					
DATE		01/18/94					

(Step 7 Continued)

Since $L_{min} < L$, the reduction factor for embedment is calculated as:

$$R_{embed} = 1.0$$

The pullout and shear capacity given in Table C.4-1 of the GIP are based on f'_c of 3500 psi. Therefore, the reduction factor for f'_c of 3000 psi is calculated as:

$$R_{conc} = \sqrt{\frac{3000}{3500}} \quad R_{conc} = 0.926$$

Using Table C.4-1 of the GIP, the pullout capacity and shear capacity of a 1.375" anchor are:

$$P_{nom} = 50400 \quad \text{lbf}$$

$$V_{nom} = 25250 \quad \text{lbf}$$

Applying reduction factors

$$P_u = P_{nom} \cdot R_{embed} \cdot R_{conc} \quad P_u = 4.666 \cdot 10^4 \quad \text{lbs}$$

The allowable bolt stress is:

$$F_b = \frac{P_u}{A_b} \quad F_b = 3.142 \cdot 10^4 \quad \text{psi}$$



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 88
REV.	0	1	2	3		OF
MICROFILMED						PAGES 114
ORIGINATOR S.J. Serhan						WO.
DATE 01/18/94						

STEP 8 Top Plate of Anchor Bolt Chair

The dimensions f and c represent the length along the vertical stiffeners and thickness of the top plate, respectively. The dimension g represents the distance between the inner surfaces of the vertical stiffener plates.

- * The following dimensions f , c and g are provided by the user:

$$f = \frac{7.5 - d}{2} \quad f = 3.063 \quad \text{in}$$

$$c = 1.5 \quad \text{in}$$

$$g = 3 \quad \text{in}$$

The maximum bending stress in the top plate is calculated as:

$$\sigma = \frac{(0.375 \cdot g - 0.22 \cdot d) \cdot P_u}{f \cdot c^2}$$

$$\sigma = 5.57 \cdot 10^3 \quad \text{psi} < f_y = 3.6 \cdot 10^4$$

If the above relation is OK, there is no load reduction factor to be applied on the anchor bolt allowable tensile stress F_b . Otherwise, multiply F_b by the following reduction factor:

$$R_{\text{chair}} = \left[\frac{f_y}{\sigma} \right]$$

$$R_{\text{chair}} = 6.464 \quad (\text{Do not use if } > 1.0)$$

- * Answer by User:

$$R_{\text{chair}} = 1.0$$

$$\sigma = \sigma \cdot R_{\text{chair}} \quad \sigma = 5.57 \cdot 10^3 \quad \text{psi}$$



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 89 OF
REV.	0	1	2	3		PAGES 114
MICROFILMED						WO.
ORIGINATOR S.J. Serhan						
DATE 01/18/94						

STEP 9 Tank Shell Stress

- * For the calculation of the tank shell stress, the following dimensions should be provided by the user:

a = 5 in [Width of chair top plate parallel to shell]

e = 3.56 in [Eccentricity of anchor bolt with respect to shell outside surface]

tb = 0.25 in [Thickness of base plate of tank]

h = 28.5 in [Height of chair]

The maximum bending stress σ in the tank shell is:

$$Z = \frac{1.0}{\left[\frac{0.177 \cdot a \cdot tb}{\sqrt{R \cdot ts}} \cdot \left[\left(\frac{tb}{ts} \right)^2 \right] + 1.0 \right]}$$

$$\sigma = \left[\frac{Pu \cdot e}{ts^2} \right] \cdot \left[\frac{1.32 \cdot Z}{\left[\frac{1.43 \cdot a \cdot h^2}{R \cdot ts} \right] + \left[4 \cdot a \cdot h^2 \right]^{0.333}} + \frac{0.031}{\sqrt{R \cdot ts}} \right]$$

$$\sigma = 1.774 \cdot 10^4 \text{ psi} < \sigma_{\psi} = 3 \cdot 10^4 \text{ psi}$$

If the above relation is OK, there is no load reduction factor to be applied on the anchor bolt allowable tensile stress F_b . Otherwise, multiply F_b by the following reduction factor:

$$R_{\text{shell}} = \left[\frac{\sigma_{\psi}}{\sigma} \right] \quad R_{\text{shell}} = 1.691 \quad (\text{Do not use if } > 1.0)$$

- * Answer by User:

$$R_{\text{shell}} = 1.0$$

$$F_r = F_b \cdot R_{\text{shell}} \quad F_r = 3.142 \cdot 10^4 \text{ psi}$$

Engineering Instruction No. 2



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 90	
REV	0	1	2	3	OF		
MICROFILMED						PAGES 114	
ORIGINATOR S.J. Serhan						WO.	
DATE 01/18/94							

STEP 10 Vertical Stiffener Plates

- * The following dimensions are provided by the user:

$k = 5.25$ in [Average width of chair vertical stiffener plate]

$j = 1.0$ in [Thickness of chair vertical stiffener plate]

- * The user should check that the following four relations are satisfied:


$$\frac{k}{j} = 5.25 < \frac{95}{\sqrt{\frac{f_y}{1000}}} = 15.833$$

$$j = 1 > 0.04 \cdot (h - c) = 1.08 \text{ in} \\ (\text{marginal, OK})$$

$$j = 1 > 0.5 \text{ in}$$

$$\frac{P_u}{2 \cdot k \cdot j} = 4.444 \cdot 10^3 < 21000 \text{ psi}$$

If one or more of the above relations are not satisfied, consult applicable codes and standards for an appropriate reduction factor or consider the tank as an outlier.

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 91
	REV.	0	1	2	3	OF	
	MICROFILMED						PAGES 114
	ORIGINATOR S.J. Serhan						WO.
DATE		01/18/94					

STEP 11 Chair-to-Tank Shell Weld

The required load per inch for the weld between the chair and tank shell is:


$$W_w = P_u \cdot \sqrt{\left[\frac{1}{a + 2 \cdot h} \right]^2 + \left[\frac{e}{a \cdot h + 0.667 \cdot h^2} \right]^2}$$

- * The user should provide thickness of leg of weld and check that the following relation is satisfied:

$$t_w = 0.25 \quad \text{in}$$

$$W_w = 790.786 < \text{or} = \frac{30600 \cdot t_w}{\sqrt{2}} = 5.409 \cdot 10^3$$

If the above relations are not satisfied, consult applicable codes and standards for an appropriate reduction factor or consider the tank as an outlier.

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 92
	REV.	0	1	2	3		OF
	MICROFILMED						PAGES 114
	ORIGINATOR S.J. Serhan						WO.
DATE 01/18/94							

STEP 12 Fluid Pressure for Elephant-Foot Buckling

- * Using the following parameters, enter Figure 7-7 of the PSP Section 7 and obtain the fluid pressure coefficient Pep for elephant-foot buckling:

$$Saf = 0.18 \quad g$$

$$HoverR = 2388$$

The following answer is provided by the user:

$$Pep = 2.7$$

Based on the value of $P.p$, the fluid pressure at the base of the tank for elephant-foot buckling is:

$$Pe = Pep \cdot F \cdot R$$

$$Pe = 23.413 \quad \text{psi}$$



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 93	
REV.	0	1	2	3	OF		
MICROFILMED						PAGES 114	
ORIGINATOR		S.J. Serhan				WO.	
DATE		01/18/94					

STEP 13 Elephant-Foot Buckling Stress Capacity Factor

- * Using the following parameters, enter Figure 7-8 of the PSP Section 7 and obtain the fluid pressure coefficient P_{ep} for elephant-foot buckling:

$$P_e = 23.413$$

$$t_{\text{sover}R} = 0.002$$

The following answer is provided by the user for tanks made of Carbon Steel:

$$\sigma_{TE} = 19 \quad \text{ksi}$$

$$\sigma_{TE} = \sigma_{TE} \cdot 1000 \quad \sigma_{TE} = 1.9 \cdot 10^4 \quad \text{psi}$$

For tanks made of stainless steel or aluminum, the following procedure applies:

$$S1 = \frac{R}{400 \cdot ts}$$

$$S2 = \frac{S1 + \left[\frac{\sigma_{\psi}}{36000} \right]}{S1 + 1}$$

$$\sigma_{TE} = \frac{0.6 \cdot E_s}{\frac{R}{ts}} \cdot \left[1 - \left[\frac{P_e \cdot R}{\sigma_{\psi} \cdot ts} \right]^2 \right] \cdot \left[1 - \left[\frac{1}{1.12 + S1^{1.5}} \right] \right] \cdot S2$$

$$\sigma_{TE} = 1.471 \cdot 10^4 \quad \text{psi}$$

For the Borated Water Tank, $\sigma_{TE} = 1.471 \cdot 10^4 \quad \text{psi}$

Engineering Instruction No. 2



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 94	
REV.	0	1	2	3	OF		
MICROFILMED						PAGES 114	
ORIGINATOR S.J. Serhan						WO.	
DATE 01/18/94							

STEP 14 Fluid Pressure for Diamond-Shape Buckling

- * Using the following parameters, enter Figure 7-9 of the PSP Section 7 and obtain the pressure coefficient P_{dp} for diamond-shape buckling:

$$S_{af} = 0.18 \quad g$$

$$H_{overR} = 2.388$$

The following answer is provided by the user:

$$P_{dp} = 2.5$$

Based on the value of P_{dp} , the fluid pressure at the base of the tank for diamond-shape buckling is:

$$P_d = P_{dp} \cdot \Gamma \cdot R$$

$$P_d = 21.679 \quad \text{psi}$$



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 95 OF
REV.	0	1	2	3		PAGES 114
MICROFILMED						WO.
ORIGINATOR S.J. Serhan						
DATE 01/18/94						

STEP 15 Diamond-Shape Buckling Stress Capacity Factor

- * Using the following parameters, enter Figure 7-10 of the PSP Section 7 and obtain the stress capacity factor ϕ_d for diamond-shape buckling:

$$P_d = 21.679 \quad \text{psi}$$

$$t_{\text{soverR}} = 0.002$$

The following answer is provided by the user:

$$\sigma_{\bar{d}} = 23.5 \quad \text{ksi}$$

$$\sigma_{\bar{d}} = \sigma_{\bar{d}} \cdot 1000 \quad \sigma_{\bar{d}} = 235 \cdot 10^4 \quad \text{psi}$$

This value of ϕ_d is for carbon steel. For tanks made of stainless steel or aluminum, the following procedure is applied:

- * Using the following parameter, enter Figure 7-11 of the PSP Section 7, obtain $\bar{\sigma}$, and calculate ϕ_d :


$$\frac{P_d}{E_s} \cdot \left[\frac{R}{t_s} \right]^2 = 0.243 \quad \delta \Gamma = 0.09 \quad [\text{Figure 7-11}]$$

$$\phi = \frac{1}{16} \cdot \sqrt{\left[\frac{R}{t_s} \right]} \quad \Gamma = 1 - 0.73 \cdot [1 \cdot \exp(-\phi)]$$

$$\sigma_{\bar{d}} = \left[0.6 \cdot \Gamma + \delta \right] \cdot \left[\frac{E_s}{R/t_s} \right] \quad \sigma_{\bar{d}} = 1.781 \cdot 10^4 \quad \text{psi}$$

For the Borated Water Tank, $\sigma_{\bar{d}} = 1.781 \cdot 10^4 \quad \text{psi}$

Engineering Instruction No. 2

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 96 OF
	REV.	0	1	2	3	PAGES 114	
	MICROFILMED						WO.
	ORIGINATOR S.J. Serhan						
DATE 01/18/94							

STEP 16 Allowable Buckling Stress

The allowable buckling stress σ_c is calculated as 72% of the lower value of σ_{pe} or σ_{pd} .

$$\lambda = 0.1$$

$$\sigma_{\pi_0} = \sigma_{\pi_e} \quad \sigma_{\pi_0} = 1.471 \cdot 10^4 \quad \text{psi}$$

$$\sigma_{\pi_1} = \sigma_{\pi_0} \quad \sigma_{\pi_1} = 1.781 \cdot 10^4 \quad \text{psi}$$

$$\sigma_\chi = 0.72 \cdot \min(\sigma_\pi)$$

$$\sigma_\chi = 1.059 \cdot 10^4 \quad \text{psi}$$



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 97	
REV.	0	1	2	3	OF		
MICROFILMED						PAGES 114	
ORIGINATOR S.J. Serhan						WO.	
DATE 01/18/94							

STEP 17 Overturning Capacity of Tank

Ductile Failure:

Ductile failure modes are

- Anchor bolt stretching (Step 7)
- Chair top plate bending (Step 8)
- Tank shell bending (Step 9)

Using the following parameters, enter Figure 7-12 of the PSP Section 7, and obtain the base overturning moment coefficient Mcapp:

$$c_p = 0.018$$

$$\frac{\sigma_1}{F_r} \cdot \frac{h_c}{h_b} = 0.077$$

$$M_{capp} = 0.08 \quad [\text{Figure 7-12}]$$

The base overturning moment is:

[User Note: Use the smaller value of Fb or FR from Steps 7, 8, 9, 10, or 11]

$$M_{capDUCT} = M_{capp} \cdot (2 \cdot F_r) \cdot \left[R^2 \cdot t_s \right] \cdot \left[\frac{h_b}{h_c} \right]$$

$$M_{capDUCT} = 5.315 \cdot 10^8 \quad \text{in-lbf}$$



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 98	
REV.	0	1	2	3	OF		
MICROFILMED						PAGES 114	
ORIGINATOR		S.J. Serhan				WO.	
DATE		01/18/94					

STEP 17 Continued

Brittle Failure:

Brittle failure modes are

Concrete cone failure (Step 7)

Chair stiffener plate shear or buckling failure (Step 10)

Chair-to-tank wall weld shear failure (Step 11)

Using the following parameters, enter Table 7-4 of the PSP Section 7, and obtain the base overturning moment coefficient M_{capp} :

$$c_p = 0.018$$


$$M_{capp} = 0.041 \quad [\text{Table 7-4}]$$

The base overturning moment is:

$$M_{capBRIT} = M_{capp} \cdot (2 \cdot Fr) \cdot \left[R^2 \cdot t_s \right] \cdot \left[\frac{hb}{hc} \right]$$

$$M_{capBRIT} = 2.724 \cdot 10^8 \quad \text{in-lbf}$$

Engineering Instruction No. 2

 CALCULATION	SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER	DC-5520-161.0SE	PAGE	99
	REV.		0	1	2	3	OF	
	MICROFILMED						PAGES	114
	ORIGINATOR		S.J. Serhan				WO.	
	DATE		01/18/94					

STEP 18 Capacit vs. Demand for Base Overturning Moment

- * If the expected failure mode is ductile, the user should select the McapDUCT for use as Mcap. However, if the expected failure mode is brittle, the user should select the lower of McapDUCT and McapBRIT for use as Mcap.

For the Borated Water Tank, the expected failure mode is brittle (90-degree hook does not meet requirements).
Therefore,

$$M_{cap} = M_{capBRIT}$$

$$M_{cap} = 2.724 \cdot 10^8 \quad \text{in-lbf}$$


The base overturning moment demand is determined from Step 6 and it is equal to:

$$M = 1.48 \cdot 10^8 \quad \text{in-lbf}$$

- * The user should check that the following relation is satisfied:

$$M_{cap} = 2.724 \cdot 10^8 \quad > \text{ or } = \quad M = 1.48 \cdot 10^8 \quad [\text{OK}]$$

Engineering Instruction No. 2

	SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 100 OF
	REV.	0	1	2	3	PAGES 114	
	MICROFILMED						WO.
	ORIGINATOR		S.J. Serhan				
	DATE		01/18/94				

STEP 19 Base Shear Load Capacity

The base shear load capacity is determined as:

$$Q_{cap} = 0.55 \cdot (1 - 0.218 \cdot S_{af}) \cdot W$$

$$Q_{cap} = 1.983 \cdot 10^6 \quad \text{lb} \cdot \text{f}$$

STEP 20 Capacity vs. Demand for Base Shear

- * The user should check that the following relation is satisfied:

$$Q_{cap} = 1.983 \cdot 10^6 \quad > \text{ or } = \quad Q = 4.953 \cdot 10^5 \quad \text{OK}$$

Engineering Instruction No. 2

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 101 OF
	REV.	0	1	2	3	PAGES 114	
	MICROFILMED						WO.
	ORIGINATOR S.J. Serhan						
	DATE 01/18/94						

STEP 21 Slosh Height

$G = 386.4$ in/sec/sec [Acceleration of Gravity]

The sloshing mode frequency is:

$$F_s = \frac{1}{2 \cdot \pi \cdot \sqrt{\frac{1.84 \cdot G}{R} \cdot \tanh\left[\frac{1.84 \cdot H}{R}\right]}} \quad F_s = 0.274 \quad \text{Hz}$$

* Note to User:

Using the 1/2% damped maximum horizontal ground or floor (whichever is applicable) acceleration response spectrum, determine the spectral acceleration Sas at frequency = F_s .

$Sas = 0.08$ g (page 21 @ 0.5 Hz: 2×0.04)

The slosh height is:

$hs = 0.837 \cdot R \cdot Sas$ $hs = 16.084$ in

STEP 22 Freeboard Clearance vs. Slosh Height

- * The user should check that the following relation is satisfied:

$$hf = 0 \quad > \text{ or } = \quad hs = 16.084 \quad \text{NG}$$

If the above relation is not satisfied, consider the tank as an outlier.

Borated Water Tank is an outlier

CONCLUSION: Tank under evaluation is an outlier per PSP Section 7 seismic verification procedure.

Conditions: The type of concrete anchorage is assumed to consist of J bolts. Should be confirmed later.

Engineering Instruction No. 2




CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 102 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR		S.J. Serhan					
DATE		01/18/94					

8. HORIZONTAL BORIC ACID TANK

The following pages document the seismic verification of the Horizontal Boric Acid Tank by using the PSP Section 7 Methodology [Reference 4].

 CALCULATION	SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER	DC-5520-161.0SE	PAGE	103
	REV.	0	1	2	3		OF	
	MICROFILMED						PAGES	114
	ORIGINATOR		S.J. Serhan				WO.	
	DATE		01/18/94					

FPC- Crystal River Unit 3

USI A-46 Project

Tanks Evaluation

Tank: Horizontal Boric Acid Tank [CAT-5A and CAT-5B]

Originator: Samir J. Serhan 10/08/1993

Reviewer: Gary M. Jackson

Program Name: TANKh1

Dr. Samir J. Serhan
Gilbert/Commonwealth, Inc.
May 10, 1993

SEISMIC VERIFICATION OF HORIZONTAL TANKS AND HEAT EXCHANGERS


Scope:

This seismic verification procedure is applicable to tanks with the following characteristics:

- (a) cylindrical tanks and heat exchangers,
- (b) curved bottom supported by saddle plates,
- (c) anchored to a stiff foundation,
- (d) all base plates under the saddles have slotted holes in the longitudinal direction except for the one under the saddle at one end,
- (e) tank and saddles are made of steel,
- (f) saddles are uniformly spaced,
- (g) tank overhanging at both ends (each) should be less than half of the uniform spacing between saddles, and
- (h) dimensions for tank shell, anchorage, and content should fall within the following range of parameters:


[See the following page]

Engineering Instruction No. 2

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 104 OF
	REV.	0	1	2	3		PAGES 114
	MICROFILMED						
	ORIGINATOR S.J. Serhan						WO.
	DATE 01/18/94						

Diameter of Tank (D): 1' to 14'
 Length of Tank (L): 4' to 60'
 Height of Center-of-Gravity of Tank and Fluid above floor (Hcg): 1' to 12'
 Number of Saddles (NS): 2 to 6
 Spacing between Support Saddles (S): 3' to 20'
 Number of Bolting Locations per Saddle (NL): 2 to 3
 Number of Anchor Bolts per Bolting Location (NB): 1 to 2
 Distance between Extreme Anchor Bolts in Base Plate of Saddle (Dprime): 1' to 12'
 Ratio of Tank C.G. Height to Saddle Spacing (Hcg/S): 0.1 to 2.0
 Ratio of Tank C.G. Height to Distance between Extreme Anchor Bolts (Hcg/Dprime): 0.5 to 2.0
 Weight Density:
 Horizontal Tanks (GAMMA_t): 60 to 75 lb/ft³
 Horizontal Heat Exchangers (GAMMA_h): 130 to 180 lb/ft³

Engineering Instruction No. 2

 CALCULATION	SUBJECT			FPC - Crystal River Unit 3 Seismic Verification of Tanks			IDENTIFIER			DC-5520-161.0SE			PAGE			105		
	REV.			0			1			2			3			OF		
	MICROFILMED															PAGES 114		
	ORIGINATOR			S.J. Serhan												WO.		
	DATE			01/18/94														

Evaluation Process:

Per the PSP Section 7 [Reference 4], the seismic verification for horizontal tanks and heat exchangers consists of the following 11 steps:

* STEP 1 INPUT DATA to be provided by the user


Tank:

$D = 9$ ft [Diameter of Tank]
 $L = 17.08$ ft [Length of Tank]
 $t = 0.25$ in [Thickness of Tank Shell]
 $W_{tf} = 73000$ lb [Weight of Tank plus Fluid]
 $GAMMA_t = 61.16 \text{ lb/ft}^3$ [Weight Density of Tank]
 $GAMMA_h = 0$ lb/ft³ [Weight Density of Heat Exchanger]
 $H_{cg} = 5.28$ ft [C.G. of Tank and Fluid above Floor]

Saddles:

$S = 9.92$ ft [Spacing between Support Saddles]
 $h = 12$ in [Height of Saddle Plate from bottom of Tank to Base Plate]
 $G = 11153846$ psi [Shear Modulus of Saddle Plate and Stiffener Material]
 $E = 290000000$ psi [Elastic Modulus of Saddle Plate and Stiffener Material]
 $NS = 2$ [Number of Saddles]

Engineering Instruction No. 2

 CALCULATION	SUBJECT			FPC - Crystal River Unit 3 Seismic Verification of Tanks			IDENTIFIER		DC-5520-161.0SE		PAGE		106		
	REV.			0		1		2		3		OF			
	MICROFILMED											PAGES		114	
	ORIGINATOR			S.J. Serhan								WO.			
	DATE			01/18/94											

Base Plate:

$t_b = 0.75$ in [Thickness of Base Plate under Saddle]
 $f_y = 30000$ psi [Minimum Specified Yield Strength of Saddle Base Plate]
 $t_w = 0.25$ in [Thickness of Leg of Weld between Saddle and Base Plate]
 $e_s = 2.7$ in [Eccentricity from Anchor Bolt Centerline to Vertical Saddle Plate]

Bolts:

$N_L = 2$ [Number of Bolt Locations on each Saddle]
 $N_B = 2$ [Number of Anchor Bolts at each Bolt Location]
 $d = 1.0$ in [Diameter of Anchor Bolt]
 $D_{prime} = 102$ in [Distance between Extreme Anchor Bolts in Base Plate of Saddle]

* Note to User:

Before proceeding to Step 2, confirm that the values listed and ratios calculated in Step 1 are within the applicable range of parameters documented in the scope of this seismic verification procedure.

Answer: Yes _____

Engineering Instruction No. 2



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 107 OF
REV.	0	1	2	3		PAGES 114
MICROFILMED						WO.
ORIGINATOR		S.J. Serhan				
DATE		01/18/94				

STEP 2 Anchor Bolt Allowable Loads

Per Section 4.4 and Appendix C of the GIP [Reference 1], the following values are determined for the anchor bolt allowables:

$P_{uprime} = 2670 \text{ lbs}$ [Anchor Bolt Allowable Tension]

$V_{uprime} = 13350 \text{ lbs}$ [Anchor Bolt Allowable Shear]

Reduction factor for concrete strength,

$$RF_{conc} = \sqrt{\frac{3000}{3500}} \quad RF_{conc} = 0.926$$

$$P_{uprime} = P_{uprime} \cdot RF_{conc} \quad P_{uprime} = 2.472 \cdot 10^3 \text{ lbs}$$

$$V_{uprime} = V_{uprime} \cdot RF_{conc} \quad V_{uprime} = 1.236 \cdot 10^4 \text{ lbs}$$

STEP 3 Base Plate Bending Strength Reduction Factor

The base plate bending strength reduction factor is equal to the ratio of the base plate yield strength over the maximum bending stress:

$$RB = \frac{[f_y \cdot t_b^2]}{(3 \cdot P_{uprime})} \quad RB = 2.276$$

STEP 4 Base Plate Weld Strength Reduction Factor

The base plate weld strength reduction factor is equal to the ratio of the weld allowable strength (30600 psi) over the weld stress:

$$RW = \frac{[2 \cdot [\sqrt{2}] \cdot t_w \cdot e_s \cdot 30600]}{P_{uprime}} \quad RW = 23.634$$



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 108 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR		S.J. Serhan					
DATE		01/18/94					

STEP 5 Anchorage Allowable Loads

The tension allowable anchorage load is:

$$R_{smaller} = \text{if}(RW > RB, RB, RW)$$

$$R_{smaller} = 2.276$$

$$P_u = P_{uprime} \cdot R_{smaller} \quad P_u = 5.625 \cdot 10^3 \text{ lb}$$

The shear allowable anchorage load is:

$$V_u = V_{uprime} \quad V_u = 1.236 \cdot 10^4 \text{ lb}$$

STEP 6 Ratios

Calculate the following items:

$$\alpha = \frac{P_u}{V_u}$$

$$W_b = \frac{W_{tf}}{(NS \cdot NL \cdot NB)}$$

$$F1 = \sqrt{[NS^2] + 1}$$

$$F2 = \sqrt{NL^2 \cdot \left[\frac{H_{cg}}{D_{prime}} \right]^2 + \left[\frac{H_{cg}}{S} \right]^2 \cdot \left[\frac{NS^2}{(NS - 1)^2} \right]}$$



CALCULATION

SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 109 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR S.J. Serhan							
DATE 01/18/94							

STEP 7 Acceleration Capacity of Tank Anchorage

$$\lambda_1 = \left[\frac{V_u}{W_b} \right] \cdot \left[\frac{1}{F_1} \right] \quad \lambda_1 = 0.606 \quad g$$

$$\lambda_2 = \frac{\left[\frac{V_u}{W_b} + \frac{0.7}{\alpha} \right]}{\left[\frac{0.7}{\alpha} \cdot F_2 + F_1 \right]} \quad \lambda_2 = 0.745 \quad g$$

Pick smaller of the above two values,

$$\lambda = \text{if}(\lambda_1 > \lambda_2, \lambda_2, \lambda_1) \quad \lambda = 0.606 \quad g$$

STEP 8 Tank Stiffness in Transverse and Vertical Directions

* Note to User:

Using the following parameters, enter Figure 7-14 (Tanks) or Figure 7-15 (Heat Exchangers) of the PSP Section 7 and obtain the maximum saddle spacing for rigid transverse and vertical response:

$$\frac{D}{12} = 0.75 \quad \text{ft} \quad (D = 9' \text{ from page 105})$$

$$t = 0.25 \quad \text{in}$$

The following answer is provided by the user:

$$S_c = 19.3 \quad \text{ft} \quad \text{or} \quad S_c \cdot 12 = 231.6 \quad \text{in}$$


If $S_c > \text{or} = S$ =====> Tank is Rigid

If $S_c < S$ =====> Tank is Flexible

* Note to User:

The following answer is provided by the user:

"Tank is Rigid in the Transverse and Vertical Directions"

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 110 OF
	REV.	0	1	2	3		PAGES 114
	MICROFILMED						WO.
	ORIGINATOR S.J. Serhan						
	DATE 01/18/94						

STEP 9 Tank Stiffness in Longitudinal Direction

The longitudinal stiffness of the end unslotted saddle is determined by assuming a fixed end at the tank and a pinned end at the base plate.

* Note to User:

Calculate the moment of inertia (I_{yy}) and area (A_s) of the saddle plate and its stiffeners at a cross section just below the bottom of the cylindrical tank. The following answer is provided by the user:

$$A_s = 79 \quad \text{in}^2$$

$$I_{yy} = 115 \quad \text{in}^4$$

$$g = 386 \quad \text{in/sec}^2$$

$$k_s = \frac{1}{\left[\frac{h^3}{(3 \cdot E \cdot I_{yy})} + \frac{h}{(A_s \cdot G)} \right]} \quad k_s = 5367 \cdot 10^6 \quad \text{lb/in}$$

$$F_{long} = \frac{1}{[2 \cdot \pi]} \cdot \sqrt{\frac{(k_s \cdot g)}{W_{tf}}} \quad F_{long} = 26.811 \quad \text{Hz}$$

If $F_{long} > \text{or} = 30 \quad \text{=====>}$ Tank is Rigid

If $F_{long} < 30 \quad \text{=====>}$ Tank is Flexible

* Note to User:

The following answer is provided by the user:

"Tank is Flexible in the Longitudinal Direction"

Engineering Instruction No. 2



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 111 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR		S.J. Serhan					
DATE		01/18/94					

STEP 10 Seismic Demand Acceleration

* Note to User:

Using the 4% damped maximum horizontal ground or floor (whichever is applicable) acceleration response spectrum, determine the spectral acceleration demand:

If $S_c > \text{or} = S$

and

If $F_{long} > \text{or} = 30$

The following answer is provided by the user:

$S_a = 0.044 \text{ g}$ [Page 28 @ 28 Hz: 2×0.022]

Otherwise,

The following answer is provided by the user:

$S_a = 0.71 \text{ g}$ [Page 28 @ 11.5 Hz: 2×0.353]

* Note to User:

The following answer is provided by the user:

$S_a = 0.044 \text{ g}$ [Demand: since $F_{long} = 26.81 \text{ Hz}$]

Knowing that: $\lambda = 0.606 \text{ g}$ [Capacity]


If Capacity is $>$ Demand =====> Tank Anchorage is Okay

If Capacity is $<$ Demand =====> Tank Anchorage is No Good

* Note to User:

The following answer is provided by the user:

"Tank Anchorage is ___Okay___"

 CALCULATION	SUBJECT FPC - Crystal River Unit 3 Seismic Verification of Tanks				IDENTIFIER DC-5520-161.0SE		PAGE 112 OF
	REV.	0	1	2	3		PAGES 114
	MICROFILMED						WD.
	ORIGINATOR S.J. Serhan						
DATE		01/18/94					

STEP 11 Saddle Stresses

Note to User:

The end unslotted saddle should resist the longitudinal seismic shear load causing weak-axis bending. In addition, all saddles should resist the vertical seismic and dead loads, and the overturning moment from transverse seismic loads.

The combined compression and bending stresses in the saddles should be evaluated according to the AISC Manual with the 1.7 increase factor on the allowable stresses (SSE Loading).

The Seismic Review Team will evaluate the saddle stresses during the official A-46 in-plant walkdowns.

CONCLUSION: Tank under evaluation is acceptable per PSP Section 7 seismic verification procedure.

Conditions: The Seismic Review Team will evaluate Step 11 during the A-46 in-plant walkdowns.



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 113 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR		S.J. Serhan					
DATE		01/18/94					

9. CONCLUSIONS

Plots and tables of the generated 4.0% damped OBE acceleration response spectra are documented in Section 4 for the free-field ground and the Auxiliary Building Elevation 119'.

Seismic verification of four tanks is performed in Sections 5 through 8 by using the PSP Section 7 Methodology [Reference 4]. The verification results are:

o Condensate Storage Tank [CDT-1]

Result: Tank is acceptable

o Dedicated Emergency Feedwater Tank [EFT-2]

Result: Tank is an outlier

Reasons: Base shear and overturning moment exceed allowable values.

o Borated Water Tank [DHT-1]

Result: tank is an outlier

Reasons: Freeboard clearance is not acceptable

Conditions: Concrete anchorage is assumed to consist of J Bolts

Engineering Instruction No. 2



CALCULATION


SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-1C1.0SE		PAGE 114 OF	
REV.	0	1	2	3	PAGES 114		
MICROFILMED						WO.	
ORIGINATOR		S.J. Serhan					
DATE		01/18/94					

- Horizontal Boric Acid Tank [CAT-5A and CAT-5B]

Result: tanks are acceptable

Conditions: Seismic Review Team will evaluate Step 11 during the A-46 in-plant walkdowns.

Engineering Instruction No. 2

 CALCULATION	SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER		DC-5520-161.0SE		PAGE		40	
	REV.		0		1		2		3		OF	
	MICROFILMED										PAGES	
	ORIGINATOR		S.J. Serhan								WO.	
	DATE		01/18/94									

ATTACHMENT A G/C DESIGN INFORMATION TRANSMITTAL



POWER AND INDUSTRIAL SYSTEMS DIVISION - READING
DESIGN INFORMATION TRANSMITTAL

A. REQUEST

TO: J.R. Beil LOCATION: _____
(RESPONDENT'S FULL NAME)

FROM: G.M. JACKSON LOCATION: _____
(REQUESTER'S FULL NAME)

DATE: 5/21/93 RESPONSE REQUESTED BY: 5/24/93
(DATE)

SUBJECT: WATER LEVELS, ETC FOR TANKS => CDT-1, DWT-1, EFT-2
CAT-5A / -5B, AND DFT-3A / -3B

REQUEST THE FOLLOWING FOR EACH TANK:

a) weight density of fluid in tank

b) Height of fluid @ the maximum level to which the tank will be filled.

c) Height of freeboard ABOVE fluid level surface @ the maximum level to which the tank will be filled

ATTACHMENT: YES _____ NO X SIGNATURE G.M. Jackson

cc: _____

B. NOTE: IF INFORMATION FORWARDED BELOW IS NOT A RESPONSE TO A DOCUMENTED REQUEST, STATE "N/A" IN BLANKS ABOVE.

RESPONSE

TO: G.M. JACKSON LOCATION: _____
(RESPONDENT'S FULL NAME)

FROM: J.R. Beil DATE: 5-24-93
(REQUESTER'S FULL NAME)

SEE ATTACHED SHEETS (2).

STATUS OF INFORMATION: PRELIMINARY _____ FINAL X

SOURCE(S): SEE ATTACHED SHEETS

ATTACHMENT: YES X NO _____ SIGNATURE J.R. Beil

cc: E.B. TOLL

SUMMARY OF TANK DATA

The following is in response to your DIT dated May 21, 1993. All of the information has been referenced or assumed with engineering judgement. The data has not been verified.

When a level range is given as maximum or minimum, the level may fall somewhere between the two points during operation. The maximum and minimum levels may not be achieved during operation due to procedural/operational intervention or operator action due to alarms.

The height of freeboard is not given since levels above tank bottom are given and the freeboard height can be calculated from that point.

CDT-1

Maximum Height = 151'-6" el. (390" above inside tank bottom)
[This height is based on the CDV-113 interlock from Ref. 1]

Minimum Height = 123'-10½" el. (58" above inside tank bottom)
[Based on NPSH and Vortexing from Ref. 2]

Weight Density of Fluid = 62.305 lbm/ft³ (70 °F) to 61.376 lbm/ft³ (140 °F)
[Refs. 3 and 4]

DHT-1

Maximum Height = 47.8' above tank bottom (Ref. 5, p. 20 for maximum inventory)

Minimum Height = 119'-10" el. (8" above tank bottom)
[Based on min. usable volume from Ref. 6]

Weight Density of Fluid = 62.426 lbm/ft³ (40 °F) to 61.996 lbm/ft³ (100 °F)
[Based on water and from Refs. 5, p. 20 and 4]

EFT-2

Maximum Height = 38'-9" above tank bottom
[Based on the Hi-Alarm point from Ref. 7]

Minimum Height = 121'-7" el. (3'-1" above tank bottom)
[Based on min. usable volume from Ref. 8]

Weight Density of Fluid = Assumed the same as for CDT-1

DFT-3A/3B

Maximum Height = 31" above tank bottom
[Based on DFP-1A/1B auto stop point and Ref. 9]

Minimum Height = 5 13/16" above tank bottom
[Based on level at 2nd seat of foot valve and Ref. 9]

Weight Density of Fluid = 60.84 lbm/ft³
[Based on Fuel Oil No. 6 at 100 °F and Refs. 4 and 10]

CAT-5A/5B

Maximum Height = 95" above tank bottom
[Based on the Hi-Level Alarm and Ref. 11]

Minimum Height = 30" above tank bottom
[Based on the Lo-Level Alarm and Ref. 11]

Weight Density of Fluid = 61.16 lbm/ft^3 (152 °F) to 60.94 lbm/ft^3 (164 °F)
[Based on water as a fluid since the saturation of boric acid is approximately 7% and Refs. 12 and 13]

REFERENCES

1. FPC IDS CD-58-LS, Rev. 9
2. G/CI Calculation DC-5520-124-01.00-ME, Rev. 0
3. FPC Spec. SP-5745, Addendum C, 6/16/70
4. Crane 410, 1981
5. FPC EDBD for Decay Heat Removal, Rev. 3
6. G/CI Calculation DC-5520-124-03.00-ME, Rev. 0
7. FPC EDBD for Emergency Feedwater/Emergency Feedwater Initiation and Control, TC No. 230, sheet 4 of 5
8. G/CI Calculation EFC-0428-5503-022-001, Rev. 2
9. FPC Calculation M-91-1032, Rev. 1
10. FPC RO-2891, Rev. 14
11. IDS CA-11-LS, Rev. 6 and CA-13-LS, Rev. 7
12. Keenan and Keyes Thermodynamic Properties of Steam, 1936
13. FPC IDS CA-12-TS1, Rev. 2


Engineering Instruction No. 2



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE A0 OF	
REV.	0	1	2	3	PAGES 2		
MICROFILMED						WO.	
ORIGINATOR		S.J. Serhan					
DATE		01/18/94					

ATTACHMENT B FPC TELECOPY
DEDICATED EMERGENCY FEEDWATER TANK



TELECOPY FLORIDA POWER CORPORATION

GENERAL OFFICE COMPLEX
ST. PETERSBURG, FLORIDA

DATE 10/7/93TO/COMPANY GARY JACKSON / GCIFROM GLENN PUGH / FPC

TELECOPY NUMBER _____

ADDITIONAL PAGES OF TELECOPY 1

FPC teletype # (813) 866-4984

If you have any problems in receipt of this teletype, please notify teletype operator at (813) 866-4494.

FOR FPC (Nuclear) USE ONLY:

DISTRIBUTE &
SEND BY MAIL☐

DISCARD

☐HOLD FOR
PICK-UP☒CALL
WHEN SENT☐MAIL TO
RECIPIENT☐

NOTES:


GARY,

ATTACHED IS THE ANCHOR BOLT DETAIL
FOR THE EFW TANK.

HOPE IT HELPS

OL-5520-161-2-E

p. 2 of 2



Engineering Instruction No. 2



CALCULATION

SUBJECT		FPC - Crystal River Unit 3 Seismic Verification of Tanks		IDENTIFIER DC-5520-161.0SE		PAGE 40 OF	
REV.	0	1	2	3			
MICROFILMED						PAGES	
ORIGINATOR		S.J. Serhan				WO.	
DATE		01/18/94					

ATTACHMENT C DESIGN VERIFICATION RECORD



DESIGN VERIFICATION RECORD

PAGE A1 OF 2

PROJECT: Crystal River Unit 3

SUBJECT: FPC- Crystal River # 3- Seismic Verification of Tanks

IDENTIFIER: DC-5520-161
• OSE

DISCIPLINE NAME AND NUMBER: Structural/Piping 2241 & 2242

W.O. 04-5520-161

A

Samir J. Serhan

ORIGINATOR

Samir J. Serhan

PROJECT ENGINEER

THIS DOCUMENT CONTAINS PRELIMINARY DATA/ASSUMPTIONS:

NO ☒YES ☐

PAGE(S) _____

A COMPUTER PROGRAM WAS:

☒

NOT USED

☐ USEDVALIDATED & USED WITHIN
LIMITS OF VERIFICATIONMUST BE VERIFIED
TOGETHER WITH CALC.

PROGRAM SYSTEM NAME

REV.

(1) _____

(2) _____

(3) _____

VERIFICATION PACKAGE (IDENTIFY EACH ITEM)

DOCUMENTS TO BE VERIFIED

REV.

REV.

(1) Calculation # DC-5520-161.0SE 0 (4) _____

(2) _____ (5) _____

(3) _____ (6) _____

SUPPORTING DOCUMENTS

REV.

REV.

(1) See Page 4 (6) _____

(2) _____ (7) _____

(3) _____ (8) _____

(4) _____ (9) _____

Samir J. Serhan

ORIGINATOR'S SIGNATURE

1/19/94

DATE

B

NO VERIFICATION REQUIRED PER DCP 2.05:

REASON: _____

VERIFICATION REQUIRED (CHECK METHOD(S)):

DESIGN REVIEW ☒ALTERNATE CALCULATION ☐QUALIFICATION TESTING ☐IDENTIFICATION OF VERIFIER/VERIFICATION TEAM: Gary M. Jackson

Samir J. Serhan

PROJECT ENGINEER'S SIGNATURE


1/19/94

DATE

W.O. 0' 5520-161

IDENTIFIER: DC-5520-161.0SE

C CONCURRENCE WITH SELECTION OF VERIFIER(S):

PAGE A2 OF 2

DISCIPLINE CHIEF ENGINEER'S SIGNATURE

1/19/94

DATE

D EXTENT OF VERIFICATION:

COMPUTER PROGRAM USE (IF APPLICABLE):

(1) _____
PROGRAM NAME(S)

PROGRAM IS VALIDATED PER DCP 1.40 AND HAS BEEN USED WITHIN THE ESTABLISHED LIMITS OF VERIFICATION AS SHOWN ON THE PROGRAM VERIFICATION RECORDS. A COPY OF THE DVR HAS BEEN SENT TO THE MANAGER OF ENGINEERING SERVICES.

(2) _____
PROGRAM NAME(S)

PROGRAM IS NOT VALIDATED OR NOT USED WITHIN THE LIMITS OF VERIFICATION. THE PROGRAM IS VERIFIED TOGETHER WITH THIS CALCULATION AS DESCRIBED BELOW.


Detailed Review of Calculation # DC-5520-161.0SE Revision 0 per DCP 2.05.

RESULTS OF VERIFICATION:

Reviewer thoroughly reviewed the analytical procedure utilized, results obtained, and conclusions.Reviewer concurs with the findings of this calculation.Calculation # DC-5520-161.0SE Revision 0 is complete and acceptable.


ATTESTATION:

THIS DESIGN VERIFICATION WAS PERFORMED IN ACCORDANCE WITH DCP 2.05.


VERIFIER'S SIGNATURE1/19/94

DATE

E COMPLETION OF VERIFICATION AND APPROVAL:


PROJECT ENGINEER'S SIGNATURE1/19/94

DATE

U.S. Nuclear Regulatory Commission

3F0897-01

Enclosure 2 - USI A-46 Outlier Resolution Schedule and Status

ENCLOSURE 2

**FLORIDA POWER CORPORATION
CRYSTAL RIVER UNIT 3
DOCKET NUMBER 50-302/LICENSE NUMBER DPR-72**

**USI A-46 OUTLIER RESOLUTION SCHEDULE
AND STATUS**

UNRESOLVED SAFETY ISSUED A-46

Enclosure 2 - USI A-46 Outlier Resolution Schedule and Status

CRYSTAL RIVER UNIT 3

USI A -46 OUTLIER RESOLUTION SCHEDULE AND STATUS

UNRESOLVED SAFETY ISSUE (USI) A-46, GENERIC LETTER 87-02

A list that identified and described 111 outliers was included with the RAI response provided by FPC to the NRC in letter, 3F0397-28, dated March 27, 1997.

At the request of the NRC staff, FPC has prepared an action plan for resolving these USI A-46 outliers. This action plan commits FPC to resolve a number of outliers prior to restart scheduled for December 1997. The methodology used to select which outliers would be resolved prior to restart and which outliers will be worked later is outlined below.

There are one hundred eleven (111) outlying components identified by tag numbers on the outlier list. The detailed list showing the current status of each outlier is provided here in Enclosure 2. These 111 outliers are categorized as either Restart or Post-Restart. The categorizing of outliers was based on their association with plant systems that were assessed for readiness in accordance with the methodology of the CR-3 System Readiness Review Plan. This plan was submitted to the NRC by FPC letters, 3F0397-19, dated March 27, 1997, and, 3F0397-36, dated March 31, 1997. The System Readiness Review Plan was implemented for 105 plant systems using a graded approach methodology. Each of the systems were classified into one of three levels. The level classification was determined by a safety significance process relying on three aspects. The first aspect utilized a fission product barrier approach to comply with 10 CFR 50, Appendix A II. The second aspect relied on an analytical approach which took into consideration several system specific factors such as, PSA model importance, Maintenance Rule risk significance, Improved Technical Specification safety significance, and Safety Classification. The third aspect considered previous assessment results and findings, number of modifications performed on the system, and other opportunities for configuration changes. Based on these aspects, the systems are classified as Level 1, Level 2, and Level 3. As a result, the outlying components have been categorized and tabulated as follows.

Restart: Out of the 111 outliers, FPC will resolve 70 outliers by restart in December 1997. This number consists of the following:

- 19 Safety related components in System Readiness Level 1 systems.
- 38 Safety related components (and some non-safety related components considered important to start-up activities), in System Readiness Level 2 systems. And, safety related components in System Readiness Level 3 systems.
- 10 Components in systems of various system readiness levels solely in need of maintenance to resolve.
- 3 Components (including the Control Room Ceiling that will be resolved as part of the Control Room noise abatement modification, MAR 97-03-04-01).

Post-Restart: The remaining 41 outliers will be completed based on a work-off curve that will be developed prior to restart. All outliers are required to be resolved before December 2000. This number is consists of the following:

- 24 Non-safety related components in System Readiness Level 2 systems.
- 17 Non-safety related components in System Readiness Level 3 systems.

ID Number	Tag Number	Description	Restart Outlier	Work Priority Category	Disposition Status	Disposition Document	Comments
1	DFT-3A	DIESEL GENERATOR FUEL OIL DAY TANK A	Y	1	To be determined (TBD)		Programmatic Solutions to assist in resolving outlier
2	DFT-3B	DIESEL GENERATOR FUEL OIL DAY TANK B	Y	1	To be determined		Programmatic Solutions to assist in resolving outlier
3	DHT-1	BORATED WATER STORAGE TANK	Y	1	95%	Revise SEWS and Revised Calculation yet to be done	Acceptable as is
4	EFT-2	EMERGENCY FEEDWATER TANK	Y	1	To be determined		Programmatic Solutions to assist in resolving outlier
5	EGCP-2A	EMERGENCY DIESEL GEN A ELECTRICAL EQUIPMENT CABINET	Y	1	To be determined		Programmatic Solutions to assist in resolving outlier
6	EGCP-2B	EMERGENCY DIESEL GEN B ELECTRICAL EQUIPMENT CABINET	Y	1	To be determined		Programmatic Solutions to assist in resolving outlier
7	EGDG-1B	DIESEL GENERATOR B	Y	1	To be determined		Programmatic Solutions to assist in resolving outlier
8	ESCP-4A	ENGINEERED SAFEGUARDS ACTUATION RELAY CABINET 4A	Y	1	50%	Verbal agreement with Ops.	Operations is taking lead to have storage cabinet and tool boxes moved to less vital area.
9	ESCP-4B	ENGINEERED SAFEGUARDS ACTUATION RELAY CABINET 4B	Y	1	50%	Verbal agreement with Ops.	Operations is taking lead to have storage cabinet and tool boxes moved to less vital area.
10	ESCP-4C	ENGINEERED SAFEGUARDS ACTUATION RELAY CABINET 4C	Y	1	50%	Verbal agreement with Ops.	Operations is taking lead to have storage cabinet and tool boxes moved to less vital area.
11	ESCP-4D	ENGINEERED SAFEGUARDS ACTUATION RELAY CABINET 4D	Y	1	50%	Verbal agreement with Ops.	Operations is taking lead to have storage cabinet and tool boxes moved to less vital area.
12	ESCP-5A	ENGINEERED SAFEGUARDS ACTUATION RELAY CABINET 5A	Y	1	0%	Work Request(WR) No. (LATER)	WR to be written to fix lower door latch
13	MUP-1A	MAKE-UP AND PURIFICATION PUMP 3A	Y	1	100%	WR# NU0344791	Walkdown on 6/23/97 showed that a U-Bolt was in place. WR to be voided. No outlier present now.
14	MUV-051	LET-DOWN FLOW CONTROL VALVE	Y	1	To be determined	WR# (LATER)	Work Request to be written to resolve
15	MUV-200	LETDOWN ISOLATION VALVE TO DEMINERALIZER MUDM-1A	Y	1	To be determined		Programmatic Solutions to assist in resolving outlier
16	MUXS-1	4160V ISOLATION SWITCH	Y	1	100%	WR# NU0344312	Work Request written to inspect further
17	RCV-10	PRESSURIZER POWER OPERATED RELIEF VALVE	Y	1	70%	Analysis/Calculation 001	Seismic Demand issue
18	RCV-11	PRESSURIZER BLOCK VALVE	Y	1	70%	Analysis/Calculation 001	Seismic Demand issue

Enclosure 2 - USI A-46 Outlier Resolution Schedule and Status

ID Number	Tag Number	Description	Restart Outlier	Work Priority Category	Disposition Status	Disposition Document	Comments
19	RR2B	ENGINEERED SAFEGUARD AUXILIARY RELAY RACK RR2B	Y	1	100%	WR# NU0344784	Work complete in field. Field has fixed latch, replaced missing screws
20	ACDP-68-T	ES DISTRIBUTION PANEL 3AB TRANSFORMER	Y	2	To be determined		
21	AH-196-POS1	AHD-1 CONTROL	Y	2	To be determined	WR# (LATER)	Programmatic Solutions to assist in resolving outlier
22	AH-196-POS3	AHD-3 CONTROL	Y	2	To be determined	WR# (LATER)	Work Request to be written
23	AH-967-SV	AHD-1 & AHD-1D CONTROL	Y	2	To be determined		Programmatic Solutions to assist in resolving outlier
24	AHD-01D	CONTROL COMPLEX MAKE-UP AIR	Y	2	To be determined		Programmatic Solutions to assist in resolving outlier
25	DCP-1B	DECAY HEAT CLOSED CYCLE COOLING PUMP B	Y	2	To be determined		This is a problem with a pipe hanger. This may be rolled into the effort being done to resolve generic piping issues.
26	DPBA-1A	250/125V BATTERY A	Y	2	To be determined		Programmatic Solutions to assist in resolving outlier
27	DPBA-1B	250/125V BATTERY B	Y	2	To be determined		Programmatic Solutions to assist in resolving outlier
28	DRRD-2-1	CRD DC BREAKER CABINET UNIT 1 & 2	Y	2	20%	WR# NU0344316	WR written to inspect further - on Hold pending operations permission to access cabinet
29	DRRD-2-2	CRD DC BREAKER CABINET UNIT 3 & 4	Y	2	20%	WR# NU0344316	WR written to inspect further - on Hold pending operations permission to access cabinet
30	DRRD-2-3	CRD DC BREAKER CABINET TRIP RESET	Y	2	20%	WR# NU0344316	WR written to inspect further - on Hold pending operations permission to access cabinet
31	MSV-411	MAIN STEAM LINE A-2 ISOLATION VALVE	Y	2	To be determined		Programmatic Solutions to assist in resolving outlier
32	MTSW-2C	4160V ES 3A (NORTH)	Y	2	To be determined		Programmatic Solutions to assist in resolving outlier
33	MTSW-2E	4160V ES 3B (NORTH)	Y	2	20%	WR# NU0344313	WR written to inspect further - on Hold pending operations permission to access cabinet
34	MTSW-2F	4160V ES 3B (SOUTH)	Y	2	20%	WR# NU0344313	WR written to inspect further - on Hold pending operations permission to access cabinet
35	MTSW-3F	480V ES BUS 3A	Y	2	To be determined		Programmatic Solutions to assist in resolving outlier
36	MTSW-3F-T	4160/480V ES BUS 3A TRANSFORMER	Y	2	To be determined		Programmatic Solutions to assist in resolving outlier

ID Number	Tag Number	Description	Restart Outlier	Work Priority Category	Disposition Status	Disposition Document	Comments
37	MTSW-3G	480V ES BUS 3B	Y	2	To be determined		Programmatic Solutions to assist in resolving outlier
38	MTSW-3G-T	4160/480V ES BUS 3B TRANSFORMER	Y	2	To be determined		Programmatic Solutions to assist in resolving outlier
39	NI-1-A3	PROPORTIONAL COUNTER ASSEMBLY	Y	2	To be determined		
40	NI-2-B3	PROPORTIONAL COUNTER ASSEMBLY	Y	2	To be determined		
41	NI-3-C3	COMPENSATED ION CHAMBER/ASSEMBLY	Y	2	To be determined		
42	NI-4-D3	COMPENSATED ION CHAMBER/ASSEMBLY	Y	2	To be determined		
43	RSA	REMOTE SHUTDOWN RELAY CABINET A	Y	2	To be determined		
44	RSA-1	REMOTE SHUTDOWN RELAY CABINET A-1	Y	2	To be determined		
45	RWP-2A	NUCLEAR SERVICE SEA WATER PUMP 3A	Y	2	60%	Analysis/Calculation 004	Calculation to verify long pump shaft
46	RWP-2B	NUCLEAR SERVICE SEA WATER PUMP 3B	Y	2	60%	Analysis/Calculation 004	Calculation to verify long pump shaft
47	RWP-3A	DECAY HEAT SERVICE SEA WATER PUMP 3A	Y	2	60%	Analysis/Calculation 004	Calculation to verify long pump shaft
48	RWP-3B	DECAY HEAT SERVICE SEA WATER PUMP 3B	Y	2	60%	Analysis/Calculation 004	Calculation to verify long pump shaft
49	SWP-1A	EMERGENCY NUCLEAR SERVICE CCC PUMP 3A	Y	2	100%	WR# NU0344310	WR written to inspect further. Follow-up inspections found the SWP's to be acceptable
50	SWP-1B	EMERGENCY NUCLEAR SERVICE CCC PUMP 3B	Y	2	100%	WR# NU0344796	WR written to inspect further. Follow-up inspections found the SWP's to be acceptable
51	SWP-1C	NORMAL NUCLEAR SERVICE CLOSED CYCLE COOLING PUMP	Y	2	100%	WR# NU0344311	WR written to inspect further. Follow-up inspections found the SWP's to be acceptable
52	SWV-354-SV1	SWV-354 CONTROL	Y	2	To be determined		
53	SWV-354-SV2	SWV-354 CONTROL	Y	2	To be determined		
54	VBIT-1A	DUAL INPUT INVERTER 3A	Y	2	To be determined		

ID Number	Tag Number	Description	Restart Outlier	Work Priority Category	Disposition Status	Disposition Document	Comments
55	WDT-1A	WASTE GAS DECAY TANK 1A	Y	2	95%	Closed based on inspection of tapes and photos	Revise SEWS yet to be done
56	WDT-1B	WASTE GAS DECAY TANK 1B	Y	2	95%	Closed based on inspection of tapes and photos	Revise SEWS yet to be done
57	WDT-1C	WASTE GAS DECAY TANK 1C	Y	2	95%	Closed based on inspection of tapes and photos	Revise SEWS yet to be done
58	AH-196-POS2	AHD-2 CONTROL	Y	3	10%	TBD	Walkdown to determine WR scope
59	ATCP-1	ANTICIPATED TRANSIENT WITHOUT SCRAM LOGIC CABINET	Y	3	100%	WR# NU0344792	WR completed.
60	CAP-1B	BORIC ACID PUMP B	Y	3	100%	WR# NU0344793	Outlier complete with missing bolts now installed. WR# NU0344793 returned with work being completed. Field installed missing bolts. Dated 6/24/97
61	IAP-1A	INSTRUMENT AIR COMPRESSOR A	Y	3	10%	TBD	Walkdown to determine WR scope
62	NI&P-D2	NI&P SYSTEM SUBASSEMBLY D CABINET 2	Y	3	10%	TBD	Walkdown to determine WR scope
63	VBXS-1B	VITAL BUS TRANSFER SWITCH B	Y	3	10%	WR# NU0344786	WR written to resolve outlier. Waiting for field work to complete.
64	VBXS-1C	VITAL BUS TRANSFER SWITCH C	Y	3	10%	WR# NU0344787	WR written to resolve outlier. Waiting for field work to complete.
65	VBXS-1D	VITAL BUS TRANSFER SWITCH D	Y	3	10%	WR# NU0344788	WR written to resolve outlier. Waiting for field work to complete.
66	VBXS-3B	EFIC VITAL BUS TRANSFER SWITCH B	Y	3	10%	WR# NU0344789	WR written to resolve outlier. Waiting for field work to complete.
67	VBXS-3D	EFIC VITAL BUS TRANSFER SWITCH D	Y	3	10%	WR# NU0344790	WR written to resolve outlier. Waiting for field work to complete.
68	AHF-17A	CONTROL COMPLEX NORMAL SUPPLY FAN A	Y	4	80%	PEERE 1512	Fixing as part of CC Noise Abatement project. PEERE 1512 issued to replaced isolator. Waiting for field work to be completed.
69	AHF-17B	CONTROL COMPLEX NORMAL SUPPLY FAN B	Y	4	80%	PEERE 1512	Fixing as part of CC Noise Abatement project. PEERE 1512 issued to replaced isolator. Waiting for field work to be completed.
70	CEILING	CONTROL ROOM CEILING	Y	4	20%	MAR 97-03-04-01	Fixing as part of CC Noise Abatement project.
71	AHP-01A	CONTROL COMPLEX HVAC AIR COMPRESSOR A	N	5	To be determined		

Enclosure 2 - USI A-46 Outlier Resolution Schedule and Status

ID Number	Tag Number	Description	Restart Outlier	Work Priority Category	Disposition Status	Disposition Document	Comments
72	AHP-01B	CONTROL COMPLEX HVAC AIR COMPRESSOR B	N	5	To be determined		
73	AHP-01C	CONTROL COMPLEX HVAC AIR COMPRESSOR	N	5	To be determined		
74	AHP-01D	CONTROL COMPLEX HVAC AIR COMPRESSOR D	N	5	To be determined		
75	DPBA-1C	250/125V BATTERY C	N	5	90%	Analysis/Calculation 003	Masonry wall failure due to seismic event is not a concern, acceptable as is.
76	DPBC-1G	BATTERY CHARGER G	N	5	90%	Analysis/Calculation 003	Masonry wall failure due to seismic event is not a concern, acceptable as is.
77	DPBC-1H	BATTERY CHARGER H	N	5	90%	Analysis/Calculation 003	Masonry wall failure due to seismic event is not a concern, acceptable as is.
78	DPBC-1I	BATTERY CHARGER I	N	5	90%	Analysis/Calculation 003	Masonry wall failure due to seismic event is not a concern, acceptable as is.
79	DPDP-1C	250/125V DC MAIN PANEL 3C	N	5	90%	Analysis/Calculation 003	Masonry wall failure due to seismic event is not a concern, acceptable as is.
80	DPDS-1C	BATTERY 3C DISCONNECT SWITCH	N	5	90%	Analysis/Calculation 003	Masonry wall failure due to seismic event is not a concern, acceptable as is.
81	DPXS-1C	DPBC-1 INPUT POWER TRANSFER SWITCH	N	5	To be determined		
82	MTMC-09	480V PRESSURIZER HEATER MCC 3B	N	5	To be determined		
83	MTMC-12	480V TURBINE MCC 3A	N	5	To be determined		
84	MTSW-3A	480V TURBINE AUXILIARY BUS A	N	5	To be determined		
85	MTSW-3C	480V REACTOR AUXILIARY BUS A	N	5	To be determined		
86	MTSW-3D	480V REACTOR AUXILIARY BUS B	N	5	To be determined		
87	MTSW-3J	480V PLANT AUXILIARY BUS	N	5	95%	Revise SEWS	Acceptable as is
88	MTSW-3J-T	4160/480V PLANT AUXILIARY BUS TRANSFORMER	N	5	To be determined		
89	RWP-1	NORMAL NUCLEAR SERVICES SEA WATER PUMP MOTOR COOLER	N	5	60%	Analysis/Calculation 004	STAAD Analysis of long pump shaft

Enclosure 2 - USI A-46 Outlier Resolution Schedule and Status

ID Number	Tag Number	Description	Restart Outlier	Work Priority Category	Disposition Status	Disposition Document	Comments
90	SF-9-FIT	SPENT FUEL COOLANT FLOW TRANSMITTER	N	5	To be determined		
91	WDT-3A	RC BLEED TANK 3A	N	5	To be determined		
92	WDT-3B	RC BLEED TANK 3B	N	5	To be determined		
93	WDT-3C	RC BLEED TANK 3C	N	5	To be determined		
94	WD1	REACTOR COOLANT DRAIN TANK	N	5	To be determined		
95	CDHE-4A	MAIN CONDENSER A	N	6	To be determined		
96	CDHE-4B	MAIN CONDENSER B	N	6	To be determined		
97	ER1	EVENTS RECORDER CABINET 1	N	6	To be determined		
98	ER2	EVENTS RECORDER CABINET 2	N	6	To be determined		
99	ER3	EVENTS RECORDER CABINET 3	N	6	To be determined		
100	ER4	EVENTS RECORDER CABINET 4	N	6	To be determined		
101	ER5	EVENTS RECORDER CABINET 5	N	6	To be determined		
102	ER6	EVENTS RECORDER CABINET 6	N	6	To be determined		
103	ER7	EVENTS RECORDER CABINET 7	N	6	To be determined		
104	ER8	EVENTS RECORDER CABINET 8	N	6	To be determined		
105	ICS-5	INTEGRATED CONTROL SYSTEM CABINET 5	N	6	To be determined		
106	NGT-XX	ADV BACKUP NITROGEN SUPPLY TANKS (10)	N	6	To be determined		
107	NNI-5	AUXILIARY CONTROL SYSTEM CABINET 5	N	6	To be determined		

Enclosure 2 - USI A-46 Outlier Resolution Schedule and Status

ID Number	Tag Number	Description	Restart Outlier	Work Priority Category	Disposition Status	Disposition Document	Comments
108	NNI-6	AUXILIARY CONTROL SYSTEM CABINET 6	N	6	To be determined		
109	PORV/TEMP	PORV & TEMPERATURE SATURATION CABINET	N	6	To be determined		
110	RFL MPLXR	RFL MULTIPLEXER FOR 500 KV SWITCHYARD	N	6	To be determined		
111	TPC	TRANSMITTER POWER SUPPLY CABINETS A & B	N	6	To be determined		

Work Priority Categories:**Restart Categories:**

- 1 = System Readiness Level 1 systems - safety related.
- 2 = System Readiness Level 2 systems - safety related,
System Readiness Level 2 systems - Non-safety related but considered important to startup, and
System Readiness Level 3 systems - safety related.
- 3 = Various System Readiness Levels, requiring minor maintenance only.
- 4 = Control Room noise abatement modification (PEERE 1512 and MAR 97-03-04-01).

Post-Restart Categories:

- 5 = System Readiness Level 2 systems - non-safety related.
- 6 = System Readiness Level 3 systems - non-safety related.