PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-III-88-65 Date July 25, 1988

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region III staff on this date.

Facility: Detroit Edison Company

Fermi 2

Newport, MI 48166

Docket No. 50-341

Licensee Emergency Classification: X Notification of an Unusual Event

Site Area Emergency

General Emergency Not Applicable

Subject: UNIDENTIFIED LEAKAGE FORCES UNIT SHUTDOWN

At 1:09 a.m. (EDT), July 23, 1988, with the unit operating at 90% power, the licensee began a power reduction after unidentified drywell leakage exceeded 4.5 gallons per minute (gpm) and was approaching the Technical Specification limit of 5 gpm.

At 5:05 a.m., with the loss still at 5 gpm, the licensee declared an "unusual event," in accordance with its emergency classification system, and commenced to shut down. The unusual event was terminated at 12:45 a.m. (EDT), July 24, 1988. The unit is currently in cold shutdown.

The leakage is believed to be coming from a Reactor Core Isolation Cooling (RCIC) inboard steam isolation valve, and possibly two other valves in the Reactor Water Cleanup System.

The unit will be shut down 7 to 10 days to make the necessary repairs and conduct other maintenance and inspection activities.

A Region III (Chicago) inspector was onsite during this event. Region III will continue to monitor the licensee's course of action.

The State of Michigan will be notified.

The licensee notified the media of the unusual event. There has been considerable news media interest.

This information is current as of 11:30 a.m. (CDT), July 25, 1988.

CONTACT:

P. Pelke

FTS 388-5560

DISTRIBUTION:

WFN 1 Chairman Zech Comm. Roberts Comm. Carr Comm. Rogers

MNBB AEOD ARM 1WFN PA

1WFN

E/W DIA 0.1

WFN 1 NMSS SLITP

Resident Inspector Offices Resident Inspector

Mail To: DCS (Original) DOT (Trans. Only)

SECY OGC

FAX TO:

Nicholson Lane

Regions Region I

Region II Region IV Region V

Region III Rev. June 1988

OGC-H CA GPA ACRS PDR

INPO 12:57 NSAC 10/ Licensee 1.09

HQS. Operations Officer ///

3808030016 880725 PDR I&E PNO-III-88-065 PDC