

The Light company

Houston Lighting & Power, South Texas Project Electric Generating Station P. O. Box 289 Wadsworth, Texas 77483

July 29, 1997
ST-HL-AE-5701
File No.: G03.08
10CFR50


U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

South Texas Project
Units 1 and 2
Docket Nos. STN 50-498, STN 50-499
120-Day Response to Generic Letter 97-01,
"Degradation of Control Rod Drive Mechanism Nozzle
and Other Vessel Closure Head Penetrations"

- Reference:
- 1) Letter from T. T. Martin, Nuclear Regulatory Commission, to All Holders of Operating Licenses for Pressurized Water Reactors, dated April 1, 1997
 - 2) Letter from T. H. Cloninger to U. S. Nuclear Regulatory Commission, dated May 1, 1997 (ST-HL-AE-5635)

In Reference 2, the South Texas Project provided the 30-day response requested by Generic Letter 97-01, "Degradation of Control Rod Drive Mechanism Nozzle and Other Vessel Closure Head Penetrations" and committed to submit a written response to the Nuclear Regulatory Commission by July 30, 1997, relative to Items 1 and 2 of the requested information section of the Generic Letter 97-01. The attachment to this letter provides the written summary.

If you have any questions on this matter, please contact Mr. A. W. Harrison at (512) 972-7298 or me at (512) 972-8787.


T. H. Cloninger
Vice President,
Nuclear Engineering

JMP/

050077



A075 1/2

Project Manager on Behalf of the Participants in the South Texas Project

9708050242 970729
PDR ADOCK 05000498
P PDR

STI 90341516

- Attachments:
1. Affidavit
 2. 120 Day Response to Generic Letter 97-01, "Degradation of Control Rod Drive Mechanism Nozzle and Other Vessel Closure Head Penetrations"
 3. Safety Evaluation Report on the NUMARC Submittal Addressing Alloy 600 Control Rod Drive Mechanism (CRDM)/Control Element Drive Mechanism (CEDM) Pressurized Water Reactor Vessel Head Penetration Cracking Issue

Ellis W. Merschhoff
Regional Administrator, Region IV
U. S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

Thomas W. Alexion
Project Manager, Mail Code 13H3
U. S. Nuclear Regulatory Commission
Washington, DC 20555-0001

David P. Loveless
Sr. Resident Inspector
c/o U. S. Nuclear Regulatory Comm.
P. O. Box 910
Bay City, TX 77404-0910

J. R. Newman, Esquire
Morgan, Lewis & Bockius
1800 M Street, N.W.
Washington, DC 20036-5869

M. T. Hardt/W. C. Gunst
City Public Service
P. O. Box 1771
San Antonio, TX 78296

J. C. Lanier/M. B. Lee
City of Austin
Electric Utility Department
721 Barton Springs Road
Austin, TX 78704

Central Power and Light Company
ATTN: G. E. Vaughn/C. A. Johnson
P. O. Box 289, Mail Code: N5012
Wadsworth, TX 77483

Rufus S. Scott
Associate General Counsel
Houston Lighting & Power Company
P. O. Box 61067
Houston, TX 77208

Institute of Nuclear Power
Operations - Records Center
700 Galleria Parkway
Atlanta, GA 30339-5957

Dr. Bertram Wolfe
15453 Via Vaquero
Monte Sereno, CA 95030

Richard A. Ratliff
Bureau of Radiation Control
Texas Department of Health
1100 West 49th Street
Austin, TX 78756-3189

J. R. Egan, Esquire
Egan & Associates, P.C.
2300 N Street, N.W.
Washington, D.C. 20037

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555-0001

120 Day Response to NRC Generic Letter 97-01, "Degradation of Control Rod Drive Mechanism Nozzle and Other Vessel Closure Head Penetrations"

INTRODUCTION:

Generic Letter 97-01 (GL), *Degradation of Control Rod Drive Mechanism Nozzle and Other Vessel Closure Head Penetrations*, was issued to request licensees to describe their program for insuring the timely inspection of pressurized water reactor (PWR) control rod drive mechanisms (CRDM) and other closure head penetrations. This response provides South Texas Project's (STP) information relative to the information requested by the GL.

Prior to issuance of the GL, STP worked with the Westinghouse Owners Group (WOG), Electric Power Research Institute (EPRI), and the Nuclear Energy Institute (NEI) to understand the operational experience, identify technical issues, cause factors, relative importance, and solutions. One of these tasks was the development of safety evaluations that characterized the initiation of damage, propagation and consequences. These safety evaluations are contained in WCAP-13565, Rev. 1, "Alloy 600 Reactor Vessel Head Adapter Tube Cracking Safety Evaluation", and are applicable to STP. The Nuclear Regulatory Commission (NRC) reviewed the safety evaluations and issued a safety evaluation report (SER) to NEI on November 19, 1993. The safety evaluations and the SER establish the basis for STP's continued operation. A copy of the SER is provided in Attachment 3.

REQUESTED INFORMATION ITEM 1.1:

"1.1 *A description of all inspections of CRDM nozzle and other VHPs performed to the date of this generic letter, including the results of these inspections.*"

STP RESPONSE TO ITEM 1.1:

The South Texas Project has performed multiple inspections of the CRDM nozzles and other vessel head penetrations (VHP) of both units of STP as described below.

GL 88-05 Visual Inspection Results

Boric acid inspections as required by GL 88-05, "Boric Acid Corrosion of Carbon Steel Reactor Pressure Boundary Components in PWR Plants", are performed at STP in accordance with procedure OPGP03-ZE-0033, "RCS Pressure Boundary Inspection for Boric Acid Leaks". To date, there have been 28 inspections performed in Unit 1 and 22 inspections performed in Unit 2. No leakage has been detected in the reactor vessel head penetration area in Unit 1. Unit 2 inspections have documented one incident where leakage from a reactor vessel water level penetration flanged connection above the reactor vessel head had leaked and boric acid residue was seen on the vessel head. Additional inspections were performed after the removal of the boric acid residue and no areas of wastage were found.

ISI Visual Inspection Results of the Attachment Weld, As Required by Section XI of the ASME Code

In accordance with the STP inservice inspection (ISI) program, the Class 1 pressure boundary, including the reactor pressure vessel (RPV) head penetration welds for CRDM's, the CRDM housings themselves, and other RPV head penetrations, are subject to a visual examination for leakage (VT-2) during a system leakage test after each refueling outage and during a hydrostatic pressure test each inspection interval (approx. 10 years) under Category B-P, Item Nos. B15.10 and B15.11, respectively. The control rod drive (CRD) nozzles are also required to be visually examined (VT-2) during the system hydrostatic test at the end of each inspection interval under Class 1 Examination Category B-E, Item No. B4.12. Since STP has not yet completed its first inspection interval, we have only performed the VT-2 visual examinations during a system leakage test after each refueling outage under Section XI rules. No leakage has been identified in the RPV head area during these inspections.

ISI UT and/or PT Inspection Results of the Dual Metal Weld, As Required by Section XI of the ASME Code

Full penetration butt welds in CRD housings are categorized in Section XI as Category B-O, Item No. B14.10 welds. The code requires that the welds in 10% of the installed peripheral CRD housings be examined by a volumetric or surface examination each inspection interval. There are 26 peripheral CRD housings. STP performs a liquid penetrant (PT) examination on three housings (one weld in each housing) each interval.

The three CRD housing welds in Unit 1 were PT examined during the 1RE06 refueling outage (May-June, 1996). No recordable indications were detected. The Unit 2 CRD housing welds are scheduled for examination during the 2RE06 refueling outage scheduled for Fall, 1998.

Any Replication Inspections Performed

No replication inspections have been performed at STP.

Any Plant Specific Volumetric Inspection Results

No volumetric examinations of the CRDM nozzle attachment welds have been performed at STP.

In addition to the STP-specific inspections discussed above, CRDM penetrations have been inspected at other domestic Westinghouse plants and at Westinghouse supplied plants around the world. These CRDM inspections are summarized below.

In 1994, two WOG/Westinghouse PWR plants (Point Beach Unit 1 and D. C. Cook Unit 2) voluntarily performed inspections of the CRDM penetrations. The results showed that there were no indications found in Point Beach Unit 1. Three indications were found in a single penetration at D.C. Cook Unit 2. These were significant cracks but considerably smaller than the NRC approved acceptance limit.

In Spring of 1996, D. C. Cook Unit 2 re-inspected some of their penetrations that had been previously inspected and confirmed the same indications reported earlier. No new indications were found. Meanwhile, North Anna Unit 2 inspected 20 out of the total complement of 65 penetrations. No indications were found.

A large number of inspections have been performed on Westinghouse supplied reactor vessel head penetrations throughout the world, and this section will document those inspections, and the findings to date.

Section XI inspections have been performed for many years on the head penetration to reactor vessel partial penetration weld, and the weld between the head penetration tube and the CRDM. While these inspections do not cover the Alloy 600 portion of the head penetration directly, they do provide surveillance information on the head penetration region, and must be performed every ten years. To date, no indications have been reported.

A second series of inspections which have been carried out regularly since 1988 involves visual surveillance of the head for boron deposits which would be evidence of leaks, following Generic Letter 88-05. Some boron deposits have been found by this surveillance, but the sources of the leakage were not from cracked head penetrations. Generally these leaks have been associated with mechanical seals on the head.

Westinghouse supplied nuclear steam supply system (NSSS) plants in Spain, Sweden, Switzerland, Belgium, Brazil, and Korea have conducted nondestructive examination (NDE) inspections on Reactor Vessel Head Penetrations. By the beginning of 1996, some 5200 penetrations had been inspected worldwide. The results are summarized in Table 1-1. On average, indications were found in approximately 2% of the penetrations that were inspected. Based on Table 1-1, it appears that the rate of indications at U.S. plants is significantly less than that of the French plants. Of all these inspections, only one penetration was found to have through-wall cracking: the Bugey plant where cracking was first identified.

It will be of interest to examine the history of inspections of the plants of Westinghouse design worldwide, as well as the plants of Westinghouse design and US fabrication. A relatively large number of these plants have been inspected, and very few indications have been found. Outside of France, a total of 39 plants of Westinghouse design have been inspected. Of approximately 1900 penetrations inspected, only 10 were found to be cracked, for a percentage of less than 0.6 percent. Of the 39 plants, 9 were manufactured in the USA, and for these plants 310 penetrations were inspected with only one cracked. Thus, for Westinghouse plants manufactured in the USA, only 0.3 percent of the penetrations have been found to be cracked.

Root cause evaluations concluded that the cracks were caused by primary water stress corrosion cracking (PWSCC) of the Alloy 600 material. Electricite de France (EdF) and Westinghouse concluded that the following factors contributed to the Bugey Unit 3 PWSCC.

- Susceptible microstructure produced during manufacturing
- Surface finish on the inside of the penetration
- Stresses induced during welding, which caused ovalization of the penetration

**TABLE 1-1
 WORLDWIDE VESSEL HEAD PENETRATION PWSCC INSPECTION RESULTS***

Country	Number of Plants Inspected	Total No. of Penetrations in the Plants	Number of Penetrations Inspected	Penetrations With Indications	Rate of Indication Detected**
France	47	3225	3213	105	3.3%
Sweden	3	195	190	7	3.7%
Switzerland	2	72	72	2	2.8%
Japan	17	960	834	0	0
Belgium	7	435	435	0	0
Spain	5	325	102	0	0
Brazil	1	40	40	0	0
South Africa	1	63	63	0	0
South Korea	1	65	65	0	0
United States	5	314	217	1***	0.5%
Total:	89	5694	5231	115	2.0%

* Based on data available as of January 1996 (Europe) and July 1996 (U.S.).

** Ratio of number of penetrations with indications detected to number of penetrations inspected.

*** Oconee indications were not counted as cracks, because they had no measurable depth. Eddy current inspections after one cycle did not indicate any growth

REQUESTED INFORMATION ITEM 1.2 THROUGH 1.4:

- "1.2 If a plan has been developed to periodically inspect the CRDM nozzle and other VHPs:
- a) Provide the schedule for first, and subsequent, inspections of the CRDM nozzle and other VHPs, including the technical basis for this schedule.
 - b) Provide the scope for the CRDM nozzle and other VHP inspections, including the total number of penetrations (and how many will be inspected), which penetrations have thermal sleeves, which are spares, and which are instrument or other penetrations."
- 1.3 If a plan has not been developed to periodically inspect the CRDM nozzle and other VHPs, provide the analysis that supports why no augmented inspection is necessary.
- 1.4 In light of the degradation of CRDM nozzle and other VHPs described above, provide the analysis that supports the selected course of action as listed in either 1.2 or 1.3, above. In particular, provide a description of all relevant data and /or tests used to develop crack initiation and crack growth models, the methods and data used to validate these models, the plant-specific inputs to these models, and how these models substantiate the susceptibility evaluation. Also, if an integrated industry inspection program is being relied on, provide a detailed description of this program."

STP RESPONSE ITEM 1.2 THROUGH 1.4:

STP is a participant in the WOG/NEI RPV head penetration integrated inspection program. This integrated program includes volumetric inspection of head penetrations that have been performed (see Table 1-1 above) and additional volumetric inspections that will be performed.

STP believes that the number of plants that have or will be inspected is sufficient to demonstrate the adequacy of the WOG/NEI integrated inspections program.

The need and schedule for re-inspection will be based on an evaluation of the inspection results from the integrated inspection program. The plant performing re-inspections will keep the NRC staff informed of its future re-inspection plans.

STP has selected a crack initiation and growth prediction model developed by Dominion Engineering Inc. The reactor pressure vessel head nozzle PWSCC calculations of time to 75% through-wall flaw depth are based on: 1) a crack initiation model using industry inspection data and Weibull statistics with corrections for factors such as stress and nozzle temperature and 2) a crack growth model using a stress intensity power law relationship. Predictions of initiation and growth are integrated for the entire head using a Monte Carlo analysis because of the variability in susceptibility among nozzles.

Based on the currently available results using this approach, even the most conservative integrated prediction (i.e., the number of effective full power years from January 1, 1997 until a 5% probability of the presence of a 75% through-wall crack in any nozzle in the vessel head) indicates augmented inspections of the RPV head penetrations will not be required for either unit prior to the end of the second ISI interval (circa 2009-2010). STP RPV head penetrations are accessible for volumetric examination only during non-rapid refueling outages when the upper internals are disconnected from the head. This evolution occurs approximately each ten years when the RPV mechanized ISI examinations are performed.

All three PWR owners groups, EPRI, and NEI are cooperatively working to compile industry-wide information on the estimated operating time from January 1, 1997, needed to initiate and propagate a crack 75% through wall in a vessel penetration. This information will be evaluated to determine if an adequate number of plants have or are planning to inspect. This evaluation will be completed by the end of 1997 and provided to the NRC. Therefore, STP will base any future inspections upon an evaluation of the integrated inspection plan.

REQUESTED INFORMATION ITEM 2:

2. *Provide a description of any resin bead intrusions, as described in IN 96-11, that have exceeded the current EPRI PWR Primary Water Chemistry Guidelines recommendations for primary water sulfate levels, including the following information:*
 - 2.1 *Were the intrusions cation, anion, or mixed bed?*
 - 2.2 *What were the durations of these intrusions?*
 - 2.3 *Does the plant's RCS water chemistry Technical Specifications follow the EPRI guidelines?*
 - 2.4 *Identify any RCS chemistry excursions that exceed the plant administrative limits for the following species: sulfates, chlorides or fluorides, oxygen, boron, and lithium. Identify any conductivity excursions which may be indicative of resin intrusions. Provide a technical assessment of each excursion and any follow-up actions.*
 - 2.5 *Provide an assessment of the potential for any of these intrusions to result in a significant increase in the probability for IGA of VHPs and any associated plan for inspections"*

STP RESPONSE ITEM 2 :

STP has reviewed the plant historical records to determine if any incident of resin ingress similar to those which occurred in 1980 and 1981 at the Jose Cabrera (Zorita) plant has occurred at Unit 1 or Unit 2 of STP. This data search is structured to identify all resin intrusion events into the primary coolant system with a magnitude greater than 1 ft³ (30 liters). The threshold of 1 ft³ was chosen as a conservative lower bound since it represents less than 15% of the estimated volume of resin released into the reactor coolant system during the two events at Jose Cabrera.

For the period of plant operation prior to the routine analysis for sulfate in reactor coolant, the data search was based on a review of the plant's reactor coolant chemistry records relative to specific conductance of the reactor coolant. An elevation of a 28 micro S/cm increment in specific conductance was the value used as an indicator of cation resin ingress equivalent to a volume of 1 ft³.

Routine analysis for sulfate in reactor coolant was performed for plant operation from June, 1990 to the present. A sulfate concentration in the range of 15 to 17 ppm peak concentration was used as the indicator of cation resin ingress. This concentration is approximately equivalent to a volume of 1 ft³.

The review of plant records showed no indication that an incident of resin ingress similar to those which occurred in 1980 and 1981 at the Jose Cabrera (Zorita) plant had occurred in Units 1 or 2 of STP.

Had either specific conductance or sulfate increases indicated resin ingress to the magnitude of the threshold quantity identified above, additional data evaluation would have been conducted to look for a corresponding depression in pH or elevation in lithium as corroborating information of the incident. In the case of the use of sulfate data as the indicator, specific conductance would also have been included as confirmatory data had a significant in leakage event been identified.

It is unnecessary to review plant records for boron, chlorides, fluorides and oxygen, because these species are not viewed as valid indicators of cation resin ingress and degradation within the primary coolant system of a PWR. Borate, chloride and fluoride anions could be associated with the anion portion of mixed bed resin (cation plus anion); however, if mixed bed resin leakage to the RCS occurred, the cation portion of the resin would contain the sulfate indicator described above. Detectable dissolved oxygen in reactor coolant, during power operation with appropriate hydrogen overpressure on the volume control tank and specified residual dissolved hydrogen in the reactor coolant, could not occur and, therefore, could not be associated with resin in-leakage.

STP has followed the *EPRI PWR Primary Water Chemistry Guidelines* since the start of commercial operation of each unit and has implemented revisions when issued.



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

November 19, 1993

William Rasin, Vice President
Director of the Technical Division
Nuclear Management and Resources Council
1776 Eye Street, N.W.
Suite 300
Washington, D.C. 20006-3706

Dear Mr. Rasin:

The attached safety evaluation was prepared by the Materials and Chemical Engineering Branch, Division of Engineering, Office of Nuclear Reactor Regulation, on the NUMARC submittal of June 16, 1993, addressing the Alloy 600 Control Rod Drive Mechanism (CRDM)/Control Element Drive Mechanism (CEDM) pressurized water reactor vessel head penetration cracking issue. This submittal addressed stress analyses, crack growth analyses, leakage assessments, and wastage assessments for potential cracking of the inside diameter of CRDM/CEDM nozzles. Based on the overseas inspection findings and the review of your analyses, the staff has concluded that there is no immediate safety concern for cracking of the CRDM/CEDM penetrations. This finding is predicated on the performance of the visual inspection activities requested in Generic Letter 88-05. Also, special nondestructive examinations are scheduled to commence in the Spring of 1994 to confirm your safety analyses for each PWR owners group.

Your submittals for each PWR type did not address the Sugey-3 flaw that was oriented approximately 30° off the vertical axis nor a circumferential, J-groove flaw discovered at Ringhals. Preliminary information supplied to the staff by Swedish authorities indicates that the J-groove flaw may be associated with a fabrication defect. We are continuing to work with the Swedish authorities to confirm this. From the information available to us today, neither of these flaws would pose a threat to the integrity of the CRDM penetrations. It is our understanding that you are also reviewing these flaws and you will provide your assessment as to their significance and origin. NRC will issue a supplemental safety evaluation after reviewing your supplemental assessment.

The staff agrees that there are no unreviewed safety questions associated with CRDM/CEDM penetration cracking. The staff agrees that the flaw predictions based upon penetration stress analyses are in qualitative agreement with inspection findings. However, the stress analyses do not address stresses from possible straightening of CRDM penetration tubes during fabrication. These stresses, if large, could result in circumferential flaw orientations. The staff requests that you also address this issue in your supplemental assessment. Based upon information received from overseas regulatory authorities, your analyses, and staff reviews, the staff believes that catastrophic failure of a penetration is extremely unlikely. Rather, a flaw would leak before it reached the critical flaw size and would be detected during periodic surveillance walkdowns for boric acid leakage pursuant to Generic Letter 88-05. However, the staff recommends that you consider

9312090177 12 RP

enhanced leakage detection by visually examining the reactor vessel head until either inspections have been completed showing absence of cracking or on-line leakage detection is installed in the head area. The staff requests that you also address the issue of enhanced leakage detection in your supplemental assessment.

The NRC staff has reviewed your July 30, 1993 submittal, which proposed flaw acceptance criteria to be used in dispositioning any flaws found during CRDM/CEDM inspections. The staff finds the proposed flaw acceptance criteria acceptable for axial cracks because the criteria conform to the American Society of Mechanical Engineers (ASME) Section XI criteria. The staff determined that flaws that are primarily axial (less than 45° from the axial direction) should be treated as axial cracks as indicated in Figure 1(b), (d), and (f) of your July 30, 1993 letter. Flaws more than 45° from the axial direction should be treated as circumferential flaws. However, based upon information submitted to date and the more serious safety consequences of circumferential flaws, the staff does not agree with your proposed criteria for circumferential flaws. Circumferential flaws which a licensee proposes to leave in service without repair, should be reviewed by the staff on a case-by-case basis.

Sincerely,

Original signed by

William T. Russell, Associate Director
for Inspection & Technical Assessment
Office of Nuclear Reactor Regulation

Enclosure:
As Stated

Distribution:

Central File	JStrosnider	WRussell
EMCB RF	BDLiaw	RHermann
JDavis	JWiggins	WKoo
PDR		

*SEE PREVIOUS CONCURRENCE

*EMCB:DE	*EMCB:DE	*EMCB:DE	*EMCB:DE	*DE:D	NR:ADT <i>WR</i>
JDavis	WKoo	RHermann	JStrosnider	JWiggins	WRussell
09/23/93	10/25/93	10/27/93	11/18/93	11/19/93	11/19/93

SAFETY EVALUATION
FOR
POTENTIAL REACTOR VESSEL HEAD ADAPTOR TUBE CRACKING

1.0 INTRODUCTION

Primary water stress corrosion cracking (PWSCC) of Alloy 600 was identified as an emerging issue by the NRC staff to the NRC Commission following a 1989 leakage from an Alloy 600 pressurizer heater sleeve penetration at Calvert Cliffs Unit 2, a Combustion Engineering designed pressurized water reactor (PWR). Several instances of PWSCC of Alloy 600 pressurizer instrument nozzles had been reported to the NRC between the time period of 1986 to the present on domestic and foreign pressurized water reactors (PWR). The licensee at Arkansas Nuclear Operations, Unit 1, a Babcock & Wilcox (B&W) designed PWR, reported a leaking pressurizer instrument nozzle in 1990, after 16 years of operation. Westinghouse PWR's do not use Alloy 600 for penetrations or nozzles in the pressurizers.

According to the information provided to the staff by NUMARC at a public meeting held on July 5, 1993, a leak was discovered in an Alloy 600 control rod drive mechanism (CRDM) adaptor tube penetration during a hydrostatic test at the Bugey 3 plant in France in 1991 after 12 years of operation. A visual examination of the CRDM adaptor tube penetration indicated the presence of axial flaws in the inside diameter (ID) of the CRDM adaptor tube penetration. The remaining 65 CRDM adaptor tube penetrations were examined at Bugey 3 and 2 additional CRDM adaptor tube penetrations contained axial cracks on the ID of the CRDM adaptor tube penetrations. An examination of 24 CRDM adaptor tube penetrations at Bugey 4 revealed axial ID cracks in 8 CRDM adaptor tube penetrations. CRDM adaptor tube penetrations have been examined at 37 nuclear power plants in France, Sweden, Switzerland, Japan, and Belgium and 59 of the 1,850 penetrations have revealed short, axial crack indications.

The primary safety concern associated with stress corrosion cracking in Alloy 600 in CRDM penetrations is the potential for circumferential cracks. Extensive circumferential cracking could lead to the ejection of a CRDM resulting in an unisolable rupture in the primary coolant system. As indicated above, the inspections to date have identified short axial cracks. However, two other inspection findings are of particular interest. First, the CRDM penetration that leaked during hydrostatic testing at Bugey-3 was removed and examined metallurgically during December 1992. A secondary crack that was 0.120 inches long and 0.090 inches deep at about 30 degrees to the axial direction was observed on this CRDM. Second, in early in 1993, a J-groove weld at the Ringhals plant in Sweden was discovered to contain a circumferential crack. Preliminary indications are that this flaw is a fabrication defect. Additional work is in progress by the staff at the Swedish Nuclear Power Inspectorate to confirm this.

The Westinghouse CRDM adaptor tube penetrations are similar in design to the European PWR's and use Alloy 600 for the penetrations. The NRC staff met with the WOG on January 7, 1992 to discuss the experience at

the Bugey 3 plant and the relationship of the French design of the CRDM adaptor tube penetrations to the design of domestic Westinghouse plants. The WOG informed the NRC staff that a program had been initiated in December 1991 to: (1) determine the root cause of the CRDM penetration cracking; (2) analyze the stress distributions in the CRDM penetrations of a typical domestic plant; (3) compare the design and operational characteristics of domestic and French plants to determine the likelihood for cracking; and (4) identify the need for additional efforts. The NRC staff also met with the Combustion Engineering Owners Group (CEOG) and the Babcock & Wilcox Owners Group (B&WOG) to discuss the PWSCC of CRDM adaptor tube penetrations. The Nuclear Management and Resources Council (NUMARC) coordinated the PWR Owners' Group efforts on this subject.

On June 16, 1993, NUMARC submitted safety assessments to the NRC from WOG, CEOG, and B&WOG for review by the NRC staff. These safety assessments present stress analyses, crack growth analyses, leakage analyses, and wastage assessments for flaws initiating on the ID of CRDM adaptor tube penetrations. NRC requested additional information on the safety assessments by letter dated September 2, 1993. NUMARC submitted the response to NRC on September 22, 1993. The safety assessments submitted to the NRC did not address the secondary flaw observed at the Bugey-3 plant that was oriented approximately 30° from the longitudinal axis of the penetration nor the apparent fabrication flaw at the Ringhals plant. Neither of these flaws posed a threat to the integrity of the CRDM penetrations. However, NUMARC has committed to submit a safety assessment relevant to this type of cracking. After this safety assessment has been reviewed by NRC, a supplement to this SER will be issued.

2.0 STAFF EVALUATION

2.1 WOG WCAP-13565, ALLOY 600 REACTOR VESSEL HEAD ADAPTOR TUBE CRACKING SAFETY EVALUATION

The WOG submitted the, "Alloy 600 Reactor Vessel Head Adaptor Tube Safety Evaluation," through NUMARC on June 16, 1993. The safety evaluation addresses the following elements:

1. A summary of the stress analysis focusing on the type (orientation) of cracking that may be expected in the Alloy 600 material, and the stresses necessary for flaw propagation;
2. A summary of the flaw propagation analysis along with the background of the flaw prediction method;
3. An assessment of the WOG plants with respect to penetration flaw indication data from plant inspections at Ringhals, Beznau, and various Electricite de France plants, in which the key parameters for cracking are compared to WOG plants;

4. A leakage assessment summarizing leak rate vs. flaw size, and postulating leaks for WOG plants for which leakage considerations may apply; and,
5. A vessel head wastage assessment including the process that leads to wastage and an estimate of the allowable wastage.

2.1.1 REGULATORY BASIS AND DETERMINATION OF UNREVIEWED SAFETY QUESTIONS

The WOG prepared safety evaluation addresses the potential for cracking and the ramifications of such cracking of the reactor vessel head adaptor tubes at Westinghouse designed NSSS plants. The WOG compared the results of this safety evaluation to the criteria in the Title 10, Code of Federal Regulations, Section 50.59 (10 CFR 50.59). The WOG concluded that an unreviewed safety question did not exist. Its evaluation considered the following:

1. Continued plant operation will not increase the probability of an accident previously evaluated in the FSAR.
2. The consequences of an accident previously evaluated in the FSAR are not increased due to continued plant operation.
3. Continued plant operation will not create the possibility of an accident which is different than any already evaluated in the FSAR.
4. Continued plant operation will not increase the probability of a malfunction of equipment important to safety.
5. Continued plant operation will not increase the consequences of a malfunction of equipment important to safety previously evaluated in the FSAR.
6. Continued plant operation will not create the possibility of a malfunction of equipment important to safety different than any already evaluated in the FSAR.
7. The evaluation for the effects of continued plant operation with potentially cracked reactor vessel head adapters has taken into account the applicable technical specifications.

2.1.2 STAFF'S EVALUATION OF THE REGULATORY BASIS AND DETERMINATION OF UNREVIEWED SAFETY QUESTIONS

The staff agrees that no unreviewed safety question exists, provided only axial flaws are found. Those axial flaws would be expected to be short, and they would most probably leak noticeably prior to the flaw size reaching unstable dimensions. The existence of any unexpected leaks would not adversely affect plant operation, or accident/transient response. No significant equipment degradation would be expected. Details of the staff's evaluation that led to the above conclusions is discussed in the following sections.

2.1.3 PENETRATION STRESS ANALYSIS

The WOG conducted an elastic-plastic, finite element analysis of a 4-loop WOG plant vessel head penetrations. The WOG concluded that the 4-loop WOG plant is bounding since prior analyses showed that the operating and residual stresses are higher on a 4-loop plant than on 2 or 3-loop plants on the outermost penetrations. Three penetration locations were modeled, the center location, the outermost location, and the location next to the outermost location. The stress history was simulated by using a load sequence of the thermal load from the first welding pass, the thermal load from the second weld pass, the fabrication shop cold hydrotest, the field cold hydrotest, and the steady state operational loading.

The highest stresses are found in the zone around the weld and are the highest in the penetration farthest from the center of the vessel (peripheral penetrations). The highest stresses on that penetration are on the side of the penetration nearest to the center of the vessel (centerside) and on the side of the penetration farthest from the center of the vessel (hillside). Also, the stresses are the highest below the weld and decrease significantly above the weld. The ratio of peak hoop stress to axial stress at the same location at the outermost penetrations was about 1.4 compared to a value of about 1.6 estimated based on the degree of ovaling measured on actual penetrations. The ratio of hoop stress to axial stress was about the same for center penetrations as for peripheral penetrations (1.6 for center penetrations compared to 1.4 for peripheral penetrations); however, the magnitude of the stresses at the peripheral penetrations was higher. The analysis indicates that axial flaws would be more likely than circumferential flaws, flaws are more likely below the weld than above the weld, and that axial flaws would appear at locations in the penetrations where they have been found in service.

2.1.4 STAFF EVALUATION OF THE PENETRATION STRESS ANALYSIS

The staff is in agreement with the results of the WOG stress analysis that predicts that the cracking will be predominately axial. These results are in qualitative agreement with field inspection findings. However, the WOG did not address the effects of possible straightening of the CRDM penetration tubes during fabrication. Such straightening operations could significantly alter the residual stress fields within the penetration tubes. Results of inspections to date have not identified any problems directly related to this process; however, the staff requests that NUMARC address this issue for all three owners' plants.

2.1.5 CRACK GROWTH ANALYSIS: FLAW TOLERANCE

The WOG crack growth analysis was based on the assumptions that the flaw would be caused by primary water stress corrosion cracking, and that the crack growth is controlled by the hoop stress. The maximum principal stress will be oriented at a slight angle to the hoop stress and flaws

would be expected to be perpendicular to the maximum principal stress. However, all of the flaws found in service with two exceptions have been axially located. Hence, the WOG used the hoop stress as an approximation of the maximum principal stress. The outer-most penetration for a 4-loop Westinghouse plant was selected for analysis since this location experiences the highest stresses. The highest stress was located along the inner surface just below the center side of the weld. The calculated hoop stress through the wall of the penetration was used for flaw growth calculations. The flaw growth data were obtained from steam generator field experience and laboratory data.

Based on the stress fields that exist in the CRDM penetrations, any flaw growth that occurs is expected to be predominately axial in nature. Furthermore, the growth of any flaws inclined from the vertical would be limited in length due to the nature of the existing stresses. These conclusions are consistent with the inspection results described above. Accordingly, there is no significant potential for failure of a penetration by ejection of the CRDM sleeve. With regard to axial cracking, WOG has concluded that the critical flaw length for an axial flaw for Alloy 600 is sufficiently long that leakage would occur and be detected during surveillance walkdowns as required by GL 88-05. Therefore, the consequences of cracking in the penetration sleeve are limited to the affects of leakage as discussed below.

The flaw growth analysis showed that under the most severe conditions of metallurgical microstructure, peak hoop stress, and operating temperature, it would take about five years for a flaw to grow through wall. Under the same conditions, it would take an additional 10 years for a through-wall flaw to grow $1 \frac{1}{2}$ inches above the weld on the lower hillside of the outermost head penetrations (Figure 3.2-2) and about the same time to grow two inches above the J-groove weld on the center side of the outermost penetrations (Figure 3.2-3). The flaw growth analysis indicates that through wall flaws would essentially arrest before growing a maximum of two inches above the weld. These flaws would be constrained within the head and could not significantly open thus limiting the amount of leakage that could occur.

2.1.6 STAFF EVALUATION OF THE CRACK GROWTH ANALYSIS

The WOG stated that the crack growth analysis is in general agreement with the inspection findings. The crack growth rate data used in this analysis was limited, but the results predicted using these flaw growth data bound the results of the inspections. Crack growth rates are difficult to determine precisely; however, the assumed growth rates compare well with inspection data available to date and the large margins that exist in the analyses will account for any possibly higher growth rates. There are large margins of safety in the analyses and the CRDM penetrations are constructed of inherently tough material with a critical flaw size of approximately 13 inches in the free span above the reactor vessel shell. Therefore, the staff concludes that catastrophic failure of a penetration is extremely unlikely because a flaw would be

detected during boric acid leakage surveillance walkdowns before it reached the critical flaw size.

2.1.7 ASSESSMENT OF WOG PLANTS

The WOG compared the Ringhals and Beznau plants to the domestic Westinghouse plants and developed a model for the relative susceptibility to PWSCC. The WOG considered residual and operating stresses in the penetrations, the environment, material condition, operating temperature, and time-of-operation at temperature, and pressure. Based on this evaluation, the WOG has evaluated domestic WOG PWR's with regard to their degree of susceptibility. Based on what WOG considers to be conservative assumptions, the Ringhals plants envelope 45 domestic plants. None of these plants are expected to have any flaws other than some short, shallow, axial flaws. Nine additional WOG plants are not enveloped by the Ringhals plants. Based on the stresses, operating temperatures, hours of operation, and the flaw growth curves provided in the WOG safety assessment, the WOG does not expect any CRDM penetration axial flaws to reach a length in excess of 1 inch before about the middle of 1995.

2.1.8 STAFF EVALUATION OF THE WOG ASSESSMENT

The susceptibility model developed by the WOG considers the appropriate parameters affecting IGSCC and should provide a reasonable ranking of plant susceptibilities. In addition, this evaluation indicates that it is unlikely that U.S. plants should exhibit any cracking significantly worse than that found in European plants.

2.1.9 LEAK RATE CALCULATIONS

The leak rates were calculated based on the assumption that the leak rate will be controlled by the flow rate through the flaw in the head penetration or by the flow through the penetration annulus, whichever is smaller. WOG estimates the maximum leak rate would be 0.7 gpm for a 2 inch long flaw and an annular clearance of 0.003 inches. Leakage above 1.0 gpm is detectable in domestic WOG plants according to WOG. Growth of an axial flaw outside of the part contained within the reactor head will result in leakage greater than 1.0 gpm prior to reaching the critical flaw size. The WOG stated that an axial flaw would remain stable for growth up to 13 inches above the reactor vessel head.

2.1.10 STAFFS EVALUATION OF THE WOG LEAK RATE CALCULATIONS

The staff agrees with the WOG assumptions about leakage and concludes, that based on existing leakage monitoring requirements, there is reasonable assurance that leakage in excess of the 1.0 gpm technical specification limit would be detected prior to any unstable extension of the flaw.

2.1.11 REACTOR VESSEL HEAD WASTAGE ASSESSMENTS

This section assesses the potential wastage of the reactor vessel head due to leakage of primary coolant through the CRDM penetrations. This assessment is based on wastage data from previous Westinghouse experiments and from the results of a penetration mockup test conducted by the Combustion Engineering Owners Group (CEOG).

This analysis assumed that coolant escaping from the penetration would flash to steam leaving boric acid crystals behind. WOG assumed that crystals would accumulate on the vessel head but would cause minimal corrosion while the reactor was operating. The head temperature would be about 500°F during operation and significant wastage of the reactor head by the boric acid crystals would not be expected. Dry boric acid crystals do not cause corrosion. Wastage would only occur during outages when the head temperature is below 212°F.

The CEOG provided all of the PWR owners groups with the results of pressurizer penetration mockup test results. The WOG examination of the CEOG mockup test results showed that the maximum penetration rate at the deepest pit was 2.15 inches/year while the average penetration rate was 0.0835 inches/year. The maximum total metal loss rate or wastage volume was 1.07 in³/year, and the greatest damage occurred where the leakage left the annulus. The WOG considered the maximum wastage would be 6.4 in³ of vessel head material. The assumptions made were that any leakage over 1.0 gpm can be detected so only leak rates between 0.0 and 1.0 gpm were considered. The WOG analyzed the situation using finite element analyses for a 2 loop, 3 loop, and 4 loop reactor vessel head where a 1.0 gpm leak went undetected for 6 years and concluded that the ASME code minimum wall thickness requirement would be satisfied and that the stresses remain within the ASME code allowable stresses.

2.1.12 THE STAFF'S EVALUATION OF THE REACTOR VESSEL HEAD WASTAGE ASSESSMENTS

The assumption used in the WOG corrosion assessment are based on experimental data and should provide a reasonable estimate of potential wastage of the reactor vessel head. Based on these evaluations, there would be significant time between initiating a leak and experiencing wastage that would reduce the structural integrity margins of the reactor vessel head to below acceptable levels. Considering the length of time involved, there is reasonable assurance that leakage, manifested by the accumulation of moderate amounts of boric acid crystals would be detected during a surveillance walkdown in accordance with GL 88-05.

3.0 CEOG SAFETY EVALUATION

The CEOG safety evaluation is essentially the same as the WOG safety evaluation. The CEOG plants run at a slightly higher temperature than the European plants that have experienced cracking, have greater hillside angles, and have been in operation longer than many of the European plants. The CEOG indicated that all of these factors would

increase the probability of cracking for the CEOG plants. However, the CEOG plants have significantly less weld metal in the J-groove welds and the CEOG stated that this would significantly reduce the residual welding-induced stresses and would reduce the probability of PWSCC. CEOG concluded that any PWSCC that formed would be short, axial flaws.

The CEOG states that they can detect a 0.12 gpm leak in the primary coolant system. CEOG also states that the boric acid accumulation as a result of a 0.12 gpm leak would not result in wall thinning below the code allowables in less than 8.8 years compared to 6 years for WOG plants and that surveillance walkdowns would detect boric acid crystals long before the 8.8 years.

3.1 STAFF EVALUATION OF THE CEOG SAFETY EVALUATION

The staff has concluded that the potential for PWSCC of CRDM/CEDM for CEOG plants does not create an immediate safety issue as long as the surveillance walkdowns required by GL 88-05 continue and corrective action is instituted when leaks are discovered. The CEOG analyses indicating that the stresses would favor development of axial rather than circumferential cracks and that significant time would be required to reduce the wall thickness of the vessel head to below the ASME code allowables demonstrates that an immediate safety concern does not exist.

4.0 B&WOG SAFETY EVALUATION

The B&WOG safety evaluation was essentially the same as the WOG and CEOG safety evaluations. The B&WOG analysis indicates that B&WOG plants have essentially the same susceptibility to PWSCC as the European plants based on operating temperature, residual stresses, and operational life. The B&WOG predicts short, axial flaws on the peripheral locations based on the results of finite element analyses. The B&WOG estimates that it would take 10 years from the time a flaw initiates on the inside diameter of a CRDM penetration until a leak appears. Once a leak starts, B&WOG concluded that it would take 6 years before enough corrosion would occur to reduce the wall thickness of the reactor vessel head to below ASME code minimums, and that this amount of leakage would be detected during surveillance walkdowns.

4.1 STAFF EVALUATION OF THE B&WOG SAFETY EVALUATION

The staff has concluded that the potential for PWSCC of CRDM for B&WOG plants does not create an immediate safety issue as long as the surveillance walkdowns required continue and as long as any leakage is corrected. The B&WOG analyses, indicating that the stresses would favor development of axial rather than circumferential cracks and that significant time would be required to reduce the wall thickness of the vessel head to below the ASME code allowables, demonstrates that an immediate safety concern does not exist.

5.0 PROPOSED FLAW ACCEPTANCE CRITERIA

On July 30, 1993, NUMARC submitted the proposed flaw acceptance criteria for flaws identified during inservice inspection of reactor vessel upper head penetrations to the NRC for review. These criteria were developed by utility technical staffs and the domestic PWR vendors. NUMARC proposes that axial flaws are permitted through-wall below the J-groove weld and 75 percent through-wall above the weld. There is no limit on the length of the flaws. NUMARC proposes that circumferential flaws through-wall and 75 percent around the penetration be allowed below the J-groove weld and that circumferential flaws above the weld could be 75 percent through-wall and 50 percent around the penetration. Proximity rules found in ASME Section XI, Figure IWA 3400-1 are proposed for determining the effective length of multiple flaws in one location. NUMARC proposes that the flaws be characterized by length and preferably depth. NUMARC proposes that if only the length is characterized, that the depth be assumed to be one half of the length based on inspection findings to date.

5.1 STAFF EVALUATION OF THE PROPOSED FLAW ACCEPTANCE CRITERIA

The staff finds the proposed flaw acceptance criteria acceptable for axial flaws because the criteria conform to the American Society of Mechanical Engineers (ASME) Section XI criteria. The assumption that flaw depth is one half the flaw length for flaws whose depth cannot be determined will limit the flaw length to 1.5 times the thickness of the penetration sleeve. However, it is expected that reasonable attempts will be made to determine flaw depths. Flaws found through inservice inspection (ISI) that are primarily axial (less than 45° from the axial direction) will be treated as axial flaws as indicated in Figure 1(b), (d), and (f) of NUMARC'S July 30, 1993 letter. Flaws more than 45° from the axial direction are considered to be circumferential flaws. Based upon information submitted to date and the more serious safety consequences of circumferential flaws, the staff has concluded that criteria for circumferential flaws should not be pre-approved. Detection of such flaws would be contrary to inspection results to date and to the conclusion of the Owners Groups evaluations. The circumstances associated with such a flaw would have to be well understood. Therefore, any circumferential flaws found through ISI, which a licensee proposes to leave in service without repair, will be reviewed on a case-by-case basis by the staff.

6.0 LEAKAGE MONITORING

NUMARC, through the owners groups' reports, determined that any leakage in excess of 1 gpm would be detected prior to any unstable extension of axial flaws. Also, leakage at less than 1 gpm would be detectable over time based on boric acid buildup as noted during periodic surveillance walkdowns. Although NUMARC has proposed, and the staff agrees, that low level leakage will not cause a significant safety issue to result, the staff determined that NUMARC should consider methods for detecting smaller leaks to provide defense-in-depth to account for any potential

uncertainty in its analyses. The reported leak rate at Bugey 3 was about 0.003 gpm and was detected using acoustic monitoring techniques during the performance of a hydrostatic test. The staff does not think that it is necessary to detect a 0.003 gpm leak, but does think that permitting leakage just below 1.0 gpm as currently proposed may be undesirable. Leakage of this magnitude would produce significant deposits (thousands of pounds/year) of boric acid on the reactor vessel head. Further, most facilities' technical specifications state that no pressure boundary leakage is permitted. The staff notes that small leaks resulting from flaws which progressed through-wall just prior to a refueling outage would be difficult to detect while the thermal insulation is installed. Although running for an additional cycle with that undetected leak would not result in a significant safety issue, the NUMARC should consider proposing a method for detecting leaks that are significantly less than 1.0 gpm, such as the installation of on-line monitoring equipment.

7 0 CONCLUSIONS

Based on review of the NUMARC submittal and the overseas inspection results, the staff concludes that the CRDM/CEDM cracking at the reactor vessel heads is not a significant safety issue at this time as long as the surveillance walkdowns in accordance with GL 88-05 continue. The staff agrees with the NUMARC's determination that there are no unreviewed safety questions associated with stress corrosion cracking of CRDM penetrations. However, new information and events may require a reassessment of the safety significance. Furthermore, there is a need to verify the conclusions of the NUMARC's safety evaluations. Therefore, nondestructive examinations should be performed to ensure there is no unexpected cracking in domestic PWRs. These examinations do not have to be conducted immediately since only short, shallow, axial flaws are likely to be present in the CRDM penetrations. The industry has committed to conduct inspections at three units in 1994. They are:

- (a) Point Beach Unit 1 in the Spring of 1994,
- (b) D.C. Cook Unit 2 in the third quarter of 1994,
- (c) Oconee Unit 2 in September 1994.

As the surveillance walkdowns proposed by NUMARC are not intended for detecting small leaks, it is conceivable that some affected PWRs could potentially operate with small undetected leakage at CRDM/CEDM penetrations. In this regard, the staff believes it is prudent for NUMARC to consider the implementation of an enhanced leakage detection method for detecting small leaks during plant operation.

The staff found NUMARC's flaw acceptance criteria acceptable for axial flaws but NRC review and approval of the disposition of any circumferential flaws will be required.

Technical Contacts:	Robert A. Hermann (301) 504-2768
	William H. Koo (301) 504-2706
	James A. Davis (301) 504-2713