

DUKE POWER COMPANY
Limited Examination Coverage Worksheet

NDE-91-1

Revision 0

Examination Volume/Area Defined

Base Metal Weld Near Surface Bolting Inner Radius

Area Calculation

$7.0" / 2 (1.375" + .85") = 7.79 = 7.8 \text{ sq.in.}$

Volume Calculation

$7.8 \text{ sq.in.} \times 21.5" = 167.7 \text{ cu.in.}$

Coverage Calculations

Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
1	0	NA	7.8	6.5	50.7	167.7	30.23
2	35	1	7.8	6.5	50.7	167.7	30.23
3	35	2	7.8	6.5	50.7	167.7	30.23
4	45	1	7.8	6.5	50.7	167.7	30.23
5	45	2	7.8	6.5	50.7	167.7	30.23
6	35	CW	7.8	6.5	50.7	167.7	30.23
7	35	CCW	7.8	6.5	50.7	167.7	30.23
8	45	CW	7.8	6.5	50.7	167.7	30.23
9	45	CCW	7.8	6.5	50.7	167.7	30.23

$456.3 / 1509.3 \times 100 = 30.2 \%$

Examination from the inside clad surface is impractical because of high radiation exposure.

*James J. McQuillan
 Level III UT*

Item No: B01.022.003

Prepared By: David Zimmerman *David Zimmerman* Level: II Date: 4/2/97

Reviewed By: Larry Mauldin *Larry Mauldin* Level: III Date: 4/17/97

4/17

DUKE POWER COMPANY
Limited Examination Coverage Worksheet

NDE-91-1

Revision 0

Examination Volume/Area Defined

Base Metal Weld Near Surface Bolting Inner Radius

Area Calculation

$$7.0" / 2 (3.5" + 3.8") + 7.0" / 2 (3.5" + 3.8") = 51.1 \text{ sq.in.}$$

Volume Calculation

$$51.1 \text{ sq.in.} \times 21 \text{ in.} = 1098.65 \text{ cu.in.}$$

Coverage Calculations

Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
1	0	NA	51.1	6.5	332.15	1098.65	30.23
2	35/45	1	51.1	6.5	332.15	1098.65	30.23
3	35/45	2	51.1	6.5	332.15	1098.65	30.23
4	35/45	CW	51.1	6.5	332.15	1098.65	30.23
5	35/45	CCW	51.1	6.5	332.15	1098.65	30.23

$$1660.75 / 5493.25 \times 100 = 30.2 \%$$

Item No: B01.022.003


Prepared By: David Zimmerman *David Zimmerman* Level: II Date: 4/2/97

Reviewed By: Larry Mauldin *Larry Mauldin* Level: III Date: 4/17/97

5-0/17

L109

CATAWBA UNIT 2 RPV HEAD




REDUCED TO 77%

SCALE 1/4" = 1.0"

I.D. # 2RPV-101-104G
ITEM # B01.022.003

BY: Lowell
DATE: 4/17/97
R. Mauldin III
4-16-97

CATAWBA UNIT #2 RPV HEAD MERIDIONAL VIEW



EXAM AREAS:

BASE MAT'L

A-B-C-D $\frac{7.0}{2} (3.5 + 3.8) = 25.55$
 E-F-G-H $\frac{7.0}{2} (3.5 + 3.9) = 25.55$
51.158 in.

WELD MAT'L

B-E-D-G $\frac{7.0}{2} (1.375 + .85) = 7.79 =$
7.858 in.

LENGTH INSPECTED 6.5"
 LENGTH NOT INSPECTED 15.0"
 TOTAL LENGTH 21.5"

REDUCED 10.77%
 SCALE 1/2" = 1.0"

I.D.# ZRPV-101-104G
 ITEM# B01.022.003

BY: David B.
 DATE: 4/27/97
 Lang Mueller III
 4.16.97

REQUEST FOR RELIEF
97-03
ATTACHMENT 3

DUKE POWER COMPANY ULTRASONIC EXAMINATION DATA SHEET FOR LAMINAR REFLECTORS													Exam Start: 12:52	NDE-UT-3A
													Exam Finish: 13:18	Revision 2
Station: Catawba			Unit: 2		Component/Weld ID: 2BNSHX-3-5							Date: 4/4/97		
Nominal Material Thickness (in): 0.75				Weld Length (in.): 165.63'				Surface Temperature: 75 Deg F						
Measured Material Thickness (in): .809				Lo: NORTH SIDE				Pyrometer S/N: MCNDE 27025						
Surface Condition: AS WELDED				Calibration Sheet No: 9702034				Cal Due: 9/20/97						
Examiner: Winfred C. Leeper <i>Winfred C. Leeper</i> Level: II			Configuration: Shell to Flange											
Examiner: Gayle E. Houser <i>Gayle Houser</i> Level: II			SHELL Flow FLANGE											
Procedure: NDE-640 Rev: 1 FC: *													S1 to S2	
IND NO.	Ampi ≥ rem BW LOB	L1 ≥ rem BW LOB	W1 ≥ rem BW LOB	Mp1 ≥ rem BW LOB	W2 ≥ rem BW LOB	Mp2 ≥ rem BW LOB	L2 ≥ rem BW LOB	W1 ≥ rem BW LOB	Mp1 ≥ rem BW LOB	W2 ≥ rem BW LOB	Mp2 ≥ rem BW LOB	Exam Surf.	Damps	
4														
NRI														

Remarks: * 95-18, 95-19													
										Limitations: see NDE-UT-4 <input checked="" type="checkbox"/> None: <input type="checkbox"/>			Sheet <u>1</u> of <u>5</u>
Reviewed By: Larry Mauldin <i>Larry Mauldin</i>		Level: III		Date: 4/15/97		Authorized Inspector: <i>Robert Mauldin</i>			Date: 5-7-97		Item No: C01.010.008		

DUKE POWER COMPANY

ULTRASONIC EXAMINATION DATA SHEET FOR PLANAR REFLECTORS

Exam Start: 13:20 Form NDE-UT-2A
 Exam Finish: 14:30 Revision 4

Station: Catawba	Unit: 2	Component/Weld ID: 2BNSHX-3-5	Date: 4/4/97
Weld Length (in.): 165.63'	Surface Condition: As Welded	Lo: N Side	Surface Temperature: <u>75</u> ° <u>F</u>
Examiner: Gayle E. Houser <i>Gayle Houser</i> Level: II	Scans:		Pyrometer S/N: <u>MCNDE 27025</u>
Examiner: Winfred C. Leeper <i>Winfred C. Leeper</i> Level: II	45 <input checked="" type="checkbox"/> <u>33.5</u> dB 70 <input type="checkbox"/> _____ dB		Cal Due: <u>9/20/97</u>
Procedure: NDE-630 Rev: 2 FC: N/A	45T <input checked="" type="checkbox"/> <u>43</u> dB 70T <input type="checkbox"/> _____ dB		Configuration: <u>Shell to Flange</u>
Calibration Sheet No: 9702035, 9702036, 9702037	60 <input type="checkbox"/> _____ dB		<u>SHELL</u> Flow <u>FLANGE</u>
	60T <input type="checkbox"/> _____ dB		<u>S1</u> to <u>S2</u>
	Other: <u>45°L --72</u> dB		Scan Surface: <u>OD</u>
			Applies to NDE-680 only
			Skew Angle: <u>NA</u>

IND #	<input checked="" type="checkbox"/>	Max % Ref	Mp Max	W Max	L Max	L1	L2	W1	Mp1	W2	Mp2	Beam Dir.	Exam Surf.	Scan	Damps
		DO NOT WRITE IN THIS SPACE				20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA	20%dac HMA		DO NOT WRITE IN THIS SPACE		
						50%dac	50%dac	50%dac	50%dac	50%dac	50%dac				
						100%dac	100%dac	100%dac	100%dac	100%dac	100%dac				
NRI															

Remarks:

Limitations: (see NDE-UT-4) 90% or greater coverage obtained: yes no

Reviewed By: *Larry Mauldin* Level: III Date: 4/15/97 Authorized Inspector: *Robert McMillan* Date: 5-7-97 Item No: C01.010.008

Sheet 2 of 5

**DUKE POWER COMPANY
ISI LIMITATION REPORT**

FORM NDE-UT-4

Revision 1

Component/Weld ID: 2BNSHX-3-5	Item No: C01.010.008	Remarks:
<input checked="" type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ NA _____ to L _____ NA _____ INCHES FROM WO _____ .85" _____ to _____ BEYOND _____ ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ 45°L _____ FROM _____ 0 _____ DEG to _____ 360 _____ DEG	SURFACE <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 BEAM DIRECTION <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	DUE TO FLANGE
<input type="checkbox"/> NO SCAN <input checked="" type="checkbox"/> LIMITED SCAN FROM L _____ NA _____ to L _____ NA _____ INCHES FROM WO _____ CL _____ to _____ .85" _____ ANGLE: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ 45°L _____ FROM _____ 0 _____ DEG to _____ 360 _____ DEG	SURFACE <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION <input type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	DUE TO AS WELDED CAP CONDITION. SCAN STOPPED AT TOE OF WELD.
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ INCHES FROM WO _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM _____ DEG to _____ DEG	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	
<input type="checkbox"/> NO SCAN <input type="checkbox"/> LIMITED SCAN FROM L _____ to L _____ INCHES FROM WO _____ to _____ ANGLE: <input type="checkbox"/> 0 <input type="checkbox"/> 45 <input type="checkbox"/> 60 <input type="checkbox"/> Other _____ FROM _____ DEG to _____ DEG	SURFACE <input type="checkbox"/> 1 <input type="checkbox"/> 2 BEAM DIRECTION <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> cw <input type="checkbox"/> ccw	

Prepared By: Gayle Houser <i>Gayle Houser</i>	Level: II	Date: 4/4/97	Sketch(s) attached <input checked="" type="checkbox"/> yes <input type="checkbox"/> no	Sheet <u>3</u> of <u>5</u>
Reviewed By: Larry Mauldin <i>Larry Mauldin</i>	Date: 4/15/97	Authorized Inspector: <i>Robert M. Sullivan</i>	Date: 5-7-97	

DUKE POWER COMPANY
Limited Examination Coverage Worksheet

NDE-91-1

Revision 0

4 of 5

Examination Volume/Area Defined

Base Metal Weld Near Surface Bolting Inner Radius

Area Calculation

$1.0" \times 2.7" - (.2" \times .25" / 2) - (.3" \times .25") =$
 $2.7 \text{ "sq.} - (.025" \text{ sq.}) - (.075" \text{ sq.}) =$
 $2.7 \text{ "sq.} - (.10" \text{ sq.}) = 2.6" \text{ sq.}$

Volume Calculation

$2.6" \text{ sq.} \times 165.63" = 430.64" \text{ cu.}$
 (Area) (Length)

Coverage Calculations

Scan #	Angle	Beam Direction	Area Examined (sq.in.)	Length Examined (in.)	Volume Examined (cu.in.)	Volume Required (cu.in.)	Percent Coverage
1	45	2	0	0	0	430.64	0.00
2	45	1	.4	165.63	66.3	430.64	15.40
3	45	CCW	2.6	165.63	430.64	430.64	100.00
4	45	CW	2.6	165.63	430.64	430.64	100.00

$927.58 / 1722.56 \times 100 = 53.85\%$

Item No: C01.010.008

Prepared By: Gayle Houser

Gayle Houser

Level: II

Date: 4/4/97

Reviewed By: Larry Mauldin


Larry Mauldin

Level: III

Date: 4/15/97

FLANGE (SUR. 2)

SHELL (SUR. 1)



NOTE: SCANNING ON WELD CAP WAS NOT POSSIBLE DUE TO "AS WELDED" CONDITION (AXIAL DIRECTION)

O.D. CAP ON WELD HAS RIPPERS 1/2" WIDE ENABLING CIRC. SCAN.

EXAM. AREA

$$ABFH - (GDE) - (CDEF) = 1.0 \times 2.7 - \left(\frac{2.0 \times 2.5}{2} \right) - (3.0 \times 2.5 \sin)$$

$$2.7 \text{ in}^2 - (0.25 \text{ in}^2) - (0.075 \text{ in}^2) = 2.6 \text{ in}^2$$

INSUF. AREA

$$BFIJ - (GDE) - (CDEF) = \frac{1.0 \text{ in} \times 1.0 \text{ in}}{2} - \left(\frac{2.0 \text{ in} \times 2.5 \text{ in}}{2} \right) - (3.0 \text{ in} \times 2.5 \text{ in})$$

$$0.5 \text{ in}^2 - (0.25 \text{ in}^2) - (0.075 \text{ in}^2) = 0.4 \text{ in}^2$$

PERCENT OF COVERAGE

$$\frac{0.4 \text{ in}^2}{2.6 \text{ in}^2} = 0.154 = 15.4\%$$

SCALE: 1" = 1"
 COI, 010.008
 2BNSHX-3-5

Stacy Hoover II
 4/14/97