

# The Light company

Houston Lighting & Power

P.O. Box 1700 Houston, Texas 77001 (713) 228-9211

July 20, 1988  
ST-HL-AE-2735  
File No.: G2.4  
10CFR2.201

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

South Texas Project Electric Generating Station  
Unit 1  
Docket No. STN 50-498  
Revised Response to Violation 8809-06

As stated in telephone conversations held on May 23, 1988 and in response to your letter dated June 28, 1988, HL&P submits the attached revised response to Notice of Violation 8809-06.

If you should have any questions on this matter, please contact Mr. M.A. McBurnett at (512) 972-8530.



G. E. Vaughn  
Vice President  
Nuclear Plant Operations

GEV/RAF/ni

Attachment: Revised Response to Notice of Violation 8809-06

8808030226 880720  
PDR ADOCK 05000498  
Q PDC

NL.88.196.01

A Subsidiary of Houston Industries Incorporated

LEO/  
1/1

cc:

Regional Administrator, Region IV  
Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, TX 76011

George Dick  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

Jack E. Bess  
Resident Inspector/Operations  
c/o U. S. Nuclear Regulatory Commission  
P. O. Box 910  
Bay City, TX 77414

Don L. Garrison  
Resident Inspector/Construction  
c/o U. S. Nuclear Regulatory Commission  
P. O. Box 910  
Bay City, TX 77414

J. R. Newman, Esquire  
Newman & Holtzinger, P.C.  
1615 L Street, N.W.  
Washington, DC 20036

R. L. Range/R. P. Verret  
Central Power & Light Company  
P. O. Box 2121  
Corpus Christi, TX 78403

R. John Miner (2 copies)  
Chief Operating Officer  
City of Austin Electric Utility  
721 Barton Springs Road  
Austin, TX 78704

R. J. Costello/M. T. Hardt  
City Public Service Board  
P. O. Box 1771  
San Antonio, TX 78296

Rufus S. Scott  
Associated General Counsel  
Houston Lighting & Power Company  
P. O. Box 1700  
Houston, TX 77001

INPO  
Records Center  
1100 Circle 75 Parkway  
Atlanta, Ga. 30339-3064

Dr. Joseph M. Hendrie  
50 Bellport Lane  
Bellport, NY 11713

South Texas Project Electric Generating Station  
Unit 1  
Docket No STN 50-498  
Response to Notice of Violation 8809-06

I. Statement of Violation

Test Procedure Adequacy and Implementation

Technical Specification 6.8.1 states, in part, that written procedures shall be established, implemented, and maintained as recommended in Appendix A of Regulatory Guide 1.33, Revision 2, February 1978.

Contrary to the above, on January 26, 1988, the licensee failed to reestablish the proper testing configuration as required by the note in Section 4.7 of Station Procedure 1TEP07-AF-0010, Revision 0, "Auxiliary Feedwater Proof Test," after interrupting the test to feed steam generators. This resulted in obtaining improper test results requiring a repeat of the test. On February 5, 1988, the licensee implemented an inadequate procedure. Station Procedure 1PEP04-ZL-0024, Revision 3, "Rod Drop Time Measurement" did not provide for closing the reactor trip breakers, nor did the procedure provide controls to ensure that the same breakers were opened upon recovering from the test.

II. Houston Lighting & Power Position

Houston Lighting & Power does not contest the violation.

III. Reason for Violation

The discrepancy identified during the conduct of the Auxiliary Feedwater Proof Test is attributed to inattention to detail on the part of the test coordinator.

The lack of control associated with the reactor trip breakers in procedure 1PEP04-ZL-0024, Rod Drop Time Measurement, was caused by an inadequate review during the generation and approval cycle, in that it was believed that the reactor trip breakers were operated as part of the procedure for starting/securing the Rod Control System Motor Generator sets. If this had been true the prerequisite section would have ensured the breakers closed and the breakers would have been opened when the Shift Supervisors secured the M/G set after being informed that the testing had been completed.

IV. Corrective Actions That Have Been Taken

Procedure 1TEP07-AF-0010, Auxiliary Feedwater Proof Test was reperforme d.

Procedure 1PEP04-ZL-0024, Rod Drop Time Measurement, was changed to incorporate specific steps to control the position of the reactor trip breakers. This was done to provide consistency between various plant procedures.

V. Corrective Actions That Will Be Taken

No further corrective actions are deemed necessary.

VI Full Compliance

The plant is in full compliance.