



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

MAY 14 1985


MEMORANDUM FOR: Dennis M. Crutchfield, Assistant Director
Division of Licensing

FROM: Robert J. Bosnak, Acting Assistant Director for
Components & Structures Engineering
Division of Engineering

SUBJECT: FINAL DRAFT OF THE RIVER BEND UNIT 1 TECHNICAL
SPECIFICATION

As requested in your memo dated April 19, 1985, on above subject, the River Bend Unit 1 Technical Specifications under Containment Systems, Primary Containment Purge System, Limiting Conditions for Operations (3/4 6-14) do not reflect the content of the SER sent to DL from DE (R. Bosnak to T. Novak) dated February 15, 1985. The 36-inch valves must be limited to an opening angle of 65° or less and the 24-inch and 8-inch valves have not been demonstrated operable. These latter size valves, 24-inch and 8-inch, must be closed during operation modes 1, 2, 3 and 4.

? I don't see why?


Robert J. Bosnak, Acting Assistant Director
for Components & Structures Engineering
Division of Engineering

cc: J. Knight
S. Stein
D. Houston
R. Wright
R. LaGrange

85052306 34XA
4

B/9