

August 1, 1997

Mr. Nicholas J. Liparulo, Manager  
Nuclear Safety and Regulatory Analysis  
Nuclear and Advanced Technology Division  
Westinghouse Electric Corporation  
P.O. Box 355  
Pittsburgh, PA 15230

SUBJECT: AP600 SHUTDOWN EVALUATION REPORT REQUEST FOR ADDITIONAL INFORMATION

Dear Mr. Liparulo:

Westinghouse letter NSD-NRC-97-5164 dated June 6, 1997, submitted Revision 1 of WCAP-14837, "AP600 Shutdown Evaluation Report." The report discusses the shutdown risks and safety concerns related to the AP600 design and evaluates those design features which mitigate the consequences of events which can occur during shutdown. The Nuclear Regulatory Commission (NRC) staff is reviewing this report and has some requests for additional information (RAIs). The RAIs are provided as an enclosure to this letter. The staff notes that the review of this report is not yet complete and additional RAIs may be forthcoming.

If you have any questions regarding this matter, you may contact me at (301) 415-1141.

Sincerely,

Original signed by

William C. Huffman, Project Manager  
Standardization Project Directorate  
Division of Reactor Program Management  
Office of Nuclear Reactor Regulation

Docket No. 52-003

Enclosure: As stated

cc w/enclosure:  
See next page

DISTRIBUTION:

Docket File

PUBLIC

TKenyon

DJackson

ADG (11)

JLyons, 0-8 E23

HWalker, 0-8 D1

PDST R/F

SWeiss

BHuffman

JMoore, 0-15 B18

GHolahan, 0-8 E2

ALevin, 0-8 E23

CLi, 0-8 D1

MSlosson

TRQuay

JSebrosky

WDean, 0-5 E23

SNewberry, 0-8 E2

DDiec, 0-8 E23

DF03/1

070060

DOCUMENT NAME: A:SD-EVAL.RAI

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PDST:DRPM	BC:PDST:DRPM			
NAME	WCHuffman <i>WCH</i>	TRQuay <i>TRQ</i>			
DATE	8/1/97	8/1/97			

OFFICIAL RECORD COPY

**NRC FILE CENTER COPY**

9708070214 970801  
PDR ADOCK 05200003  
A PDR



Mr. Nicholas J. Liparulo  
Westinghouse Electric Corporation

Docket No. 52-003  
AP600

cc: Mr. B. A. McIntyre  
Advanced Plant Safety & Licensing  
Westinghouse Electric Corporation  
Energy Systems Business Unit  
P.O. Box 355  
Pittsburgh, PA 15230

Mr. Ronald Simard, Director  
Advanced Reactor Programs  
Nuclear Energy Institute  
1776 Eye Street, N.W.  
Suite 300  
Washington, DC 20006-3706

Ms. Cindy L. Haag  
Advanced Plant Safety & Licensing  
Westinghouse Electric Corporation  
Energy Systems Business Unit  
Box 355  
Pittsburgh, PA 15230

Ms. Lynn Connor  
Doc-Search Associates  
Post Office Box 34  
Cabin John, MD 20818

Mr. M. D. Beaumont  
Nuclear and Advanced Technology Division  
Westinghouse Electric Corporation  
One Montrose Metro  
11921 Rockville Pike  
Suite 350  
Rockville, MD 20852

Mr. James E. Quinn, Projects Manager  
LMR and SBWR Programs  
GE Nuclear Energy  
175 Curtner Avenue, M/C 165  
San Jose, CA 95125

Mr. Sterling Franks  
U.S. Department of Energy  
NE-50  
19901 Germantown Road  
Germantown, MD 20874

Mr. Robert H. Buchholz  
GE Nuclear Energy  
175 Curtner Avenue, MC-781  
San Jose, CA 95125

Mr. S. M. Modro  
Nuclear Systems Analysis Technologies  
Lockheed Idaho Technologies Company  
Post Office Box 1625  
Idaho Falls, ID 83415

Barton Z. Cowan, Esq.  
Eckert Seamans Cherin & Mellott  
600 Grant Street 42nd Floor  
Pittsburgh, PA 15219

Mr. Frank A. Ross  
U.S. Department of Energy, NE-42  
Office of LWR Safety and Technology  
19901 Germantown Road  
Germantown, MD 20874

Mr. Ed Rodwell, Manager  
PWR Design Certification  
Electric Power Research Institute  
3412 Hillview Avenue  
Palo Alto, CA 94303

Mr. Charles Thompson, Nuclear Engineer  
AP600 Certification  
NE-50  
19901 Germantown Road  
Germantown, MD 20874

**AP600 SHUTDOWN EVALUATION REPORT  
REQUEST FOR ADDITIONAL INFORMATION**

- 440.684 Section 2.1.2.1 indicates that the AP600 steam generator nozzle dam is installed with the hot leg level much higher than the traditional designs. Please provide a detailed drawing and discussion of the nozzle dam design. Discuss the nozzle dam installation process during shutdown and refueling operation to preclude potential inadvertent RCS repressurization. Also provide a comparison between the traditional nozzle dam design(s) and AP600 nozzle dam's insertion with respect to the hot leg level.
- 440.685 Section 2.1.2.1 also states that sufficient RCS vent path through the pressurizer is established when the coolant level in the hot leg is at 80% of the hot leg level. Table 2.1-1 shows that coolant level at the top of the hot leg is at 31 inches and therefore, a sufficient RCS vent path through the pressurizer at 80% of the hot leg level is 24.8 inches. However, the nominal water level for mid-loop operation is set at 27.74 inches, which is much higher than the 80% hot leg level. Please clarify and provide a programmatic approach to the adequacy of RCS venting, while maintaining a maximized mid-loop level operation. Where will this programmatic approach be implemented or recommended to be followed by the COL applicants?
- 440.686 Section 2.1.2.2 indicates that a manual isolation of letdown on low hot leg level capability is provided and actuation of IRWST on (low) empty hot leg level is also provided. Is the IRWST actuation automatic? Are alarm and valves position indications associated with these signals provided in the control room and on the remote shutdown console?
- 440.687 Section 2.1.2.2 states that the IRWST injection is actuated 30-minutes after receipt of the empty hot leg level signal. Table 2.3-2 indicates that it would take 59-minutes to boil empty the hot leg and an additional 43-minutes to expose the core. The 30-minutes time delay for IRWST injection would allow only 13-minutes to the start of core uncover to reestablish level or take other corrective actions if IRWST injection failed. What operator actions would be taken to reestablish core cooling in this situation and when would these actions be initiated? How will the necessary operator actions be captured and appropriately incorporated into the emergency operating procedures for shutdown and refueling operation?
- 440.688 Table 2.1-1 gives comparison between various hot leg level elevations and time-to-drain, assuming a nominal RCS drain rate of 20gpm. Is this drain rate required when the water level is at the top of the hot leg? Where will this important design/operation information be captured?
- 440.689 The draining time in Table 2.1-1 (assuming a nominal 20gpm drain rate) appears to be inconsistent and is not linear for the water to drain from the top of the hot leg level to the nominal water level for midloop operation elevation, to the low level alarm set point and to the auto-isolation of letdown. Please explain.

Enclosure

- 440.690 Page 2.1-8, RCS Hot Leg Wide-range Temperatures, indicates that safety-related hot leg temperature detectors are provided. The temperature detector's accuracy is highly flow dependent. What are assurances in place for a continuous RCS flow and a credited RCS temperature detection capability? Incore thermocouples are available for midloop operation when the vessel head is on, however, they will not be available when the vessel head is off (i.e., detensioned and instruments disconnected in preparation for refueling activities) to detect changes in RCS temperature and the wide-range hot leg temperature detectors can not reliably measure temperatures at the no RCS flow condition. Discuss how AP600 design would cope with this situation.
- 440.691 Section 2.1.2.4 identifies the dedicated drain path, which is used to drain the RCS water during a normal draindown process and is controlled from the main control room. Does this dedicated drain path display information in the control room (i.e., dedicated refueling trees information panel)? How will this improved feature be captured in the ITAAC program?
- 440.692 Section 2.1.2.4, second paragraph, it is stated that the letdown flow control valve as well as the letdown line containment isolation valve will receive a signal to automatically close once the appropriate level is attained. Define the appropriate RCS level, and discuss as to how manually controlled letdown would interact with auto-isolation signal to close the letdown control valve and the letdown line containment isolation valve. Are these functions captured and included in the ITAAC program?
- 440.693 The next to the last paragraph in Section 2.1.3.2 states that pressurizer heaters are de-energized and spray flow is used to cool the pressurizer and maintain the required RCP suction pressure. In the subsequent paragraph states that the pressurizer heaters continue to operate to maintain system pressure for RCP operations. Clarify the usage of the pressurizer heaters with respect to temperatures and pressures during the RCS cooldown and depressurization process.
- 440.694 Section 2.1.3.3 states that at the appropriate time during the cooldown, the operator can initiate the drain-down. Define the optimum time after plant shut down that the operator can initiate the drain-down process. Is this time part of the design and operational defense-in-depth during shutdown and refueling for AP600? Where will this insight be implemented or recommended to be followed by the COL applicants?
- 440.695 Section 2.3.1 states that during refueling operations when the IRWST water has been drained into the refueling cavity, other passive means of core decay heat removal are used. Identify what other passive means are used for emergency core decay heat removal and how they will be maintained.
- 440.696 Table 2.3-1, from Mode 5 RCS pressure boundary open to Mode 6 reactor internal in- place and refueling cavity not full, indicates that one

IRWST path is available. The IRWST injection capability can be challenged during these modes and there will be no other alternative emergency core cooling available if the only available injection capability is rendered inoperable. Discuss why a single IRWST injection path is sufficient for these conditions, where RCS inventory is at the smallest available volume and the ADS operability would do little to help cool the core if there is no emergency core makeup and cooling available.

- 440.697 Section 2.3.2.3 indicates that manual actuation of the IRWST is relied upon to mitigate loss of inventory/cooling events. Provide a list of ERGs reference and discuss how IRWST injection capability would be used in these events.
- 440.698 Section 2.3.3.2 indicates that the RNS relief valve would open if the operator failed to perform the required action in a loss of RNS cooling during shutdown operations. Provide a list of the RNS system parameters display and alarm in the control room and discuss how they would be maintained throughout the shutdown and refueling operations.
- 440.699 Section 2.3.3.3 states that makeup from CMTs is possible in the event of a loss of RNS cooling during midloop operation. Identify CMTs maintenance provisions that allow the tanks to be available during shutdown and refueling operations. Will this insight be proceduralized and made available as vendor shutdown and refueling guidelines for the COL applicants? Identify other potential sources, not including IRWST, that can be used as additional insights for the COL applicants.
- 440.700 Section 2.4.2.1 indicates that a large NPSH provides the RNS pump the capability to operate during midloop conditions with saturated fluid in the RCS without throttling the RNS flow. Discuss the NPSH requires for this configuration. Will the required NPSH be included in the ITAAC program?
- 440.701 Section 2.4.2.3 discusses the ability to align the RNS to take suction from the IRWST as a diverse method for IRWST injection, regardless whether the RNS pumps are operating. Identify and discuss flow path, valves positions and injection controls (flow rates) with the pumps not running. Will this insight be proceduralized and made available as vendor shutdown and refueling guidelines for the COL applicants?
- 440.702 Table 2.3-2 indicates that RCS boiling would occur 17-minutes after a loss of RMS capability during midloop operation. Discuss the decay heat rate and assumptions used in the analysis, and an optimum time for AP600 to enter midloop conditions. Compare the decay heat rates and time to boil during a forced outage from a steam generator tube leaks with a normal shutdown for refueling. Provide and discuss the AP600 refueling outage plan that would minimize, not only the occupational exposure to refueling personnel, but also the risk of RCS boiling.
- 440.703 LTOP protection of the RCS and RNS was implemented in the design. Discuss LTOP's actuation and indication capabilities (i.e., flow indications and information display locations).

- 440.704 The RNS provides cooling for IRWST as discussed in Section 2.4.3.4 and that both RNS divisions are also required to maintain the RCS decay heat removal function during the cool down as discussed in Section 2.4.3.2. Discuss the design capacity of the RNS that supports simultaneous RCS and IRWST cooling.
- 440.705 The RNS can also provide cooling to the spent fuel pool with the suction connection line located at 4-feet below the SFS pump suction connection. Discuss the potential over-draining of the spent fuel pool due to the inadvertent operation of both the SFS and the RNS for fuel pool cooling.
- 440.706 Section 2.8 discusses the spent fuel cooling system. Provide detailed drawings showing the relative elevations of the IRWST, refueling cavity, reactor cavity, fuel transfer canal from the reactor floor. In addition, identify potential scenarios which could result in a loss of refueling water and the impact during spent fuel assembly movement. Discuss the ability to quickly move and safely store fuel assembly.
- 440.707 The PCS supplies water for fire protection alternatives. Provide analysis discussion of the PCS required water volume and flow rates, which simultaneously satisfy both SFS emergency makeup and fire protection alternative.
- 440.708 It is stated in Section 2.8 that an isolation valve in the refueling cavity drain line to the SGS compartment is closed only immediately before refueling operations. During other plant conditions this valve is locked open to prevent overfilling the refueling cavity during an accident. However, it is also stated that the drain line elevation allows accommodation of the possible estimated 38,200 gallons of IRWST overflow without draining to the SGS during the non-refueling plant conditions. Clarify whether the IRWST overflow can be accomplished with the refueling cavity drain isolation valve locked open during plant non-refueling conditions.
- 440.709 Also in Section 2.8, it is stated that a connection line from the SFS to the CVS makeup pump allows the use of the spent fuel pool borated water as a backup source of RCS makeup. Discuss plant conditions which warrant the use of this configuration. Where will this insight be implemented or recommended to be followed by the COL applicants?
- 440.710 Section 2.8.2.1 discusses the use of a permanent reactor cavity seal. Provide the seal design reference, detailed drawing showing the seal design and its connection to the reactor vessel cavity.
- 440.711 Table 2.8-2 shows five different case studies for spent fuel protection. Please provide additional explanation on how this table relates to Table 2.8-1. What is the meaning of the different fuel water coverage levels at 7 days? What is the minimum level required to be maintained above the spent fuel and how is it maintained? Please provide additional details of the initial assumption and necessary actions and safety conclusion for each of these cases.

- 440.712 The RCS Hot leg level indication system is used to monitor water at midloop condition. The ability to accurately measure the RCS water level at midloop condition is very important to ensure that adequate decay heat removal capability is maintained. Discuss the ability to accurately measure the RCS level during midloop operating condition using the RCS hot leg level monitoring system. Define the system accuracy.
- 440.713 Section 4.8 discusses the results of analyses for LOCA events initiated from shutdown modes. In these analyses, initial decay heat in the core was based on the initial conditions of the hot leg temperature of 425°F and the cooldown rate of 50°F/hr. Justify that these initial conditions are the limiting conditions for Mode 3 LOCA calculations.
- 440.714 Section 4.8.4 discusses SBLOCAs from a DEDVI line break and an inadvertent ADS opening events. SSAR Section 15.6.5B (Rev. 13), however, indicates that the limiting SBLOCA case is the 10-inch break, resulting in the minimum RCS inventory of 75,000lbs. Explain why the 10-inch break was not reanalyzed for Mode 3 condition. The limiting SBLOCA cases resulting from all modes of operation should be included in the SSAR and should be provided for staff review.
- 440.715 Section 4.10.2 indicates that PRHR HX capability to meet the safe shutdown temperature is dependent on condensate from the containment shell being returned to the IRWST. If condensate is returned to the IRWST, then safe shutdown using the PRHR HX can be maintained indefinitely. However, if condensate is not returned to the IRWST, PRHR heat removal can only be sustained for 72 hours. It further states that in about twenty-two hours after the loss of a normal feedwater event, if no AC power was available, or if condensate return was not available, the operator would be instructed to actuate the ADS to depressurize and cool down the plant to below 420°F. Where is this guidance implemented in the ERGs and its supporting analyses?
- 440.716 SSAR Section 15.1.5 discusses the results of the analysis for a limiting case SLB that initiates from zero power (Mode 2) condition. The analysis takes account for the reactor trip and CMT actuation on the "S" signals. The "S" signals are actuated on the setpoints of low pressurizer pressure, low steam line pressure and low cold leg temperature. Table 3.3.2-1 of the TS requires that the "S" signals be blocked when the pressurizer pressure is below the P-11 setpoint (interlock). Discuss the effects of P-11 interlock considered in the SLB analysis with the pressure below P-11 setpoint for Mode 2 operation.
- 440.717 In SSAR Section 15.1.2.2.2, it is stated that the analysis results of excessive increase in feedwater flow are bounded by the analysis results of an uncontrolled rod cluster control assembly bank withdrawal from a subcritical or low-power startup condition. Provide an analysis to support the above statement.

- 440.718 Section 2.5 discusses the used of two trains of CCS and service water system, which are needed for spent fuel pool cooling and RNS cooling during refueling operation. Explain the consequences of a failure of both trains of the CCS during the refueling operation.
- 440.719 Table 3.1-1, designer recommendations for RTNSS-Important Nonsafety-related Systems that apply to shutdown, identifies that both Normal Residual Heat Removal Systems (RNS) subsystems, Component Cooling Water System (CCS) subsystems, Service Water Systems and, AC power should be available during reduced inventory operations when they are required for decay heat removal. Identify fire areas or zones and describe in details the fire protection provided to protect each of these systems from their redundant system during refueling and shutdown conditions. Provide reference drawings, including cable routings, associated with each of these systems.
- Westinghouse is also requested to address high impedance faults, breaker coordinations and spurious operations to ensure that the redundant decay heat removal systems and associated equipment are protected from a fire.
- 440.720 The NRC has concluded that the current PRA for risks associated with fire does not accurately evaluate the facility as described in the SSAR. Provide a revised Shutdown Evaluation Report reflecting the actual plant design described in the SSAR.

#### EDITORIAL COMMENTS

1. In Section 2.2 system names are not consistent with the SSAR. For example, Main FW system and Startup FW system in the SSAR are called SGS feedwater subsystem and startup feedwater subsystem in WCAP-14837.
1. The 3rd bullet on P.2.9-7 should also include "Trip Turbine" to make it consistent with SSAR Rev.12, P.7.7-16.
3. The last sentence on P.2.9-8 refers to subsection 7.7-11 of the SSAR for additional information on the DAS rather than subsection 7.7.1.11.