



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DETROIT EDISON COMPANY

WOLVERTINE POWER SUPPLY COOPERATIVE, INCORPORATED

DOCKET NO. 50-341

FERMI-2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 23
License No. NPF-43


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Detroit Edison Company (the licensee) dated November 20, 1987, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. NPF-43 is hereby amended to read as follows:

Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No.23 , and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. DECo shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Martin J. Virgilio, Director
Project Directorate III-1
Division of Reactor Projects - III,
IV, V & Special Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: July 28, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 23

FACILITY OPERATING LICENSE NO. NPF-43

DOCKET NO. 50-341

Replace the following page of the Appendix "A" Technical Specifications with the attached page. The revised page is identified by Amendment number and contains a vertical line indicating the area of change. The corresponding overleaf page is also provided to maintain document completeness.

REMOVE

3/4 3-77

INSERT

3/4 3-77

TABLE 3.3.7.12-1 (Continued)

RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION

| | <u>INSTRUMENT</u> | <u>MINIMUM CHANNELS OPERABLE</u> | <u>APPLICABILITY</u> | <u>ACTION</u> |
|----|--|--------------------------------------|----------------------|---------------|
| 4. | TURBINE BLDG. VENTILATION MONITORING SYSTEM | | | |
| | a. Noble Gas Activity Monitor | 1 | * | 121 |
| | b. Iodine Sampler | 1 | * | 122 |
| | c. Particulate Sampler | 1 | * | 122 |
| | d. Sampler Flow Rate Monitor | 1 | * | 123 |
| 5. | SERVICE BUILDING VENTILATION MONITORING SYSTEM | | | |
| | a. Noble Gas Activity Monitor | 1 | * | 121 |
| | b. Iodine Sampler | 1 | * | 122 |
| | c. Particulate Sampler | 1 | * | 122 |
| | d. Sampler Flow Rate Monitor | 1 | * | 123 |

TABLE 3.3.7.12-1

RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION

| | <u>INSTRUMENT</u> | <u>MINIMUM CHANNELS OPERABLE</u> | <u>APPLICABILITY</u> | <u>ACTION</u> |
|----|---|--------------------------------------|----------------------|---------------|
| 1. | REACTOR BUILDING EXHAUST PLENUM EFFLUENT MONITORING SYSTEM | | | |
| a. | Noble Gas Activity Monitor - Providing Alarm | 1 | * | 121 |
| b. | Iodine Sampler | 1 | * | 122 |
| c. | Particulate Sampler | 1 | * | 122 |
| d. | Sampler Flow Rate Monitor | 1 | * | 123 |
| 2. | OFFGAS MONITORING SYSTEM (At the 2.2 minute delay piping) | | | |
| a. | Hydrogen Monitor | 1 | ** | 124 |
| b. | Noble Gas Activity Monitor | 1 | *** | 126 |
| 3. | STANDBY GAS TREATMENT SYSTEM | | | |
| a. | Noble Gas Activity Monitor - Providing Alarm | 1 | # | 125 |
| b. | Iodine Sampler | 1 | # | 122 |
| c. | Particulate Sampler | 1 | # | 122 |
| d. | Sampler Flow Rate Monitor | 1 | # | 123 |