



SAFEGUARDS INFORMATION

UNITED STATES
NUCLEAR REGULATORY COMMISSION

REGION II
101 MARIETTA STREET, N.W.
ATLANTA, GEORGIA 30323

Report Nos.: 50-424/88-14 and 50-425/88-11

Licensee: Georgia Power Company
P. O. Box 4545
Atlanta, GA 30302

Docket Nos.: 50-424 and 50-425

License Nos.: NPF-68 and CPPR-109

Facility Name: Vogtle 1 and 2

Inspection Conducted: February 22-26, 1988

Inspectors:

A. Tillman
A. Tillman, Physical Security Inspector

3/24/88
Date Signed

Cynthia Perry
Cynthia Perry, Physical Security Inspector

3/28/88
Date Signed

Approved by:

D. R. McGuire
D. R. McGuire, Chief, Physical Security Section
Nuclear Materials Safety and Safeguards Branch
Division of Radiation Safety and Safeguards

3/28/88
Date Signed

SUMMARY

Scope: This routine, unannounced physical security inspection included a review and inspection of: Management Effectiveness - Security Program; Security Program Audit; Records and Reports; Testing and Maintenance; Locks, Keys, and Combinations; Compensatory Measures; Access Control - Personnel; Access Control - Packages; Access Control - Vehicles, and Physical Protection Safeguards Information. The status of corrective actions for previously cited violations and licensee reported Physical Security Events was also reviewed. In addition, the inspectors attended the Project Director's weekly meeting on the status of Unit Two construction and installation of security related facilities and equipment, toured Unit Two facilities, and discussed the Unit Two readiness review with the Manager of Readiness Review Group.

Results: Five violations of regulatory requirements were identified.

1. Failure to control access to a vital area.
2. Failure to control access to the protected area.
3. Failure to provide detection capability for areas of the protected area barrier.
4. Security officer asleep on post.
5. Failure to control and secure Safeguards Information.

ENCLOSURE CONTAINS
SAFEGUARDS INFORMATION
UPON SEPARATION THIS
PAGE IS DECONTROLLED.

SAFEGUARDS INFORMATION