#### LICENSEE EVENT REPORT (LER

ACIENT MARK III										OCKET NU		700	.7		I C			
Las	alle	Coun	су	stat	10n Uni	t 1					10	15 0	0	0 3	11 3	1 OF	101	
	sed F	ire l	Pro	tect	ion Sur	veillanc	e by	Mecha	nical	Maint	enance De	partme	ent					
EVE	NT DATE	(6)				(6)	RE	PORT DAT	E (7)		OTHER P	ACILITIES	INVOL	VED (8)				
HTMON	DAY	YEAR	YEAR BEQU		BEQUENTIAL	REVISION	MONTH	DAY	YEAR	FACILITY NAMES				DOCKET NUMBERIS				
										LaSalle Unit 2				0 15 10 10 10 13 17 14				
1 1	30	8   5	8	5	069	- 00	1 2	20	3 5					0   5	10 10	101	1.1	
OPE	PATING		THIS	REPOR	T IS BUSMITTI	D PURSUANT	O THE R	EQUIREM	ENTS OF 10	CFR 9. /C	thack one or more of	the follow	nng) (11	1				
MODE (9) 5		20.402751			20.406(c) \$0.73(a)			90.73(a)(2)(iv)	(a)(2)(iv)			73.71(b)						
100 0 10 10			20.406(a)(1)(i)			80.38(e)(1) 80.73(a)(2)(v) 80.73(a)(2)(vi) 80.73(a)(2)(vii)			60.73(a)(2)(v)			71	1.71(e)					
			20.406(a)(1)(N)						90.73(a)(2)(vii)			OTHER (Specify in Abstract						
					(a)(1)(W)	X	60.73(a				80.73(a)(2)(vill)(A			36	SA/			
				30.406 (a) (1) (iv)							80.73(a)(2)(viii)(B	)						
				20.406	(0)(1)(+)		60.73ta				80,73(a)(2)(x)							
AME						-	ICEMBEE	CONTACT	FOR THIS	LEM (12)		_	_	TEL EPHO	NE NUM	IER.		
												AREA		TELETINO	THE HORN			
Ter	mur W.	Wien	mho	1+	extensi	on 534						81	115	315	7 1 -	16 17	1611	
101	7 11 -	11.4.6.1	1010	20,			EACH CO	OMPONEN	T FAILURE	DESCRIBE	D IN THIS REPORT	the state of the s	-1/1	2/2	1, 1	101	1-1-	
CAUSE	SYSTEM	COMP	OMPONENT		MANUFAC TURER	REPORTABLE TO NPROS			CAUSE	SYSTEM	COMPONENT	MANUFAC- TURER		REPORTABLE TO NPROS				
А	KIP	ZIZ	1 ZI	ZZ	1 21 2 12	N					1-1-1-							
	1	1	11									1.1						
SUPPLEMENTAL REPORT EXPECTED (14)											XPECTE	n	MONTH	DAY	YEAR			
												SU	BMISSIO	ON				
_																		

LMS-FP-15, "Monthly Inspection of Tech Spec Fire Hose Stations", was not performed within the time interval specified by Technical Specifications.

The Mechanical Maintenance Department Surveillance Foreman prepared his work schedule correctly scheduling IMS-FP-15 for completion prior to its due date. Then he left for vacation after inadequately turning over his responsibilities to another Maintenance Foreman who had no previous experience as Surveillance Coordinator. The temporary Foreman did not understand the significance of exceeding the "critical date" of a surveillance and incorrectly rescheduled IMS-FP-15 without attempting to find out whether the original scheduled completion date was essential. The General Foreman failed to ensure an adequate turnover was performed and failed to detect that the scheduled test was not done as required.

The following corrective actions were taken; LMS-FP-15 was successfully completed, all Foremen involved were reprimanded and all Mechanical Maintenance Management were retrained on the significance of "Priority", "Due" and "Critical" parameters of the LSCS General Surveillance Program.

8601020662 851220 PDR ADDCK 05000373 S PDR IEZZ

NRC Form 386A (9-63)

#### LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

US NUCLEAR REGULATORY COMMISSION
APPROVED OMB NO 3150-0104
EXPIRES 8/31/85

FACILITY NAME (1)	DOCKET NUMBER (2)		L	ER NUMBER (6)	PAGE (3)			
		YEAR	I	SEQUENTIAL NUMBER	REVISION			
LaSalle County Station Unit 1	0  5  0  0  0   3  7	13 815	-	01619	-010	012	OF	013

TEXT (If more apace is required, use additional NRC Form 366.4's) (17)

#### I. EVENT DESCRIPTION

LaSalle Unit 1 was in its first refuel with no fuel in the core and Unit 2 was in Cold Shutdown.

On December 2, 1985, the Station Fire Marshal was notified that surveillance LMS-FP-15, "Monthly Fire Inspection of Tech Spec Fire Hose Stations" (KP), was past due but was in progress. On December 3, 1985, the Unit 1 Operating Engineer was notified that LMS-FP-15 was past due and past the critical due date. The uninspected fire hose stations were declared inoperable pursuant to Technical Specification 4.0.3. The 1 hour Action Statement required in Technical Specification 3.7.5.4 had not been satisfied. LMS-FP-15 was successfully completed on December 3, 1985.

Surveillance Coordination in the LSCS Mechanical Maintenance Department is performed by the Maintenance Foreman whose crew of Mechanics performs surveillances and lubrication. On November 21, 1985, the Surveillance Foreman prepared his work schedule for the week of November 25, 1985. He scheduled LMS-FP-15 to be started on November 25, 1985, and completed by November 27, 1985. LMS-FP-15 was due on November 29 and past critical (outside the 3.25 month Technical Specification maximum time interval) after November 30. The 7-day grace period had been reduced to one day because the September surveillance was delayed by fire hose replacement done at the same time.

On November 22, 1985, the Surveillance Foreman left for vacation. His crew was assigned to another Maintenance Foreman who had no previous experience as Surveillance Coordinator. The Surveillance Foreman turned over his work schedule.

On November 25, 1985, the temporary Surveillance Foreman, who was now directing 12 Mechanics instead of the usual crew of 6, decided that his manpower was insufficient to perform LMS-FP-15. The temporary Foreman was not aware of the significance of postponing a surveillance required by Technical Specifications. The temporary Foreman rescheduled LMS-FP-15 for the week of December 2.

# II. CAUSES

The causes of missing the required test interval on IMS-FP-15 were personnel error, incomplete training, and inadequate turnover.

- 1. The permanent Surveillance Foreman failed to provide adequate turnover to the temporary Foreman.
- 2. The temporary Foreman rescheduled IMS-FP-15 without attempting to find out whether the original scheduled completion date was essential.
- 3. The temporary Foreman did not understand the significance of exceeding the "Critical Date" of a surveillance.

NRC Ferm 364A 19-631	LICENSEE EVENT RE	PORT (LER) TEXT CONTIN	UATIO	APPROVED OMB NO 3150-0104 EXPIRES 8/31/85					
FACILITY NAME (1)		DOCKET NUMBER (2)		L			PAGE (3)		
			YEAR		SEQUENTIAL	MEVISION		П	
LaSalle Cou	unty Station Unit 1	0 15 10 10 10 13 1 71	3 8 15	_	0 1 61 9	- 010	013	OF	013

## II. CAUSES (Continued)

The General Foreman failed to ensure an adequate turnover was performed, and failed to detect the scheduled test that was not done.

## III. PROBABLE CONSEQUENCES OF THE OCCURRENCE

Consequences of the late performance of LMS-FP-15 were minimal. All required fire equipment was at the fire hose stations as required by Technical Specification 4.7.9.4.a. Safe operation of the plant was maintained at all times.

#### IV. CORRECTIVE ACTIONS

- 1. On December 3, 1985, LMS-FP-15 was successfully completed.
- 2. On December 3, 1985, Mechanical Maintenance Management was retrained on the importance of performing surveillances when due and trained on the significance of "Critical Dates", "Priority" parameters of the LSCS General Surveillance Program. All Mechanical Maintenance Management received documented training by December 4, 1985.
- The Surveillance Foreman and General Foreman were reprimanded because 3. turnover of the surveillance work was inadequate. They were counseled concerning the importance of adequate work turnover.
- The temporary Surveillance Foreman was reprimanded for rescheduling IMS-FP-15 without attempting to find out whether or not it was important to do as scheduled.

#### PREVIOUS OCCURRENCES V.

Four other events of a similar nature were documented by LER's:

82-007/03L-0 82-035/03L-0 83-151/03L-0 83-004/03L-0

## VI. NAME AND TELEPHONE NUMER OF PREPARER

Terry W. Wiemholt, Technical Staff Engineer, 815/357-6761, extension 534.

December 20, 1985

U.S. Nuclear Regulatory Commission Document Control Desk Washington, D.C. 20555

Dear Sir:

Reportable Occurrence Report #85-069-00, Docket #050-373 is being submitted to your office in accordance with 10CFR 50.73.

> CE Sargent G. J. Diederich A Station Manager LaSalle County Station

GJD/DRR/kg

Enclosure

xc: NRC, Regional Director INPO-Records Center

File/NRC