

APPENDIX A

NOTICE OF VIOLATION

Wolf Creek Nuclear Operating Corporation
Wolf Creek Generating Station

Docket: 50-482
Operating License: NPF-42

During an NRC inspection conducted on March 14-18, 1988, a violation of NRC requirements was identified. The violation involved the failure to lock a high radiation area. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (1987), the violation is listed below:

High Radiation Area Controls

Technical Specification 6.12.2 requires that areas assessable to personnel with radiation levels greater than 1000 mrem/hr at 18 inches from the radiation source shall be provided with locked doors to prevent unauthorized entry.

Contrary to the above, on March 17, 1988, an NRC inspector determined that a high radiation area greater than 1000 mrem/hr (1300 mrem/hr) at 18 inches from the radiation source on the portable demineralizer located in the low level drum storage area of the radwaste building was not provided with a locked door to prevent unauthorized entry into the area.

This is a Severity Level IV violation. (Supplement IV)(482/8809-01)

Pursuant to the provisions of 10 CFR 2.201, Wolf Creek Nuclear Operating Corporation is hereby required to submit to this office, within 30 days of the date of the letter transmitting this Notice, a written statement or explanation in reply, including for each violation: (1) the reason for the violation if admitted, (2) the corrective steps which have been taken and the results achieved, (3) the corrective steps which will be taken to avoid further violations, and (4) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time.

Dated at Arlington, Texas,
this *15th* day of *April* 1988.