



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DETROIT EDISON COMPANY

WOLVERINE POWER SUPPLY COOPERATIVE, INCORPORATED

DOCKET NO. 50-341

FERMI-2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 27
License No. NPF-43

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Detroit Edison Company (the licensee) dated January 27, 1988, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. NPF-43 is hereby amended to read as follows:


Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. , and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. DECo shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

8808090165 880805
PDR ADOCK 05000341
PDC

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Martin J. Virgilio, Director
Project Directorate III-1
Division of Reactor Projects - III, IV, V
& Special Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 5, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 27

FACILITY OPERATING LICENSE NO. NPF-43

DOCKET NO. 50-341

Replace the following page of the Appendix "A" Technical Specifications with the attached page. The revised page is identified by Amendment number and contains a vertical line indicating the area of change. The corresponding overleaf page is also provided to maintain document completeness.

REMOVE

3/4 3-61

INSERT

3/4 3-61

TABLE 3.3.7.5-1
ACCIDENT MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>REQUIRED NUMBER OF CHANNELS</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE OPERATIONAL CONDITIONS</u>	<u>ACTION</u>
1. Reactor Vessel Pressure	2	1	1, 2	80
2. Reactor Vessel Water Level, Fuel Zone	2	1	1, 2	80
3. Suppression Chamber Water Level	2	1	1, 2	80
4. Suppression Chamber Water Temperature	2	1	1, 2	80
5. Suppression Chamber Air Temperature	2	1	1, 2	80
6. Suppression Chamber Pressure	2	1	1, 2	80
7. Drywell Pressure, Wide Range	2	1	1, 2	80
8. Drywell Air Temperature	2	1	1, 2	80
9. Drywell Oxygen Concentration***	2	1	1, 2	80
10. Drywell Hydrogen Concentration	2	1	1, 2	80
11. Safety/Relief Valve Position Indicators	1*/valve	1*/valve	1, 2	80
12. Containment High Range Radiation Monitor	2	2	1, 2, 3	81
13. Standby Gas Treatment System Radiation Monitors**	2	1	1, 2, 3	81
14. Neutron Flux	2	1	1, 2	80
15. Drywell Sump Level	2	1	1, 2	80
16. Primary Containment Isolation Valve Position	1/valve	1/valve	1, 2, 3	80

*Pressure switch

**High (accident) range noble gas monitors

***See Special Test Exception 3.10.5

TABLE 3.3.7.5-1 (Continued)

ACCIDENT MONITORING INSTRUMENTATION

ACTION STATEMENTS

ACTION 80 -

- a. With the number of OPERABLE accident monitoring instrumentation channels less than the Required Number of Channels shown in Table 3.3.7.5-1, restore the inoperable channel(s) to OPERABLE status within 7 days or be in at least HOT SHUTDOWN within the next 12 hours.
- b. With the number of OPERABLE accident monitoring instrumentation channels less than the Minimum Channels OPERABLE requirements of Table 3.3.7.5-1, restore the inoperable channel(s) to OPERABLE status within 48 hours or be in at least HOT SHUTDOWN within the next 12 hours.

ACTION 81 -

- With the number of OPERABLE accident monitoring instrumentation channels less than required by the Minimum Channels OPERABLE requirement, either restore the inoperable channel(s) to OPERABLE status within 72 hours, or:
- a. Initiate the preplanned alternate method of monitoring the appropriate parameter(s), and
 - b. Prepare and submit a Special Report to the Commission pursuant to Specification 6.9.2 within 14 days following the event outlining the action taken, the cause of the inoperability and the plans and schedule for restoring the system to OPERABLE status.