

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

5N 157B Lookout Place

AUG 04 1988

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

In the Matter of ) Docket Nos. 50-327  
Tennessee Valley Authority ) 50-328

SEQUOYAH NUCLEAR PLANT (SQN) LICENSEE EVENT REPORT (LER) 87-001-01  
COMMITMENT - REPORT OF COMPLETION

Reference: LER 87-001-01, "Trip Setpoints for ACBs on Shutdown Boards That  
Feed Control and Auxiliary Building Vent Boards Were Incorrect Due  
To A Design Error," dated March 17, 1988

The referenced LER reported the discovery that the trip setpoints for  
continuous overcurrent were incorrect for the feeder breakers supplying power  
to three Control and Auxiliary Building ventilation boards because of a design  
error. The LER also described corrective actions that had been taken or were  
planned to be taken. One commitment that was made to prevent recurrence of  
the event included the development of a training course and subsequent  
training of Electrical Engineering Branch (EEB) personnel. TVA had committed  
to complete this work by June 15, 1988.

On June 16, 1988, the NRC resident inspector at SQN, the NRC Region II office,  
and the NRC Office of Special Projects were notified that, because of a  
misinterpretation of the required level of training, the commitment had not  
been fully implemented on schedule. Although EEB had conducted informal  
training of its personnel, a training course had not been developed.

The purpose of this letter is to report that the development of the subject  
training course and subsequent training of EEB personnel were completed on  
July 22, 1988, thus fully implementing the recurrence control commitment made  
in the referenced LER.

No new commitments are made in this letter.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

*Ralph H. Shell*

R. Gridley, Manager  
Nuclear Licensing and  
Regulatory Affairs

8808110142 880804  
PDR ADOCK 05000327  
S PDC

IE22  
1/2

cc: See page 2

U.S. Nuclear Regulatory Commission

AUG 04 1988

cc: Ms. S. C. Black, Assistant Director  
for Projects  
TVA Projects Division  
U.S. Nuclear Regulatory Commission  
One White Flint, North  
11555 Rockville Pike  
Rockville, Maryland 20852

Mr. F. R. McCoy, Assistant Director  
for Inspection Programs  
TVA Projects Division  
U.S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

Sequoyah Resident Inspector  
Sequoyah Nuclear Plant  
2600 Igou Ferry Road  
Soddy Daisy, Tennessee 37379