



A Centenor Energy Company

DONALD C. SHELTON
Vice President - Nuclear
(419) 249-2300

Docket No. 50-346

License No. NPF-3

Serial No. 1494

August 1, 1988

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Subject: License Amendment Application to Clarify and Update the Surveillance Requirements for HEPA Filter and Charcoal Adsorber Units on ESF Atmosphere Cleanup Systems (TAC No. 67392).

Gentlemen:

Enclosed is an application for an Amendment to the Davis-Besse Nuclear Power Station, Unit No. 1 Operating License No. NPF-3, Appendix A, Technical Specifications.

This application requests that the Technical Specifications be revised to reflect the changes attached. The proposed changes involve Section 4.6.4.4, Hydrogen Purge System; Section 4.6.5.1, Emergency Ventilation System; and Section 4.7.6.1, Control Room Emergency Ventilation System.

These changes to the Technical Specifications Surveillance Requirements will clarify the testing requirements and update the regulatory and industry guidance references for High Efficiency Particulate Air (HEPA) filters and charcoal adsorber units in Engineered Safety Feature (ESF) cleanup systems. These proposed changes are consistent with the Nuclear Regulatory Commission's Generic Letter No. 83-13, Clarification Of Surveillance Requirements for HEPA Filters and Charcoal Adsorber Units in the Standard Technical Specifications on ESF Cleanup Systems.

Toledo Edison requests that the Technical Specification Amendment be issued by October 30, 1988.


8808120311 880801
PDR ADJCK 05000346
P PDC

App 1
w/check #150
#:20003

Docket No. 50-346
License No. NPF-3
Serial No 1494
Page 2

Enclosed is a check for \$150 as required by 10CFR170.12(c) for a License Amendment application.

Very truly yours,



MHL/sag

Enclosures

cc: DB-1 Resident Inspector
A. B. Davis, Regional Administrator
A. W. DeAgazio, NRC/NRR Davis-Besse Project Manager
State of Ohio