



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

OMAHA PUBLIC POWER DISTRICT

DOCKET NO. 50-285

FORT CALHOUN STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 112  
License No. DPR-40

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by the Omaha Public Power District (the licensee) dated March 9, 1988, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8804280163 880419  
PDR ADOCK 05000285  
P PDR

2. Accordingly, Facility Operating License No. DPR-40 is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B. of Facility Operating License No. DPR-40 is hereby amended to read as follows:

B. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 112, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. The license amendment is effective as of its date of issuance and shall be implemented not later than October 1988.

FOR THE NUCLEAR REGULATORY COMMISSION

*Jose A. Calvo*  
Jose A. Calvo, Director  
Project Directorate - IV  
Division of Reactor Projects - III,  
IV, V and Special Projects  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: April 19, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 112

FACILITY OPERATING LICENSE NO. DPR-40

DOCKET NO. 50-285

Revise Appendix "A" Technical Specifications as indicated below. The revised page is identified by amendment number and contains vertical lines indicating the area of change.

Remove Page

3-59

Insert Page

3-59

### 3.0 SURVEILLANCE REQUIREMENTS

#### 3.7 Emergency Power System Periodic Tests (Continued)

- i. Initiation of a simulated auto-start signal to verify that the diesel starts, followed by,
- ii. Initiation of a simulated simultaneous loss of 4.16 KV supplies to bus 1A3 (1A4). Proper operation will be verified by observation of:
  - (1) De-energization of bus 1A3 (1A4).
  - (2) Load shedding from bus (both 4160 V and 480 V).
  - (3) Energization of bus 1A3 (1A4).
  - (4) Automatic sequence start of emergency load, and
  - (5) Operation of  $\geq 5$  minutes while its generator is loaded with the emergency load.
- iii. Verification that emergency loads do not exceed the 2000-HR KW rating of the engine. <sup>(2)</sup>
- d. Manual control of diesel generators and breakers shall also be verified during refueling shutdowns.
- e. Each diesel generator shall be given a thorough inspection on a refueling (R) frequency in accordance with the manufacturer's recommendations for this class of standby service.\*
- f. The fuel oil transfer pumps shall be verified to be operable each month.

#### (2) Station Batteries

- a. Every month the voltage of each cell (to the nearest 0.01 volt), the specific gravity, and temperature of a pilot cell in each battery shall be measured and recorded. <sup>(3)(4)</sup>
- b. Every three months the specific gravity of each cell, the temperature reading of every fifth cell, and the amount of water added shall be measured and recorded. During the first refueling outage and every third refueling outage thereafter the batteries shall be subjected to a rated load discharge test.
- c. At monthly intervals the third battery charger, which is capable of being connected to either of the two D.C. distribution buses, shall be paralleled in turn to each D.C. bus. In each case, load shall be transferred to this reserve battery charger by switching out the normal charger. The reserve charger shall be run on load for 30 minutes on each bus and the system shall finally be returned to normal.

\*A one time extension has been granted for this surveillance requirement, allowing the April 1988 surveillance for Diesel Generator No. 1 to be completed in October 1988.