



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555  
August 3, 1988

PHILADELPHIA ELECTRIC COMPANY  
PUBLIC SERVICE ELECTRIC AND GAS COMPANY  
DELMARVA POWER AND LIGHT COMPANY  
ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-277

PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 134  
License No. DPR-44

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Philadelphia Electric Company, et al. (the licensee) dated October 19, 1987, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I.
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health or safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. DPR-44 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 134, are hereby incorporated in the license. PECO shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Robert E. Martin for  
Walter R. Butler, Director  
Project Directorate I-2  
Division of Reactor Projects I/II

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: August 3, 1988

PDI-2/LA  
MOR  
7/27/88

PDI-2/PM  
REM  
7/19/88

OGC  
7/27/88


PDI-2/D  
WButler  
7/29/88

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 134, are hereby incorporated in the license. PECO shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

  
Walter R. Butler, Director  
Project Directorate I-2  
Division of Reactor Projects I/II

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: August 3, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 134

FACILITY OPERATING LICENSE NO. DPR-44

DOCKET NO. 50-277

Replace the following page of the Appendix A Technical Specifications with the enclosed page. The revised areas are indicated by marginal lines.

Remove

77

Insert

77

TABLE 3.2.F SURVEILLANCE INSTRUMENTATION

Item	Minimum No. of Operable Instrument Channels	Parameter	Instrument	Type Indication and Range	Action*
1	2	Reactor Water Level (narrow range)	LR-2(3)-6-96 LI-2(3)-6-94A,B,C	Recorder 0 to 60 inches Indicator 0 to 60 inches	(1) (2) (3)
2	2	Reactor Water Level (wide range)	LR-2(3)-2-3-110A,B (Green Pen)	Recorder -165 to +60 inches	(10) (11)
3	2	Reactor Water Level (fuel zone)	LR-2(3)-2-3-110A,B (Red Pen)	Recorder -325 to +60 inches	(10) (11)
4	2	Reactor Pressure	PR-2(3)-6-96 PR-2(3)-2-3-404A,B PI-2(3)-6-90A,B,C	Recorder 0 to 1500 psig Indicator 0 to 1200 psig	(1) (2) (3)
5	2	Drywell Pressure	PR-4(5)805 (Pen 2) PR-2(3)508 (Pen 2)	Recorder 0 to 70 psig	(1) (2) (3)
6	2	Drywell Pressure (wide range)	PR-8(9)102A,B (Red Pen)	Recorder 0 to 225 psig	(8) (9)
7	2	Drywell Pressure (subatmospheric range)	PR-8(9)102A,B (Green Pen)	Recorder 5 to 25 psia	(8) (9)
8	2	Drywell Temperature	TR-4(5)805 (Pen 1) TI-2(3)501	Recorder 40 to 440 degrees F Indicator 40 to 440 degrees F	(1) (2) (3) (1) (2) (3) (12)
9	2	Suppression Chamber Water Temperature	TR-8(9)123A,B TIS-2(3)-2-71A,B	Recorder 30 to 230 degrees F Indicator 30 to 230 degrees F	(1) (2) (3) (6)
10	2	Suppression Chamber Water Level (narrow range)	LR-8(9)027 LI-8(9)027	Recorder 13.7 to 15.7 feet Indicator 13.7 to 15.7 feet	(1) (2) (3)

Amendment No. 134  
APR 24, 85, 115, 120, -77-

PBAPS Unit 2



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

PHILADELPHIA ELECTRIC COMPANY  
PUBLIC SERVICE ELECTRIC AND GAS COMPANY  
DELMARVA POWER AND LIGHT COMPANY  
ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-278

PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 137  
License No. DPR-56

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Philadelphia Electric Company, et al. (the licensee) dated October 19, 1987, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I.
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health or safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. DPR-56 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 137, are hereby incorporated in the license. PECO shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Robert E. Martin for  
Walter R. Butler, Director  
Project Directorate I-2  
Division of Reactor Projects I/II

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: August 3, 1988

RDI-2/LA  
MO'Brien  
7/27/88

RDI-2/PM  
REMartin:tr  
7/27/88

OGC/ly  
m/ly  
7/27/88


RDI-2/D  
WButler  
7/29/88

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 137, are hereby incorporated in the license. PECO shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

  
for Walter R. Butler, Director  
Project Directorate I-2  
Division of Reactor Projects I/II

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: August 3, 1988



ATTACHMENT TO LICENSE AMENDMENT NO. 137

FACILITY OPERATING LICENSE NO. DPR-56

DOCKET NO. 50-278

Replace the following page of the Appendix A Technical Specifications with the enclosed page. The revised areas are indicated by marginal lines.

Remove

77

Insert

77

TABLE 3.2.F SURVEILLANCE INSTRUMENTATION

Item	Minimum No. of Operable Instrument Channels	Parameter	Instrument	Type Indication and Range	Action*
1	2	Reactor Water Level (narrow range)	LR-2(3)-6-96 LI-2(3)-6-94A,B,C	Recorder 0 to 60 inches Indicator 0 to 60 inches	(1) (2) (3)
2	2	Reactor Water Level (wide range)	LR-2(3)-2-3-110A,B (Green Pen)	Recorder -165 to +60 inches	(10) (11)
3	2	Reactor Water Level (fuel zone)	LR-2(3)-2-3-110A,B (Red Pen)	Recorder -325 to +60 inches	(10) (11)
4	2	Reactor Pressure	PR-2(3)-6-96 PR-2(3)-2-3-404A,B PI-2(3)-6-90A,B,C	Recorder 0 to 1500 psig Indicator 0 to 1200 psig	(1) (2) (3)
5	2	Drywell Pressure	PR-4(5)805 (Pen 2) PR-2(3)508 (Pen 2)	Recorder 0 to 70 psig	(1) (2) (3)
6	2	Drywell Pressure (wide range)	PR-8(9)102A,B (Red Pen)	Recorder 0 to 225 psig	(8) (9)
7	2	Drywell Pressure (subatmospheric range)	PR-8(9)102A,B (Green Pen)	Recorder 5 to 25 psia	(8) (9)
8	2	Drywell Temperature	TR-4(5)805 (Pen 1) TI-2(3)501	Recorder 40 to 440 degrees F Indicator 40 to 440 degrees F	(1) (2) (3) (1) (?) (3) (12)
9	2	Suppression Chamber Water Temperature	TR-8(9)123A,B TIS-2(3)-2-71A,B	Recorder 30 to 230 degrees F Indicator 30 to 230 degrees F	(1) (2) (3) (6)
10	2	Suppression Chamber Water Level (narrow range)	LR-8(9)027 LI-8(9)027	Recorder 13.7 to 15.7 feet Indicator 13.7 to 15.7 feet	(1) (2) (3)

Amendment No. AG, 28, 95, 127, 131, 137

-77-

PBAPS Unit 3